

3215 RILEY AV

04107106

12/21/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

FEE: NA

DATE: _____

APPLICATION FOR IMPROVEMENT PERMIT FOR RESIDENTIAL SITE INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM

( ) CRT

TYPE APPLICATION: __ NEW SYSTEM __ EXPANSION/ ALTERATION OF EXISTING SYSTEM ✓ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

FILE #: 1439B

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 041-071-06

STREET ADDRESS: 3215 Riley Ave.

SUBDIVISION OR MOBILE HOME PARK NAME:

LOT NUMBER:

TOWNSHIP (CHECK ONE):

__ 0 MECKLENBURG
✓ 1 CHARLOTTE
__ 2 DAVIDSON
__ 3 CORNELIUS
__ 4 PINEVILLE
__ 5 MATTHEWS
__ 6 HUNTERSVILLE
__ 7 MINT HILL

TYPE OF BUILDING (CHECK ONE):

__ SINGLE MOBILE HOME(S)
__ DOUBLE WIDE (D)
✓ HOUSE (H)
__ MODULAR HOME (M)
__ MULTIPLE FAMILY (U)
__ OTHER (O)

HEATED SQUARE FOOTAGE: 624 App.

NUMBER OF BEDROOMS: 2 NUMBER OF OCCUPANTS: 2

FOUNDATION FOR RESIDENCE: Brick MAS-

__ WITHOUT BASEMENT
__ ON SLAB
__ CRAWL SPACE
__ WITH BASEMENT /PLUMBING
__ WITH BASEMENT /NO PLUMBING

7/31/96 No repair approval necessary
Derita Post Office
Per property owner - line from S.T. to D-BOXES cleared of sludge.
No Land Form See notes on copy of repair application in file for

IF EXPANSION/ALTERATION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED BUILDING ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: __ YES ✓ NO TYPE: _____

WATER SUPPLY (CHECK ONE):

__ COMMUNITY (C)
__ MUNICIPAL (M)
✓ PRIVATE WELL (P)
__ SHARED WELL (S)
__ OTHER 'SPRINGS' (O)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES __ YES __ NO
EXISTING WASTEWATER SYSTEMS ✓ YES __ NO
EASTMENTS OR RIGHT-OF-WAYS ✓ YES __ NO
WELL, SPRINGS OR WATERLINES ✓ YES __ NO
DESIGNATED WETLANDS __ YES __ NO

PROPERTY OWNER:

NAME: Covington Wilson Howard
(LAST) (FIRST) (MI)

ADDRESS: 8078 McConnell Rd.

CITY: Denver STATE: N.C. ZIP: 28037

DAYTIME PHONE: ( ) 483-2175

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME:
(LAST) (FIRST) (MI)

DAYTIME PHONE: ( ) -

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? ?

An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

SIGNED: W.H. Covington DATE: 5-23-96

Built 1948

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102

Mecklenburg County
Health Department

Dear Sir/Madam:

A request for repair to your septic system has come to our attention.

In addition to the enclosed application form, there is information that we will need in order to assist us in determining the best means of repair to your system.

Please supply the following information, if possible, along with your completed, signed, and dated application:

1) Tax number (account number from tax bill).
041-071-06

2) Provide the name of the original property owner.
I Bought From Original Owner + Builder Mr. W.J. Beaver (Now Deceased)
App 1944-45

3) Do you have visible sewage on the surface of the ground?
Water ONLY Comes up Near TANK

4) Is septic water backing up into the house -- gurgling pipes and/or slow draining toilets, etc?
NO

5) Is there a separate wastewater line from your washing machine? Dishwasher?
yes

6) Has your septic tank ever been pumped out? If so, approximately when?
yes 2 Times IN last 2 yrs. Last Time Appr. March 96

7) Has there been any other type of maintenance or repair done to your system? If so, what was done, and approximately when?
NO

8) Approximately what year was your septic system installed?
App-50 yrs ago 1946

9) Have you had any other plumbing leaks (dripping faucets/leaking toilets, etc)? (NO)
Surface Water Runs Under House + after Storms

Tenant Carol Deaton 596-6800

Upon receipt of your repair application, an Environmental Health Specialist will contact you to discuss your septic problem. If it is determined that a repair to the system is needed, you will need to contact a registered septic contractor -- if you do not know of one, check the yellow pages of your telephone directory. The contractor will, in return, contact our office to set up an appointment with an Environmental Health Specialist to meet with you on the site to assess the problem and make arrangements to repair the septic system if necessary.

By complying with our requests and supplying the needed information in its entirety, you will be helping us to serve you as quickly as possible. Please mail or fax information to MCHD. Fax # 336-6894.

Should you have questions concerning the requested information, please feel free to call us at 336-5102.

Environmental Health Division
700 North Tryon Street • Suite 211 • Charlotte, North Carolina 28202-2236

Retain as part of file 1439B

FEE: NH

DATE: _____

APPLICATION FOR IMPROVEMENT PERMIT
FOR RESIDENTIAL SITE
INDIVIDUAL WATER AND WASTEWATER
SYSTEMS PROGRAM

Mecklenburg Board of Health | 1 | CRT

TYPE APPLICATION: __ NEW SYSTEM __ EXPANSION/ ALTERATION OF EXISTING SYSTEM ✓ REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COPY

FILE #: 1439B

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 041-071-06

STREET ADDRESS: 3215 Riley Ave.

SUBDIVISION OR MOBILE HOME PARK NAME:

LOT NUMBER:

TOWNSHIP (CHECK ONE):

__ 0 MECKLENBURG
✓ 1 CHARLOTTE
__ 2 DAVIDSON
__ 3 CORNELIUS
__ 4 PINEVILLE
__ 5 MATTHEWS
__ 6 HUNTERSVILLE
__ 7 MINT HILL

TYPE OF BUILDING (CHECK ONE):

__ SINGLE MOBILE HOME(S)
__ DOUBLE WIDE (D)
✓ HOUSE (H)
__ MODULAR HOME (M)
__ MULTIPLE FAMILY (U)
__ OTHER (O)

HEATED SQUARE FOOTAGE: 624 Appr.

NUMBER OF BEDROOMS: 2 NUMBER OF OCCUPANTS: 2

FOUNDATION FOR RESIDENCE: Brick Mas-

__ WITHOUT BASEMENT
__ ON SLAB
__ CRAWL SPACE
__ WITH BASEMENT /PLUMBING
__ WITH BASEMENT /NO PLUMBING

Derita Post Office

No Record found

CAN be Extended if they apply

IF EXPANSION/ALTERATION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED BUILDING ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: __ YES ✓ NO TYPE: _____

WATER SUPPLY (CHECK ONE):
__ COMMUNITY (C)
__ MUNICIPAL (M)
✓ PRIVATE WELL (P)
__ SHARED WELL (S)
__ OTHER 'SPRINGS' (O)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES __ YES __ NO
EXISTING WASTEWATER SYSTEMS ✓ YES __ NO
EASTMENTS OR RIGHT-OF-WAYS ✓ YES __ NO
WELL, SPRINGS OR WATERLINES ✓ YES __ NO
DESIGNATED WETLANDS __ YES __ NO

6/4 PC to Mr. Covington @ 11:00
NC. Left on ans. machine.

PROPERTY OWNER:	LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:
NAME: Covington Wilson Howard (LAST) (FIRST) (MI)	NAME: 6/4 PC w/ Mr. Covington (LAST) (FIRST) (MI)
ADDRESS: 8078 McConnell Rd.	DAYTIME PHONE: ( ) –
CITY: Denver STATE: N.C. ZIP: 28037	6/4 PC w/ Bobby Spruce Owner - Sewer available w/ Ext.
DAYTIME PHONE: ( ) 483-2175	

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? ~~6/5 PC to MR~~ ~~6/5 PC to~~ PC w/ Mr. Covington W.J. Frick

An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

6/4 PC to Mr Covington
NC Left message about Ext.


SIGNED W. H. Covington DATE: 5-23-96

Built 1948

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CER., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102

OVER →

4S




Friley Ave

7/31 OSV. No answer @ door. Soil disturbed over S.T. D-Box. No visible malfunction. Left bus. card for tenant

7/31 PC w/ Wilson Conington. Staked 2 D-Boxes in sequence. Line clogged from S.T. to first D-Box & then from first D-Box to 2nd D-Box - rodded out nitrification lines; No more problems with septic system - no straight pipes. Advised Mr. Conington to contact me @ further work on septic system necessary.

4S PC w/ Bobby Spires @ CMUD - Sewer avail. w/ Extension up from lowpt @ Friley.

4/5 OSV. No answer @ door. Area over S.T. disturbed - soil wet. Probed drainfield - Saturated. Possible seepage between S.T. & D-Box



4/6 PC to Conington's NC. Left an answer machine

4/10 OSV. Mr Wilson Conington & his son Steve present. Water pooled in crawlspace. Per Steve no plumbing breaks - surface water. Advised to do surface water diversion upslope from house, re-check under house, uncover line from ST to D-Box - contact me. Recommended they pay CMUD tap fee for extension; however, no effluent observed on ground surface today.