Date Issued 11-14-79 **Serial** 3200

C of A (s) No. 7261

T C No 001-023-49

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Herndon (LAST), Michael (FIRST) D. (MIDDLE)

Location of Property 16333 Terry Lane

Application Number 7261 Permit Number 7261

Inspection Data:

Liquid Capacity of Tank 1500 gallons Tank Material p/c concrete

Total Length of Drain Tile 495' +125' Number of Lines 5 + 4

Depth of Filter Material 17" Cover Depth 15"

Water Supply Source well Distance from Water Source >50'

Excavation Inspected ____ (DATE) Tank Inspected ____ (DATE)

Nitrification Field Inspected 11-14-79 (DATE)

Washing Machine Disposal Inspected If Applicable 11-14-79 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed constructed altered or repaired in substantial accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Poor soils

Mike Sexton
Environmentalist

EHD-S-76

Environmental Health Department's Copy