Date Received _____

APT No. 1-1-1

T C. No. [illegible]

Map Date _____

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

## APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER HARRIS (LAST) Jno C.D Harris (FIRST) Jr (MIDDLE)

2) ADDRESS OF OWNER 1213 N. Tryon St ZIP 28206

3) PHONE NO. Home 364-3019 Office 333-4410


4) LOCATION OF PROPERTY Williamsburg Circle (STREET OR COUNTY ROAD)

5) SUBDIVISION Westminster Park #2 LOT NO. 44 BLOCK NO. A

MAP BOOK NO 11 PAGE NO 128

6) DEED REFERENCE DEED BOOK 2495 PAGE NO 128

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Jno C.D Harris Jr
OWNER

C.D. Harris Pres.

EHD-5-76

Environmental Health Department's Copy

Date Received 10-6-82

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
OCT - 6 1982

SIR No. 16142

T C No. 25-13C(1)

Map Date

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

## APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER HARRIS (LAST) & WALTER (FIRST) D (MIDDLE) Inc

2) ADDRESS OF OWNER 1913 N TRYON St ZIP 28206

3) PHONE NO. Home 364-3019 Office 333 4410

4) LOCATION OF PROPERTY WILLIAMSBURG CIRCLE (STREET OR COUNTY ROAD)


5) SUBDIVISION WESTMINSTER PARK LOT NO 4 BLOCK NO A

MAP BOOK NO 11 PAGE NO 128

6) DEED REFERENCE DEED BOOK 2495 PAGE NO 128

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge

COPY OF FORMER SOIL TEST RESULTS SENT 10-7-82 - per Bill Harlin




7) ACCURATELY DIAGRAM & DIMENSION LOT

J W & C D Harris Jr
OWNER
C. D. Harris Pres

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

16147
025-153-07

(Ground Absorption Sewage Disposal)

OWNER: C. D. HARRIS
ADDRESS: 1713 N. TRYON ST.
COUNTY: CHARLOTTE, 28206
LOCATION OF SITE: WILLINGBURG CIRCLE

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 20085

| FACTORS | AREA 1 | AREA 2 | AREA 3 | AREA 4 |
|---|---|---|---|---|
| 1. SLOPE (Z) | S (PS) U — 0—10 | S PS U | S PS U | S PS U + |
| 2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay) | S PS (U) — clayey 2-1 | S PS U | S PS U | S PS U |
| 3. SOIL STRUCTURE (12.36 in.) (Clayey Soils) | S PS (U) — MASSIVE | S PS U | S PS U | S PS U |
| 4. SOIL DEPTH (In.) | S PS (U) — <48 | S PS U | S PS U | S PS U |
| 5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock) | S PS (U) — Clay | S PS U | S PS U | S PS U |
| 6. SOIL DRAINAGE/GROUNDWATER (External & Internal) | S PS (U) — SLOW | S PS U | S PS U | S PS U |
| 7. SOIL PERMEABILITY (Percolation Rate) | S PS (U) — SLOW | S PS U | S PS U | S PS U |
| 8. OTHER (Specify) | S PS U | S PS U | S PS U | S PS U |
| 9. SITE CLASSIFICATION | ✓ UNSUITABLE | | | |
| SOIL SERIES | HELENA | | | |

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: W. B. Ramsey
Title: Soil Scientist Date: 9-11-79

DHS Form 2601 (2/77)
Sanitation

2


103
HELENN
0-10
Lot 4
200
Williamsburg Circle

**MECKLENBURG COUNTY**
**DEPARTMENT OF ENVIRONMENTAL HEALTH**
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 16147

T.C. # 025-153-07

DATE Sept. 13, 1979

NAME OF OWNER C.D. Harris

ADDRESS OF OWNER 1713 North Tryon St.

LOCATION OF LOT Williamsburg Circle, Lot 4-A

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

**Soil Structure Massive**

**Soil Permeability Slow**

**Site Classification Unsuitable**

John R. Adkisson

John R. Adkisson, Environmentalist

R