Date Received 5 Sept 72

Application No. 7481

T. C. No. PO 217-041-23

Map Date 14-E-23

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR WELL WATER SUPPLY PERMIT

NAME OF OWNER Bailey (LAST) Raymond (FIRST) Robert (MIDDLE)

ADDRESS OF OWNER 2242 Markham Court ZIP 28205

PHONE NO. Home 536-0715 Office 372-2430

LOCATION OF PROPERTY # 15224 Regina Lane (STREET OR COUNTY ROAD)


SUBDIVISION _____ LOT NO. 14 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

DEED REFERENCE: DEED BOOK _____ PAGE NO. _____

WELL CONTRACTOR _____ LICENSE NO. _____

Application is hereby made to the Mecklenburg County Health Department for a permit to drill a water well on the hereinabove described lot to be used as a source of _____ individual, _____ semi public, or _____ public water supply



ACCURATELY DIAGRAM & DIMENSION LOT

DATE OF APPLICATION

Raymond R. Bailey
OWNER

Application approved and permit hereby granted

Permit No: 7481

ENVIRONMENTALIST

FORM NO. E-20-9-1-72

HEALTH DEPARTMENT'S COPY

D

Date Received 2-13-94

APT No 7481

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

S & S Development Corp
By Pres.

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Stallsmith Richard Eugene
LAST FIRST MIDDLE

2) ADDRESS OF OWNER Rt 2, Box 138 Midland, N.C. ZIP 28107

3) PHONE NO. Home 888-2731 Office

4) LOCATION OF PROPERTY Rogers Lane — Off Flowers Rd
STREET OR COUNTY ROAD


5) SUBDIVISION LOT NO BLOCK NO

MAP BOOK NO PAGE NO.

6) DEED REFERENCE DEED BOOK 2723 PAGE NO. 367

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and on on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

Mail to:
Ray Bowley
2242 Markham Ct.
Ch. 28205



7) ACCURATELY DIAGRAM & DIMENSION LOT

S & S Development Corp
By Richard E. Stallsmith Pres.
OWNER

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 4030

PTR No 7481
P.O.
T C No 217-041-23

Date Issued February 14, 1974

Map Date 2-14-73

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Stikeleather (LAST) Richard (FIRST) Eugene (MIDDLE)

ADDRESS OF OWNER Rt. 2, Box 138, Midland, N.C. ZIP
c/o Ray Bowley, 2242 Markham Ct., 28205

LOCATION OF PROPERTY Regena Lane (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot

The percolation rate determined by the test was 50 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

Director, Environmental Health Division or
Authorized Section Head

FORM NO E-2-9-1-72

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 9-24-74

ICAR'S Application No 7481

T C No 217-041-23

Map Date 2-19-23


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that or parts described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1) ✓ Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

13) NAME OF OWNER Bowley (LAST) Raymond (FIRST) Robert (MIDDLE)

14) ADDRESS OF OWNER 2242 Hawkins Court

15) PHONE NO Home 536-0715 Office 372-2130

16) LOCATION OF SYSTEM Regina Lane (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No 14 Block No _____

Map Book No _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____ PR→ 50

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN 2-13-74

20) PTR NUMBER (See Instructions) 7481

The undersigned person herein agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION July 12, 1974

OWNER Raymond R. Bowley

Form No E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued July 24, 1974 **Serial No.** 4316

LA No 7481 P.O.

T C No 217-041-22

Map Date 2-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Bouley (LAST) Raymond (FIRST) Robert (MIDDLE)

ADDRESS OF OWNER 2242 Markham Court ZIP

LOCATION OF LOT Regina Lane (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 14 BLOCK NO

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 50 min/in on on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 7481. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

R.M Reynolds
Environmentalist

John R Johnson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 5916 ICAR(S) Permit No 7481

Date Issued 22 Jul 74 FC T C No 217-041-23

Map Date 14 Jul 73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7481, dated 24 Jul 74 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 19 Dec 74, after which date this permit shall be null and void



PLOT OF SYSTEM

Percolation Rate 30

Liquid Capacity of Tank 1000

Tank Construction PC

Absorption and/or Nitrification Lines

Total Line Length 370' + 150' (WM 3 (75' x 50' 417"))

Number of Lines 6 (5 x 62' x 1')

Distance from House 10'

Distance from Property Line 12'

Distance from Well 100'

NAME OF OWNER Conley, Raymond Herbert

LOCATION OF PROPERTY Regina Lane (Lot 14)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used

Comments FC: Lawn (Curtis)

Trench will consist over about 1/2 property - Lawn before trenching work

Division or Section Head

Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired

E-5-9-1-72

Serial No. 5530

C of A (s) No 7481

Date Issued 22 Dec 74

T C No 217-C41-23

Map Date 14 Feb 73

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Parks (LAST) Raymond (FIRST) Tate (MIDDLE)

Location of Property Virginia Lane (Lot 14)

Application Number 7481 Permit Number 7481

Inspection Date:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 555'+150'=705' Number of Lines 6 (3'x3'x12")

Depth of Filter Material 17" Cover Depth 18-24"

Water Supply Source Individual Distance from Water Source 100'

Excavation Inspected 11 Dec 74 (DATE) Tank Inspected 11 Dec 74 (DATE)

Nitrification Field Inspected 11 Dec 74 (DATE)

Washing Machine Line Inspected, If Applicable 23 Dec 74 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ~~/~~ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit as well as in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Lot 14 - Lane (Cont.)

Environmentalist

FORM NO E-6-9-1-72

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. 6-27-74
2. 6-28-74
3. _____

SDR No. 7432
T.C. No. [illegible] on Of 031-163-03

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

6- -74

NAME OF OWNER [illegible]

ADDRESS OF OWNER [illegible] Davidson Highway, Mooresville, N. C. ZIP _____

LOCATION OF LOT [illegible]

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	6-4-74	200+ min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

X ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) 6-17-74 - The lot consists of soils of the [illegible] series. These soils have plastic and sticky clay subsoils which contain swelling clay minerals. They may also have a seasonal perched high water table during periods of high rainfall. These soil characteristics result in inadequately slow [illegible] ility and percolation rate (true mean perc. rate in excess of 150 min./in).

Soil investigation confirmed 6-26-74.

[illegible] Soil Scientist

[illegible] Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70