SEE INSTRUCTIONS ON BACK

Date Received JUNE 6, 1973 ICAR(S) Application No 6434

T C No

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ✓ Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms 2

5) Business Use Max No Employees X

6) Washing Machine Yes ✓ No

7) Garbage Disposal Yes ✓ No

8) Dishwasher Yes ✓ No

9) Water Supply

A) Individual System

B) Government System

C) Community System

1 Well Private ✓

2 Government

10) Sewage System

House located within 200 feet of public sewer Yes No

House located within 200 feet of community sewer Yes ✓ No

11) FHA Case No No

12) VA Case No No

13) NAME OF OWNER ~~Charles~~ Robinson (LAST) Charles (FIRST) Macown (MIDDLE)

14) ADDRESS OF OWNER 2409 Hargett Rd. Matthe[redacted] N.C.

15) PHONE NO Home 537-5687 Office X

16) LOCATION OF SYSTEM 2409 Hargett Rd. Matthews, N.C. (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No _____ Block No. _____

Map Book No [redacted] Page No. [redacted]

18) DEED REFERENCE — DEED BOOK 2805 AT PAGE 208

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES NO DATE RUN 1970

20) PTR NUMBER (See Instructions) 1 yes, 3 years ago

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

JUNE 6, 1973
DATE OF APPLICATION

Charles Macown Robinson
OWNER

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued June 8, 1973 Serial No. 3811 ICAR(S) Permit No. 6454

T. C. No. 193-141-21

Map Date 11-11-72


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 6454 dated June 6, 1973 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before July 5, 1973, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1000

Tank Construction Concrete

Absorption and/or Nitrification Lines:

Total Line Lenght 300'

Number of Lines 4

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Charles Macown Robinson

LOCATION OF PROPERTY 2409 Hargett Rd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: 10' x 75' (1)" stone - aerate pipe trench

Hagler Winkler, Contractor

Division or Section Head

Thomas R. Ward
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO E 5-4-1-71

HEALTH DEPARTMENT'S COPY

Serial No. 3553

C of A (s) No. 6434

Date Issued 6-15-93

T. C. No.

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Robinson (LAST) Charles (FIRST) Marcus (MIDDLE)

Location of Property 2409 Harget Rd.

Application Number 6434 Permit Number 6434

Inspection Data:

Liquid Capacity of Tank 1500 gal. Tank Material pre cast con

Total Length of Drain Tile 300' Number of Lines 4

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 6-15-93 (DATE) Tank Inspected 6-15-93 (DATE)

Nitrification Field Inspected 6-15-93 (DATE)

Washing Machine Line Inspected, If Applicable ~~6-15~~ (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: Installed by Slagle & Winbeth

Thomas R. Wood

Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY