BF 5-3-83

C of A (s) No 18295

Date Issued 19 May 83 Serial 5841 T C. No 197-103-99

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner [redacted] (LAST) (FIRST) (MIDDLE)

Location of Property 8245 [redacted] Rd.

Application Number 18295 Permit Number 18295

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 230' Number of Lines 3

Depth of Filter Material 12" Cover Depth 18"

Water Supply Source Well Distance from Water Source > 100'

Excavation Inspected 19 May 83 (DATE) Tank Inspected 19 May 83 (DATE)

Nitrification Field Inspected 19 May 83 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

[redacted]
Environmentalist

EHD-S-74

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 7-21-83

Serial No. 6005


ICAR(S) Permit No 18235

T C No 132-109-79

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, __ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18235 dated 7-21-83, and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 21 Nov 83, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate: PS

Liquid Capacity of Tank: 1500

Type: PC

Area: 220'

Number: 3

Distance: >10'

Distance: >10'

NAME OF OWNER: Robert William Donald

LOCATION OF PROPERTY: 8245 Lee Hall Rd

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

3 bedroom - 3 177 x 12' 9' centers

Comments: -

Division or Section Head

Environmentalist W. O. Kirby

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 9-8-81

Serial No. 5241

LA No. 18235

T C No PC 137-103-39

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Noles, (LAST) William (FIRST) Donald (MIDDLE)

ADDRESS OF OWNER Rt. 12, Box 389-B, Charlotte, NC ZIP 28212

LOCATION OF LOT Pine Hill Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 39 BLOCK NO

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 18235 This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

SEE INSTRUCTIONS ON BACK

Date Received 9-1-81

ICAR (S) Application No 18231

T C No. 137-103-P;


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ✓ Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4) No of Bedrooms 2
5) Business Use Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply
A. Individual Well ✓
B. Governmental System ___
C. Community System
1. Well source ___
2. Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER Dixie, (LAST) William (FIRST) Donald (MIDDLE)

14) ADDRESS OF OWNER Rt. 12, Box 359-B, Charlotte NC 28212

15) PHONE NO Home 545-4102 Office 545-4115

16) LOCATION OF SYSTEM Tree Line Dr. (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No 39 Block No. ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ✓ YES NO DATE RUN 1963

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

9-1-81
DATE OF APPLICATION

William D Dixie
OWNER

EHD-5-76 ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 4299

PTR No. 18235

T C No PO 137-103-39

Date Issued 9-8-81

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Moles, William Donald
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER Rt. 12, Box 389-B, Charlotte, NC ZIP 28212

LOCATION OF PROPERTY Pine Hill Road
(STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 39 BLOCK NO



PLOT PLAN

[illegible] Mecklenburg County. [illegible] was conducted

Provisionally Suitable

[illegible] The said lot is approved [illegible] subsurface, soil ob[illegible]

[illegible] Mecklenburg County Depa[illegible]
[illegible] Water Treatment

[illegible] the Mecklen[illegible]

[illegible] system [illegible]

[illegible] in the [illegible] are as accepted [illegible]

[illegible] rules and regulations [illegible] and the Mecklen[illegible] said if at any [illegible] the [illegible] changed such [illegible] approval would not [illegible] granted and the new [illegible] laws, rules and regulations been in effect on the issue date

William H. Mullin
Soil Scientist

John R. Johnson
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 18235
T.C. No. Po137-103-39

(Ground Absorption Sewage Disposal)

OWNER: William D. Nolen
ADDRESS: Rt. 12, Box 389-B
COUNTY: Charlotte, N.C. 28212
LOCATION OF SITE: off Pine Hill Rd

DATE REQUESTED:
PLAT NO:
LOT SIZE: Approx 2 Acres

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-8%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	(S) PS U 48"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (inches) (Impervious strata, Rock)	(S) None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) PS U 24" ground water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (percolation rate)	S (PS) Moderate U	S PS U	S PS U	S PS U
8. OTHER (specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	✓ Provisionally suitable			
10. SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable


** See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments:

Described By: William R. Marlin
Title: Soil Scientist
Date: 9-8-81

DHS Form 2601
Sanitation
EHD 539 (2/80)

✓


Existing House
150
Approx 200'
Cecil
60
White Brick column w/ Mailbox
Pine Hill Rd

Date Received 9-1-81

APT No. 1823 J
PO
T. C No. 137-103-37

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Noles (LAST) William (FIRST) Ronald (MIDDLE)

2) ADDRESS OF OWNER Charlotte Rt. 12 - 28213 ZIP 28212

3) PHONE NO Home 545-4162 Office 545-4115


4) LOCATION OF PROPERTY Pine Hill Road (STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO 39 BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the purpose of a soil investigation to be made by the Mecklenburg County Health Department as described for the purpose of determining if the lot is suitable for the installation of an individual sewage disposal system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

William D Noles
OWNER

EHD-5-76

Environmental Health Department's Copy