Date Received 4/9/80

SEE INSTRUCTIONS ON BACK
MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
APR 8 1980

CAR (S) Application No. 16699

T. C. No. 037-212-03


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) Install or Construct 2) . . . . Alter or Repair on individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home X Yes ___ No
Residence ___ Yes ___ No

4) No of Bedrooms 2

5) Business Use — Max No Employees ___

6) Washing Machine ___ Yes X No

7) Garbage Disposal ___ Yes X No

8) Dishwasher ___ Yes X No

9) Water Supply:
- A) Individual Well ___
- B) Governmental System X
- C) Community System:
  - 1 Well source ___
  - 2 Governmental source ___

10) Sewage System:
House located within 200 feet of public sewer ___ Yes ___ No
House located within 200 feet of community sewer ___ Yes ___ No

11) FHA Case No. ___

12) VA Case No. ___

13) NAME OF OWNER Dancy Homes, Inc., (LAST / FIRST / MIDDLE)

14) ADDRESS OF OWNER 1443 S. Boulevard, Charlotte, N.C.

15) PHONE NO. Home ___ Office 332-6310

16) LOCATION OF SYSTEM Hendrson Circle North - Off Hi hway 115. (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. 10 Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DANCY HOMES, INC.
R. T. Dancy

DATE OF APPLICATION

OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 3/4/80 MAR 3 1980 ICAR(S) Application No. 16699

P.C. No. 037-212-03


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to: Make repairs to existing system

1) _____ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home X Yes ___ No
Residence ___ Yes X No

4) No. of Bedrooms 2
5) Business Use — Max No Employees _____
6) Washing Machine X Yes ___ No
7) Garbage Disposal ___ Yes X No
8) Dishwasher ___ Yes X No
9) Water Supply:
A) Individual Well _____
B) Governmental System Yes
C) Community System:
1. Well source _____
2 Governmental source _____
10) Sewage System:
House located within 200 feet of public sewer ___ Yes ___ No
House located within 200 feet of community sewer ___ Yes ___ No
11) FHA Case No. _____
12) VA Case No. _____

13) NAME OF OWNER Dancy Homes, Inc. (LAST / FIRST / MIDDLE)

14) ADDRESS OF OWNER 1443 South Boulevard, Charlotte, N.C., 28203

15) PHONE NO. Home 332-6310 Office _____

16) LOCATION OF SYSTEM Henderson Circle, off Highway 115 (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. #6 & #8 Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

2/27/80
DATE OF APPLICATION

Dancy Homes, Inc.
M J Dancy
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY


Date Issued 5-7-80 Serial 3894 ICAR(S) Permit No. 16699

T. C. No. 037-212-03

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 16699, dated 2-27-80 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 5-13-80, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate —

Liquid Capacity of Tank —

Tank Construction —

Absorption and/or Nitrification Lines:

Total Line Length 200'

Number of Lines 2

Distance from House 10'

Distance from Property Line 10'

Distance from Well >100'

NAME OF OWNER Dancy Homes, Inc.

LOCATION OF PROPERTY Henderson Circle lot 8

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

add a 6'wide x 15'long x 10'deep overflow pit
keep 6'between beds

Division or Section Head

Mike Sexton
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-74

Environmental Health Department's Copy

Date Issued 7-8-80 Serial 3862

C of A (s) No. 16699

T C No. 037-212-03

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Dancy (LAST) Homes, Inc. (FIRST)

Location of Property lot 8 Metroline North MHP (MIDDLE)

Application Number 16699 Permit Number 16699

Inspection Date:

Liquid Capacity of Tank — Tank Material —

Total Length of Drain Tile 200' Number of Lines 2

Depth of Filter Material 10' Cover Depth 24"

Water Supply Source Community well Distance from Water Source >100'

Excavation Inspected — (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 7-8-80 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ____ installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

one of the trailers (#7 or 8) must be removed from this system if it leaks again.

Mike Sexton

Environmentalist

EHD-S-76

Environmental Health Department's Copy