Serial No. 4125

PTR No 7589
P.O.
T C No 195-041-22
Map Date 12-14-73

Date Issued March 12, 1974

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Thomas (LAST) William (FIRST) P. (MIDDLE)

ADDRESS OF OWNER 4901 Melissa Lane, Matthews, NC. ZIP 28105

LOCATION OF PROPERTY 3724 Peggy Lane (STREET OR COUNTY ROAD)

SUBDIVISION W. F. Thomas Property LOT NO 1f BLOCK NO A



PLOT PLAN

This [illegible] the application [illegible] Mecklenburg County Health Department [illegible] described above. This soil test [illegible] that portion of the lot [illegible] above plat.

The rate for the percolation test was 60*min/in. This [illegible] for the installation of a subsurface sewage disposal system [illegible] discharge subject to the following terms and conditions:

1. A permit to install [illegible] Mecklenburg County Health Department [illegible] system.
2. This approval [illegible] which must be [illegible] by the Health Department [illegible] size and type of building [illegible] structed thereon.
3. This approval is [illegible] the system is installed in the immediate area where percolation test was run.
4. This approval [illegible] grading, filling or construction including the [illegible] laws is performed on the lot which [illegible] Department revises the area of the plat [illegible] run unsuitable for the [illegible] construction, alteration and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void at any time in the future prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

*Results determined by soil analysis.

W. Gayle Lyon Jr. Soil Scientist

Director, Environmental Health Division or Authorized Section Head

FORM NO E-2-9-[illegible]

HEALTH DEPARTMENT'S COPY

Date Received 9/25/73 RECEIVED | ICAR(S) Application No. 73-1

T C No. 195-041-22

Map Date 12-14-73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1. ✓ Install or Construct 2. ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4. No. of Bedrooms 3
5. Business Use Max No. Employees 710
6. Washing Machine ✓ Yes ___ No
7. Garbage Disposal ___ Yes ✓ No
8. Dishwasher ✓ Yes ___ No
9. Water Supply
   A. Individual Well ✓
   B. Governmental System ___
      Community System
      1. Well source ___
      2. Governmental source ___
   Sewage System
   Is property located within 200 feet of
   community sewer Yes ___ No
10. FHA Case No. ___
11. VA Case No. ___

12. NAME OF OWNER Thomas, William P.
    LAST FIRST MIDDLE
13. ADDRESS OF OWNER 4401 Briggs Ave. Charlotte, NC 28212
14. PHONE NO. Home 535-1992 Office
15. LOCATION OF SYSTEM 3724 Briggs Ave. Charlotte, NC (Mint)
    STREET OR COUNTY ROAD
16. SUBDIVISION St. Thomas (Map) Lot No. 16 Block No. H
    Map Book No. 17 Page No. 252
17. DEED REFERENCE - DEED BOOK 3513 AT PAGE 526
18. HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN March 12, 1973
19. PTR NUMBER See Instructions 73-54

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

Sept. 21, 1973
DATE OF APPLICATION

Wm. P. Thomas
OWNER

FORM NO. E-414

HEALTH DEPARTMENT'S COPY

Date Issued 9/29/76

Serial No. 0199

IMPROVEMENTS PERMIT

LA No 7589

T C. No. P.O. 195-041-22

Map Date 12-14-73

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Thomas (LAST) William (FIRST) P. (MIDDLE)

ADDRESS OF OWNER 4901 Melissa Lane, Charlotte, N. C. ZIP 28212

LOCATION OF LOT 3724 Peggy Lane (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 16 BLOCK NO A

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" number 7589 This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation, Construction, Alteration, and or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and or repaired in accordance with a valid Installation, Construction Alteration, and/or Repair Permit

Environmentalist

John R Atkinson

Environmental Health Director, or Authorized Section Head

EHD 5-76

Environmental Health Department's Copy

Date Issued 2-23-77

Serial No. 0493


ICAR (S) Permit No. 2582

T C No 195-041-23

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application _____ dated _____. This permit shall be void and of no effect if the information provided in the application is not true. All work shall be completed on or before 3-22-77 after which date this permit shall be void and of no effect.



Permeability Rate 60

Linear Feet 1500

Type Construction PC

Absorption Trench Dimensions

Width 600 - 150

Number 5 4

Depth 10

Length 14'

Total Area 100'

NAME OF OWNER W F Thomas

LOCATION OF SYSTEM 5724 Piggy Lane

This system is approved subject to requirements set forth in the Regulations of the Mecklenburg County Board of Health and with the understanding that the granting of this permit does not prevent the Health Director from requiring additional work at any time if sewage is found to be unsanitary. No part of the system can be covered up or otherwise rendered inaccessible for inspection until approved. Only _____ may be used.

Comments 3 @ 40 X 34'

40 X 36 X 2'

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

Date Issued 2-22-77

Serial No. 0461

C of A (s) No. 2586

T C No 195-041-23

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Thomas (LAST) W (FIRST) P (MIDDLE)

Location of Property 3224 Reppy Lane

Application Number _____ Permit Number _____

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 600' - 150' Number of Lines 5 - 4

Depth of Filter Material 34" - 12" Cover Depth 24"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected _____ (DATE) Tank Inspected 2-22-77 (DATE)

Nitrification Field Inspected 2-22-77 (DATE)

Washing Machine Line Inspected, If Applicable 2-22-77 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ____ installed or constructed altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 12½' X 60' X 34"
10' X 38' X 12"
Lemay Construction Co

Environmentalist

EHD-5-76

Environmental Health Department's Copy