Date Received 1-11-84

RECEIVED
JAN 1 2 1984
ENVIRONMENTAL HEALTH

ON BACK

ICAR(S) Application No. 20498

T. C. No. 027-072-08

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ Install or Construct 2) X After or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home X Yes ___ No
Residence ___ Yes X No

4) No of Bedrooms 2
5) Business Use – Max No Employees ___
6) Washing Machine ✓ Yes ✓ No
7) Garbage Disposal ___ Yes X No
8) Dishwasher ___ Yes X No
9) Water Supply
A) Individual Well ___
B) Governmental System ___
C) Community System
1 Well source ✓
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER NISBET, E P.
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 1818 BAXTER ST.

15) PHONE NO. Home 875-2613 Office 332-7755

16) LOCATION OF SYSTEM 6101 PROSPERITY CH RD.
STREET OR COUNTY ROAD

17) SUBDIVISION ___ Lot No. 39 Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

1-11-84
DATE OF APPLICATION

OWNER Sam Brangham / agent for E. NISBET.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 6888

ICAR(S) Permit No. 20498

Date Issued 1-11-84

T. C. No. 027-072-08

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 20498, dated 1-11-84, and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 1-25-84, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate 4 IVB.

Liquid Capacity of Tank Repair.

Type of Construction Repair.

Absorption and/or Nitrification Lines

Total Line Length 100 LIN FT.

Number of Lines Two

Distance from House 10 FT.

Distance from Property Line 50 FT

Distance from Well > 400 FT.

NAME OF OWNER NISBET, E.

LOCATION OF PROPERTY 6101 Prosperity Ch Rd Lot 39

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Two trenches to be 50 FT x 3 FT x 18 inches stone - layer straw cover.

Comments

Division or Section Head _____ Environmentalist Ralph Miller

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

[illegible] HEALTH DEPARTMENT [illegible]