APR 15 1983
ENVIRONMENTAL HEALTH

Date Received 4-15-83 SEE INSTRUCTIONS ON BACK

ICAR (S) Application No. 19564

T. C. No. 215-071-19


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge,



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4) No of Bedrooms 3
5) Business Use — Max No Employees _____
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ___ Yes ✓ No
9) Water Supply
A) Individual Well ✓
B) Governmental System _____
C) Community System
1 Well source _____
2 Governmental source _____
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No _____
12) VA Case No. _____

13) NAME OF OWNER Newton, Archie Paul
(LAST, FIRST, MIDDLE)

14) ADDRESS OF OWNER 2501 Ridge Rd. Matthews, NC 28105

15) PHONE NO. Home 847-6531 Office 379-9000

16) LOCATION OF SYSTEM Same
(STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

4/13/83
DATE OF APPLICATION

OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 6187

ICAR(S) Permit No. 19564


Date Issued 4-18-83

T. C No. 215-071-19

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19564, dated 4-13-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before APRIL 31ST 1983, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate DS - IRA

Liquid Capacity of Tank _____

Tank Construction REPAIR

Absorption and or Nutrification Lines

Total Line Length 200 lin FT

Number of Lines THREE

Distance from House 10 FT

Distance from Property Line 15 FT

Distance from Well 105 FT.

NAME OF OWNER NEWTON, ARCHIE

LOCATION OF PROPERTY 2501 RIDGE RD

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

one BASSET FTX 2FT. x 12 INCH STONE - buy or Stone cover

Comments: _____

Ralph Gilles
Environmentalist

_____
Division or Section Head

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 19564 /

Date Issued 5-11-83 **Serial** 5805 T C. No. 215-071-19

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner NEWTON, ARCHIE
LAST FIRST MIDDLE

Location of Property 2501 RIDGE ROAD

Application Number 19564 Permit Number 19564

Inspection Data:

Liquid Capacity of Tank Repair Tank Material Repair

Total Length of Drain Tile 200 LIN.FT. Number of Lines TWO

Depth of Filter Material 1 Tinches Cover Depth 18 inches

Water Supply Source well Distance from Water Source 80 FT.


Excavation Inspected 5-11-83 DATE Tank Inspected 5-11-83 DATE

Nitrification Field Inspected 5-11-83 DATE

Washing Machine Line Inspected, If Applicable — DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ~~installed~~ or constructed, ~~altered~~ or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments:



changed area of bed due to unsuitable soil on South side of property - front yard is suitable

Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY