Date Received 1-23-73

APT No 5456

T C No

Map Date

Mail to:
Rev. William B Hill
631 Eastway Dr.
28205

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER [redacted] Eula Sherrill
LAST FIRST MIDDLE

2) ADDRESS OF OWNER 100 Christenbury rd. ZIP 28213

3) PHONE NO Home 596-0089 Office


4) LOCATION OF PROPERTY off of Nichlos Ave. sr. 2513
STREET OR COUNTY ROAD

5) SUBDIVISION Hunters Acres LOT NO BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK 1648 PAGE NO 491

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Eula Sherrill Gibbon
OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. [illegible]

PTR No. 5456
P.O.
T C No. 043-041-03
Map Date 5-3-72

Date issued February 2, 1973

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Gibbon (LAST) Eula (FIRST) Sherrill (MIDDLE)

ADDRESS OF OWNER 100 Christenbury Road ZIP 28213

LOCATION OF PROPERTY off Nicholas Avenue (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 40 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system must be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction including the cutting of trees is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John R Atkisson

Director, Environmental Health Division or
Authorized Section Head

FORM NO E-2-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 7-2-73

ICAR(S) Application No. 5456

T. C. No. 043041-03

Map Date 5-3-73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of the property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1 ✓ Install or Construct 2 ___ Alter or Repair an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



3 PLOT PLAN (ACCURATELY DIMENSIONED)

4 Number of Bedrooms ___
5 Building Unit Water No. ___
Engineer ___
6 Water Meter Yes ___ No
Yes ___ No
7 Driveway Yes ___ No
8 Water Supply
A Individual Well ___
B Government System ___
C Community System
1 Well source ___
2 Governmental source ___
9 Sewage System
House located within 200 feet
a public sewer Yes ___ No
House located within 200 feet of
community sewer ___ Yes ___ No
10 FHA Case No ___
11 VA Case No ___

12 NAME OF OWNER HEMAN FREE WILL Baptist Church (LAST / FIRST / MIDDLE)

14 ADDRESS OF OWNER 631 EASTWAY DR

15 PHONE NO Home 535-4785 Office 592-1063

16 LOCATION OF SYSTEM OFF OF Nicholas AVE SR. 2513 (STREET OR COUNTY ROAD)

17 SUBDIVISION HUNTERS ACRES Lot No ___ Block No. ___

Map Book No ___ Page No. ___

18 DEED REFERENCE — DEED BOOK 1648 AT PAGE 491

19 HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN 2/23/73

20 PTR NUMBER See instructions 5456

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION ___

William B. Hill
OWNER

FORM NO. E-4 (...)

HEALTH DEPARTMENT'S COPY

Serial No. 3117

LA No. 5456
P.O.
T C No 043-041-03

Date Issued July 2, 1973

Map Date 5-3-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Heman Freewill Baptist Church
LAST FIRST MIDDLE

ADDRESS OF OWNER 631 Eastway Drive ZIP

LOCATION OF LOT off of Nicholos Avenue
STREET OR COUNTY ROAD

SUBDIVISION Hunter Acres LOT NO BLOCK NO

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption effluent discharge based on the percolation test results which yielded a percolation rate of 40 min/in on an on site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 5456. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an 'Installation, Construction, Alteration, and/or Repair Permit' be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permits which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Environmentalist

Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 2 July 74

Serial No.

ICAR(S) Permit No 5456

P.O.T.C. No 043-041-03

Map Date 5-3-73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ~~Install~~ or Construct Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as described herein at the described location. This permit is granted based upon the information supplied in application No 5456, dated and this permit shall be void and of no effect if the information is found to be false in the application or not true and correct. All work shall be completed on or before 2 July 74 after which date this permit shall be null and void.



Percolation Rate 46

Liquid Capacity of Tank 1500 gal

Tank Material PC

Absorption System Type Trench or Lines

Total Length 600'

Width 6 (15 x 102 inch)

Depth 16'

Depth 16'

Distance from Well 100'

PLOT OF SYSTEM

NAME OF OWNER Hemon Free Will Baptist Church

LOCATION OF PROPERTY off of Nicholas Ave.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments Aeration pit 3½ x 7' x 4' c/ Stone (Staple)

Director of Sanitation or Head

Environmentalist

If this permit is for the installation or construction of a new system it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

Form E-5-9-1-72

Date Issued 11 July 74 Serial No. C of A Ist No 5456

T C No 043-041-03

Map Date 5-3-73

~~CERTIFICATE OF COMPLETION~~

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Heron Freehill Baptist Church (LAST, FIRST) & DOLE

Location of Property E/S Nicholas Ave

Application Number 5456 Permit Number 5456

Inspection Data:

Liquid Capacity of Tank 500 gl Tank Material P.C.

Total Length of Drain Tile 600' Number of Lines 6 (15' x 100' x 12")

Depth of Filter Material 17" Cover Depth 15"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 11 July 74 (DATE) Tank Inspected 11 July 74 (DATE)

Nitrification Field Inspected 11 July 74 (DATE)

Washing Machine Line Inspected, If Applicable _____ (DATE)

The above signed inspected the Individual Septic Tank System with subsurface soil absorption of effluent discharge as described above and it has been ~~installed~~ constructed satisfactorily and in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health governing the date of issuance of the permit. This issuance of this Certificate of Approval is not a guarantee that the system will operate properly nor does it relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit and in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Aeration pot 2½' x 7' x 4½' Stone (Single)

Rudolph Sherlock

Environmentalist

FORM NO E-6-9-1-72

outlet

CHARLOTTE - MECKLENBURG HEALTH DEPARTMENT
PERCOLATION TEST RESULTS

Location (St., Rd., Hwy.) Brookwood Dr.
Subdivision
Lot No. & Block No. Lot 3
FHA Case No.

Owner Rogers - Yates
Builder Long & Lathrop
No. Perc. Holes 6

6-Hole Average

1st. Perc. Rate	130	Min./In.	Date 4-5-70
2nd. Perc. Rate	98	Min./In.	Date 4-12-70
3rd. Perc. Rate		Min./In.	Date
4th. Perc. Rate		Min./In.	Date

Lowest Rate Above = Average Perc. Rate

No. Bedrooms 3 Baths 2½
Washing Machine Yes ✓ No Disposal Yes ✓ No

Separate Yes ✓ No Separate Yes ✓ No

Tank Capacity 1000 Gallons
Nitrification Line 320 Lin. Ft. Sq. Ft.
100

BUSINESS OR INDUSTRIAL BUILDINGS

W. C. Urinals Lavatories
Showers Sinks Other

Check:
Approved ✓
Disapproved
Conditional Agreement Card Signed

R. C. Mecker
Sanitarian - Engineer

EH: #85
9/1968