Date Received 6/24/77

APT No. 12751

T. C. No. 137-071-5-9

Map Date 1 30 76

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Batey (LAST) Elmer (FIRST) R. (MIDDLE)

2) ADDRESS OF OWNER 3411 Boulevard Colonial Heights, Virginia ZIP 23834

3) PHONE NO Home 526-2710 Office 526-4333


4) LOCATION OF PROPERTY Willhill Road (STREET OR COUNTY ROAD)

5) SUBDIVISION Wilson Woods LOT NO 9 BLOCK NO. C

MAP BOOK NO 9 PAGE NO 241

6) DEED REFERENCE DEED BOOK 2446 PAGE NO 146

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

E. R. Batey by

OWNER Agent for Elmer R. Batey

EHD-5-76

Environmental Health Department's Copy

Date Received 11/5/79

APT No. 12751

T. C. No. 137-071-59

Map Date 9/4/79

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Batey (LAST) Elmer (FIRST) R (MIDDLE)

2) ADDRESS OF OWNER RFD 1 Box 12-F 7 Prince George, VA ZIP 23875

3) PHONE NO Home 804-541-3343 Office 804-732-6613


4) LOCATION OF PROPERTY Walnut Road # 3248 (STREET OR COUNTY ROAD)

5) SUBDIVISION Wilson Woods LOT NO 59 BLOCK NO. 71

MAP BOOK NO 137 PAGE NO 27

6) DEED REFERENCE DEED BOOK 2446 PAGE NO 146

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Elmer R Batey
OWNER

EHD 5-76

Environmental Health Department's Copy

S. I. R. NO. 12-751

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 137-074-59

(Ground Absorption Sewage Disposal)

OWNER: ELMER R. BATEY
ADDRESS: R-1 Box 164-D7
COUNTY: PRINCE GEORGE VA 23875
LOCATION OF SITE: WILL HILL ROAD Lot #9

DATE REQUESTED: 11 5 79
PLAT NO.:
LOT SIZE: 20,792

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(PS) 2-10	PS 0-2	(PS) 2-10	
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 Clay)	(U) CLAYEY 2-1	(U) Clayey 2-1	(U) Clays 2-1	
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	(U) ~~Massive~~	(U) TEND TO BE Massive	(U) Blocky To Massive	
4. SOIL DEPTH (In.)	(U) <48	(U) <48	(U) <48	
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata Rock)	(U) Clay	(U) Clays	(U) Clays	
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	(U) SLOW	(U) SLOW	(U) SLOW	
7. SOIL PERMEABILITY (Percolation Rate)	(U) SLOW	(U) SLOW	(U) SLOW	
8. OTHER (Specify)				
9. SITE CLASSIFICATION	UNSUITABLE	Unsuitable	Unsuitable	
SOIL SERIES	HELENA	MONACAN	Cecil over Helena	

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments:


Described By: W.B. RAMSEY

Title: SOIL SCIENTIST Date: 11-20-79

DHS Form 2601
Sanitation
EHD 539 (3/79)

2

e


WILL HILL RD
HELENA
2-10
LOT #9
MONACAN
0-2
HELENA
2-5
CECIL over
HELENA
2-10

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 12751

T.C. # 137-071-59

DATE 11-21-79

NAME OF OWNER Batey, Elmer R.

ADDRESS OF OWNER RFD 1, Box 164 D7, Prince George, Virginia 23875

LOCATION OF LOT Willhill Road, Lot 9, Block C

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

Soil Structure Massive

Soil Permeability Unsuitable

John R. Adkisson

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section