Date Received 5/31/79

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 31 1979
ENVIRONMENTAL HEALTH

APT No. 15659
T. C. No. 027-042-03
Map Date 6/2/77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Spencer (LAST) Sharon (FIRST) D (MIDDLE)

2) ADDRESS OF OWNER 9909 Mallard Ck. Rd. ZIP 28213

3) PHONE NO Home 596-4596 Office None


4) LOCATION OF PROPERTY 9909 Mallard Ck. Rd (STREET OR COUNTY ROAD)

5) SUBDIVISION None LOT NO None BLOCK NO None

MAP BOOK NO ____ PAGE NO ____

6) DEED REFERENCE DEED BOOK 1410 PAGE NO 239

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mary D Spencer
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

15659
027-042-03

(Ground Absorption Sewage Disposal)

OWNER: MARION SPENCER
ADDRESS: 9909 Mallard Ck. Rd.
COUNTY: Meck. 28213
LOCATION OF SITE: 9909 Mallard Crk Rd

DATE REQUESTED: 5-31-79
PLAT NO.:
LOT SIZE: 42,000 Sq. ft.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-10 U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2-1 PS Clay (U)	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS Massive (U)	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS 48 (U)	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS Clay (U)	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS Slow (U)	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS Slow (U)	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	UNSUITABLE			
SOIL SERIES	ENON			

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: _____

Described By: W. B Ramsey
Title: Soil Scientist Date: 6-7-79

DHS Form 2604 (2/77)
Sanitation

3


1A
ENON
2-10
MAHLARD CREEK Rd
N

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15659
T.C. NO. 027-042-03
MAP DATE 6/2/77
DATE 6/11/79

NAME OF OWNER Marion Spencer

ADDRESS OF OWNER 9909 Mallard Creek Road Charlotte, NC 28213

LOCATION OF LOT 9909 Mallard Creek Road

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Permeability Unsuitable
Soil Structure Massive

John R. Adkisson, Environmentalist

EHD 398
7/77

R