

8810 MOORES CHAPEL RD

05510215

7/12/2007

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

JR

APPLICATION FOR AN IMPROVEMENT PERMIT

Pd. 125.00
CK # 1070
10-16-91
HB

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr 2nd Floor
700 N. Tryon Street
Charlotte, NC 28202

Mecklenburg County services are available *without* regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 7812 A
TC:
SERIAL: № 0020621

☑ L ☐ CRT

JOB LOCATION

① ADDRESS: 8810 (STREET NO.) MOORES CHAPEL Rd (STREET) ② FILE:
③ JURISDICTION: CH ④ TAX PARCEL NO.: 05510215
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: MARGET (FIRST) (MIDDLE) HOGAN (LAST)
⑨ MAILING ADDRESS: 8810 MOORES CHAPEL Rd
⑩ CITY: CH ⑪ STATE: NC ⑫ ZIP:
⑬ PHONE: (WORK) 336 2265 ⑭ (HOME)

REQUEST

This request is for a(n):

⑮ ☐ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☑ Other (specify) TO REPLACE OLD HOUSE WITH NEW STRUCTURE

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 2 ㉕ Type?
㉓ Maximum occupancy? ㉖ Maximum number of employees?
㉔ Basement? ☐ yes ☐ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Margaret Hogan
Date: 10/16/91

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 60 months from the date of issuance.

Judy Hair R.S. 10/19/91
Environmentalist Date

Director or Authorized Section Head 10-19-91 Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.

JK

PROPOSED PLOT PLAN


Pd 125.00
ck # 1070
10-16-91
NB

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7812 A

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7812A

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



(3) 3' x 35' for washer = 105'

Septic
1500 gallon Septic TANK
(4) Trenches
3' x 40' = 160' drainfield
Combined total = 265'

Note: Existing well to be Abandoned before Permit for System is Issued.
J. Fiser, 10/17/91
Ron Powell GC.

APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy