

Old Statesville Rd.

1/29/08

thomatc

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

Date Received 2-1-84

RECEIVED
FEB 1 1984
ENVIRONMENTAL HEALTH

SIR No. 20583

T. C. No. 011-013-22

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER PETRILLO (LAST) JOSEPHINE (FIRST) S. (MIDDLE)

2) ADDRESS OF OWNER c/o WELLWORTH REALTY, RT. 2, BOX 390, DAVIDSON, N.C. ZIP 28036

3) PHONE NO. Home (305) 395-7678 Office _____


4) LOCATION OF PROPERTY HWY 115 - OLD STATESVILLE RD., HUNTERSVILLE (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO. 154-158 BLOCK NO. _____

MAP BOOK NO 5 PAGE NO. 54

6) DEED REFERENCE: DEED BOOK 3735 PAGE NO. 716

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Josephine S Petrillo
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20583

T.C. NO. 011-013-22

(Ground Absorption Sewage Disposal)

OWNER: Josephine Petrillo
ADDRESS: % Wellworth Realty R-2 Box 350 DAVIDSON 28036
LOCATION OF SITE: old Statesville Rd

PLAT NO:
LOT SIZE: .87A

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — complex slopes	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U — Clayey	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (U) — 0-40	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — None	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — Adequate	S PS U	S PS U	S PS U
7. OTHER (Specify) Restrictive Area	S PS (U)	S PS U	S PS U	S PS U
8. SOIL GROUP	IVa			
9. SITE CLASSIFICATION	Unsuitable			
10. SOIL SERIES	One ~~Hapte~~ Pitch cut in Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments: See McP.

Described by: William B. Ramsey
Title: Soil Scientist

Date: 2-8-84

EHD 539 (Revised: 6/82)

2H


Rail Road
115
Cecil
Dixon
Cecil 359
324
Rama Rd
Statesville Rd 115

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20583
T.C. NO. 011-013-22
DATE: 2-9-84

Josephine S. Petrillo
% Wellworth Realty Company
Route 2, Box 390
Davidson, NC 28036

RE: Property located at Old Statesville Road

Dear Ms. Petrillo:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure