Date Received 9-20-82

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
SEP 20 1982
ENVIRONMENTAL HEALTH

SIR No. 19016
T. C. No. PC 193-101-56
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER FAYSTAR INC. (LAST) ROGER (FIRST) EXECUTIVE CENTER (MIDDLE)

2) ADDRESS OF OWNER SUITE 108 5600 EXECUTIVE CTR. DRIVE CHARLOTTE, NC. ZIP 28212

3) PHONE NO. Home 334-986L Office 536-2239

4) LOCATION OF PROPERTY WILLIAMS ROAD (S.R. 3155) (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO _____ PAGE NO. _____

6) DEED REFERENCE: DEED BOOK 4500 PAGE NO. 146

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.

* SEND COPY OF RESULTS TO: GARY R WILLIAMS DR
11228 GLADEWATER
MATTHEWS NC. 28105

SURVEY MAP ATTACHED

7) ACCURATELY DIAGRAM & DIMENSION LOT

Faye Conley, President
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R.# 19016

T.C.# PO 193-181-56

DATE: 9-23-82

NAME OF OWNER: Faystar, Inc.

ADDRESS OF OWNER: Koger Executive Center, Suite 108, 5600 Executive Center Dr. Charlotte, NC 28212

LOCATION OF LOT: Williams Road

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

SOIL TEXTURE (2-1 clay)

SOIL STRUCTURE (massive)

SOIL DEPTH (25 inches)

RESTRICTIVE HORIZONS (2-1 clay)

SOIL DRAINAGE/GROUNDWATER (slow)

Mike Sexton

Michael A. Sexton
Environmentalist
On Premises Waste Disposal Section

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19016

T.C. NO. PO 193-101-56

(Ground Absorption Sewage Disposal)

OWNER: FAYSTAR INC. PLAT NO:

ADDRESS: Koger Executive Center LOT SIZE: 1.76A
Suite 102 5600 Executive Center Drive 28212

LOCATION OF SITE: Williams Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-10	S (PS) U 2-10	S PS (U) Natural Drainage Way	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) 2-1 Clay	S PS (U) 2-1 Clay	S PS (U) 2-1	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS (U) Massive	S PS (U) Toward Massive	S PS (U) Massive	S PS U
4. SOIL DEPTH (inches)	S PS (U) 25"	S PS (U) 30"	S PS (U) 35"	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS (U) 2-1 Clay	S PS (U) Clay Saprolite	S PS (U) Clay	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS (U) Slow	S PS (U) Slow	S PS (U) Slow Perch Water Level 6'	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IV b	IV b	IV b	
9. SITE CLASSIFICATION	Unsuitable	Unsuitable	Unsuitable	
10. SOIL SERIES	Enon-Iredell Complex	Mecklenburg	Helena	

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: W. B. Kamm
Title: Soil Scientist

Date: 9-22-82

EHD 539 (Revised: 6/82)

3/


100
Woods
452
641
Open field
Mecklenburg
EnON-
Iredell
2-10
HG
Drainage Way
Helene
2-10
Water Table 6"-10"
Mecklenburg
Williams Rd