Date Received 1-25-1994

RECEIVED
JAN 2[illegible] 94
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 20552

T. C. No. 019-251-03


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No
4) No of Bedrooms 3
5) Business Use - Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8 Dishwasher ___ Yes ✓ No
9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER _____ (LAST / FIRST / MIDDLE)

14) ADDRESS OF OWNER _____

15) PHONE NO. Home _____ Office _____

16) LOCATION OF SYSTEM 15700 _____ (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN _____

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION _____ OWNER _____

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 6909

ICAR(S) Permit No. 20552


Date Issued 1-25-84

T C. No 019-251-03

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct 1 Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application # 20552 dated 1-24-84 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before FEB 25TH 1984 after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS 104

Liquid Capacity of Tank Repair w/in

Tank Construction Repair w/in

Absorption Field Type Line

Total Line Length 150 LIN FT

Number of Lines TWO

Distance Between Lines 10 FT

Distance from Property Lines 60 FT

Distance from Well 50 FT.

NAME OF OWNER ATWELL LEONARD

LOCATION OF PROPERTY 15700 EWART ROAD

The system shall meet all the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered unavailable for inspection. The issuance of this permit does not in any way guarantee that the system anticipated herein will operate properly or relieve any person now or hereafter owning, controlling or using such system from any and all liability resulting from the failure of the system to operate properly.

Comments two trenches to be 75 FT x 3FT x 12 inches stone bed or stone sewer grade beds DIST BOX for W/in repair

Division or Section Head

Ralph Hillis
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

C of A (s) No. 20552

Date Issued 2-1-84 Serial 6415 T C No. 019-251-08

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner ATWELL, LEONARD
LAST FIRST MIDDLE

Location of Property 15700 EVHART Road

Application Number 20552 Permit Number 20552

Inspection Data:

Liquid Capacity of Tank Repair W/A Tank Material Repair - W/A

Total Length of Drain Tile 150 Lin FT Number of Lines Two

Depth of Filter Material 12 inches Cover Depth 18 inches

Water Supply Source Well Distance from Water Source 50 FT

Excavation Inspected 2-1-84 DATE Tank Inspected — DATE

Nitrification Field Inspected 2-1-84 DATE

Washing Machine Line Inspected If Applicable 2-1-84 DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County ~~Health~~ Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Ralph E. Wells
Environmentalist

EHD-5-76