Date Received 4/22/77

MECK COUNTY DEPARTMENT OF
RECEIVED
APR 22 1977

APT No. 12248

T. C. No. 221,033,02

Map Date —

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Huneycutt (LAST) Pauline (FIRST) Y. (MIDDLE)

2) ADDRESS OF OWNER P. O. Box 293, Pineville, NC ZIP 28134

3) PHONE NO. Home 889-4226 Office

4) LOCATION OF PROPERTY 7 Acres Westside Lake View Drive (STREET OR COUNTY ROAD) Tax Code 221-033-02

5) SUBDIVISION None LOT NO. BLOCK NO.

MAP BOOK NO PAGE NO.

6) DEED REFERENCE. DEED BOOK 1244 PAGE NO. 550

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

SEE ATTACHED MAP

7) ACCURATELY DIAGRAM & DIMENSION LOT

Pauline Y. Huneycutt
OWNER

EHD-5-74

Environmental Health Department's Copy

SOIL INVESTIGATION REPORT

Date of Investigation April 26, 1977 APT NO. 12246

Owner Pauline G. Honeycutt T.C. 221-03302

Location of Property Westside Jefferson Va.

Soil Suitability Ratings

Soil Properties	Soil 1	Soil 2	Soil 3	Soil 4
1. Soil Series	Mac Mosaburg		Iredell	
2. Soil Slope	suitable 6-10%		suitable 2-6%	
3. Soil Depth	suitable 40"		unsuitable 30"	
4. Soil Texture	unsuitable 2-1 Expanding Clay		unsuitable 2-1 Expanding Clay	
5. Soil Structure	unsuitable Massive		unsuitable Massive	
6. Restrictive Horizons	—			
7. Soil Drainage	suitable water Table 70'		unsuitable perched high water Table	
8. Soil Permeability (Percolation Rate)	unsuitable slow 72 min/in		unsuitable slow 72 Min/in	
9. Other				
10. Overall Rating	unsuitable		unsuitable	

Remarks, Recommendations Based on this investigation, soils unsuitable for installation of a septic tank system were found on the lot.


Soil Engineer

William R. Martin

WRC

3/15/75
FHA 439

DIAGRAM OF PROPERTY



3/18/75

File 536

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

DATE ISSUED
1. 4/27/77
2. _____
3. _____

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR NO. 12248
T.C. NO. 221-033-02
M.P. DATE _____

NAME OF OWNER **Huneycutt, Pauline Y.**

ADDRESS OF OWNER **P. O. Box 293, Pineville, N. C. 28134**

LOCATION OF LOT **Lakeview Drive**

The lot described above is not recommended for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

Soil Permeability Unsuitable

Percolation rate in excess of 200 min./in.

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section

JRA:jjk

(Stencil No.)
EHD 358
8/74

FORM NO.
E-1--8-21-74