

2516 IVEY WOOD LN

19333303

5/28/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

SERVICE REQUEST/WORK ORDER

File 6011

Log No.: _____ Section: IWWS Hazard? [ ] Yes [ ] No

Date: 3/5/97 Parcel: 193-333-02 <60 Days? [ ] Yes [ ] No

REQUESTING PERSON: Nat Huggins (h)845-1359 Phone (w)335-6210

File 6011

Address 2516 Ivywood Lane City Natt Zip _____

PROPERTY CONCERNED: Facility Name Mark Lay

File 6012

Address 2524 Ivywood Lane City _____ Zip _____

SERVICE REQUESTED: Malfunction

ASSIGNED TO: L. Mialik TAKEN BY: L. Mialik

DATE	ACTIVITY REPORT
3/5/97	PC w/Mr Huggins. Scheduled appt. for 4:15 pm 3/6/97 for
3/6/97	OSV@2516. Mrs. Huggins present. No visible malfunction. Left bus. card + brochures. Mr. Huggins did not arrive.
	OSV@2524. Mrs Lay, owner present. No visible malfunction. Advised. Left bus. card + brochures.
3/7/97	PC w/Mr. Huggins. Advised no violations observed. Mr. Huggins to run washer + observe yard for effluent surfacing - notify me of results.
3/7/97	VM message from Nat Huggins
3/10/97	Phone calls to Mr Huggins. N.C. Lm w/Mrs. Huggins
3/11/97	PC w/Mr Lay - per Mr Lay, water surfacing @ 2516 along driveway
3/21/97	PC w/Mr Huggins - scheduled OS appt. for 3/26 @ 10:30
3/27/97	OSV. (re-scheduled appt.) Nat Huggins present. Washer run - effluent surfacing. Advised repair necessary. Due to financial concerns, Mr Huggins requested to plumb washer to S.T. Cautioned about potential impact on S.T. Drainfield + discussed water conservation methods. Per Mr Huggins - will get plumb. quotes, then write me letter regarding his decision OR will have S.T.

Retain as part of file - see attached letter.

NOTIFICATION TO REQUESTING PERSON: ( ) Written ( ) Verbal ( ) Not Applicable

COMPLETED BY: Lisa B. Mialik, RS 5/7/97

REVIEWED BY: _____ /

Date: 3/5/97 File 6011 Log No.:

DATE	ACTIVITY REPORT
	contractor contact me for repair approval.
4/24/97	PC w/Mr. Huggins regarding status of issue
4/29/97	Mr. Huggins in office - delivered letter regarding his decision to tap washer into S.T. See attached letter.
5/6/97	VM mess. from Nat Huggins - roto-rooter plumbed washer to (main) sewer line (to S.T.) yesterday.
5/7/97	OSV @ 251C. Mrs. Nat Huggins present. Observed in crawlspace that washing machine plumbed to line (from another fixture) to septic tank. Left note for Mr. Huggins regarding OSV - water conservation recommendation etc. Closing SR. JSM

c:/original/serreqp2.frm

File 6011
2516 Ivywood
JBM

4/29/97

TO: Lisa Malik

Reference controlling washing machine water run-off, I've received proposals from several contractors to resolve this problem and within the next 1-2 weeks intend to have my washing machine drain line connected to my sewer drain line. I am aware of the risks involved with this alternative cure for the existing problem. I have also been contacted by the City of Matthews Town Hall and have been told that my community will be considered for city sewage in the up coming bond referendum. Additionally, I will have my sewage tank pumped annually to offset potential overflow problems. Thanks for your kindness, consideration & compassion.

Sincerely,

NATE HUGGINS

(704) 845-1691/1359

Received 4/29/97.
Mr. Huggins in office