

4329 AMOS SMITH RD

11306118

6/17/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

4329 Ames Smith 2" well #2 10922

North Caroline - Department of Environment and Natural Resources - Division of Water Quality - Groundwater Section - 1636 Mail Service Center - Raleigh, NC 27699-1639 - Phone No. (919) 733-3221

WELL ABANDONMENT RECORD

WELL CONTRACTOR Lassiter Well Company
WELL CONTRACTOR CERTIFICATION # 2297

1. WELL USE (Check Applicable Box): Residential ☒ Municipal ☐ Industrial ☐ Agricultural ☐ Monitoring ☐ Recovery ☐ Heat Pump Water Injection ☐ Other ☐ If Other, List Use:

2. WELL LOCATION: (Show a sketch of the location on back of form.)
Nearest Town: Charlotte County Meck
4329 Ames Smith Rd
(Road Name and Number, Community, Subdivision, Lot No.)
113-061-18
Quadrangle No.

3. OWNER: Provident Development Group

4. ADDRESS: 6707 Fairview Rd Char NC

5. TOPOGRAPHY: draw, slope; hilltop, valley (flat)

6. TOTAL DEPTH: 85' (circle one) DIAMETER 2"

7. CASING REMOVED:
4' feet 2" diameter


8. DISINFECTION: 1 16 HTH
(Amount of 70% hypochlorite used:)

9. SEALING MATERIAL:
Neat Cement N-A
bags of cement
gallons of water
Sand Cement N-A
bags of cement
gallons of water
Other
Type material cement / grout mix
Amount bentonite / 3 50lb bags

10. EXPLAIN METHOD EMPLACEMENT OF MATERIAL
poured from top to bottom
using bags at hole plug
bentonite - concrete cap

11. DATE WELL ABANDONED 12-19-07

WELL DIAGRAM: Draw a detailed sketch of the well showing total depth, depth and diameter of screens remaining in the well, gravel interval, intervals of casing perforations, and depths and types of fill materials used.



I do hereby certify that this well was abandoned in accordance with 15A NCAC 2C, well construction standards, and that a copy of the record has been provided to the well owner.

Signature of person abandoning the well Vernon Lassiter Jr Date 12-20-07

WELL LOCATION: Draw a location sketch on the reverse of this sheet, showing the direction and distance of the well to at least two (2) nearby reference points such as roads, intersections and streams. Identify roads with State Highway road identification numbers.

Submit original to the Division of Water Quality, Groundwater Section, one copy to the owner within 30 days from completion of abandonment.

GW-30 Revised 12/99

Mecklenburg County Health Department
Groundwater & Wastewater Services
700 N. Tryon St, Suite 211
Charlotte, NC 28202
Phone: (704) 336-5103
Fax: (704) 336-6894

PERMIT TO CONDUCT MAJOR REPAIR AND/OR ABANDON A WATER SUPPLY WELL

Permit#: 10003116 **File #:** 10922 **Tax Parcel #:** 113-061-18
Property Owner: PROVIDENT DEVELOPMENT GROUP
Job Location Address: 4329 AMOS SMITH RD
City/ETJ: CHARLOTTE **State:** NC **Zip Code:** 28214
Permit Issuance Date: 12/19/2007
Use of Well: Potable
Type of Facility Served by Well: Single-mobile home
Sewage System Type: None

Area of Regulated Groundwater Usage Restrictions Apply: YES

If Yes, see requirements in Specific Conditions of This Permit.

General Conditions of This Permit:

- The Water Supply Well repair and abandonment must meet all requirements set forth in the *Mecklenburg County Groundwater Well Regulations* and any other applicable rules and laws.
- A North Carolina Certified Well Contractor must perform the well construction activities.
- Repair of any Water Supply Well with the well head terminating below ground surface (buried seal) shall include extending the well casing at least twelve inches above the surface.
- This Permit shall be VALID for a period not to exceed 12 months from the date of issuance.

Specific Conditions of This Permit (Check all that apply):

☐ Grout must be placed the full extent of the casing.

☐ Initial water sample to taken and analyzed for (check all that apply):

☐ Volatile Organic Compounds (VOC's) ☐ Semi-volatile Compounds ☐ Metals (Specify in Other Conditions)
☐ Pesticides ☐ Herbicides ☐ Other (See Below)

Other Conditions of This Permit:

Debra Howell R.S. Tom Waters
Authorized Agent: Print Name Owner/Legal Agent: Print Name

Debra Howell R.S. [redacted]
Signature: Signature:

MECKLENBURG COUNTY

Land Use & Environmental Services Agency
Water & Land Resources
Groundwater & Wastewater Services

Fax Coversheet

****NOTICE****

The information contained in this fax may be privileged and/or confidential and is intended only for the use of the person to who it is addressed. If the reader of this message is not the intended recipient (or such recipient's employee or agent), you are hereby notified not to read, distribute, or copy the materials attached hereto without the prior written consent of the sender. If you have received this fax in error, please notify the sender by telephone call and return the original to us by mail and you will be reimbursed for the required postage. Thank you.

To: PROVIDENT DEVELOPMENT
Fax #: 704-367-0198
Phone #:

From: ANNETTE GLADNEY
Date: 12/20/07

Number of pages transmitted: 3 (including coversheet)

Comments:
PLEASE SIGN ALL DOCUMENT AND FAX BACK. THANK YOU

If you do not receive all pages of this fax please call (704) 336-5103.

☒ Original will not follow

☐ Original will follow via: ☐ U.S. Mail ☐ Hand Delivery ☐

700 North Tryon Street • Suite 211 • Charlotte, North Carolina 28202-2236
Office #: (704) 336-5103 • Fax #: (704) 336-6894

Mecklenburg County Health Department
Groundwater & Wastewater Services
700 N. Tryon St, Suite 211
Charlotte, NC 28202
Phone: (704) 336-5103
Fax: (704) 336-6894

PERMIT TO CONDUCT MAJOR REPAIR AND/OR ABANDON A WATER SUPPLY WELL

Permit#: 10003116 **File #:** 10922 **Tax Parcel #:** 113-061-18
Property Owner: PROVIDENT DEVELOPMENT GROUP
Job Location Address: 4329 AMOS SMITH RD
City/ETJ: CHARLOTTE **State:** NC **Zip Code:** 28214
Permit Issuance Date: 12/19/2007
Use of Well: Potable
Type of Facility Served by Well: Single-mobile home
Sewage System Type: None

Area of Regulated Groundwater Usage Restrictions Apply: YES

If Yes, see requirements in Specific Conditions of This Permit.

General Conditions of This Permit:

- The Water Supply Well repair and abandonment must meet all requirements set forth in the *Mecklenburg County Groundwater Well Regulations* and any other applicable rules and laws.
- A North Carolina Certified Well Contractor must perform the well construction activities.
- Repair of any Water Supply Well with the well head terminating below ground surface (buried seal) shall include extending the well casing at least twelve inches above the surface.
- This Permit shall be VALID for a period not to exceed 12 months from the date of issuance.

Specific Conditions of This Permit (Check all that apply):

☐ Grout must be placed the full extent of the casing.

☐ Initial water sample to taken and analyzed for (check all that apply):

☐ Volatile Organic Compounds (VOC's) ☐ Semi-volatile Compounds ☐ Metals (Specify in Other Conditions)

☐ Pesticides ☐ Herbicides ☐ Other (See Below)

Other Conditions of This Permit:

Debra Howell R.S.
Authorized Agent: Print Name

Debra Howell R.S.
Signature:

Owner/Legal Agent: Print Name

Signature:

FILE NUMBER: 1092

SEPTIC FEE: _____
DATE: _____

MECKLENBURG COUNTY GROUNDWATER & WASTEWATER SERVICES
APPLICATION FOR A RESIDENTIAL SITE IMPROVEMENT PERMIT/ CONSTRUCTION AUTHORIZATION FOR AN ON-SITE WASTEWATER SYSTEM, NEW WELL INSTALLATION, OR REPAIR OF EXISTING WELL

WELL FEE: _____
DATE: 12-17-07

1. SEPTIC / TYPE APPLICATION: ■ NONE ☐ NEW SYSTEM ☐ ALTERATION ☐ REPAIR ☐ MODIFIED PLOT PLAN

2. WELL / TYPE APPLICATION: ☐ NONE ☐ NEW WELL ☐ MAJOR REPAIR ■ ABANDONMENT 3116

3. JOB LOCATION INFORMATION:

TAX PARCEL NUMBER: 113D6118
STREET ADDRESS: 4329 Amos Smith Rd
CITY: Char
STATE: NC ZIP: 28214
SUBDIVISION NAME:
LOT #: LOT SIZE (acres):
TOWNSHIP:
■ 0-MECKLENBURG ☐ 3-CORNELIUS ☐ 6-HUNTERSVILLE
☐ 1-CHARLOTTE ☐ 4-PINEVILLE ☐ 7-MINT HILL
☐ 2-DAVIDSON ☐ 5-MATTHEWS

4. BUILDING INFORMATION:

BUILDING TYPE:
■ SINGLE MOBILE HOME ☐ MODULAR HOME
☐ DOUBLE WIDE ☐ MULTIPLE FAMILY
☐ HOUSE ☐ OTHER _____
HEATED SQUARE FOOTAGE: 600
NUMBER OF BEDROOMS: 2
NUMBER OF OCCUPANTS: 2
FOUNDATION TYPE:
■ CONCRETE SLAB ☐ BASEMENT WITH PLUMBING
☐ CRAWL SPACE ☐ BASMENT WITH NO PLUMBING

5. IF PLANNING TO EXPAND OR ALTER THE EXISTING SYSTEM PLEASE COMPLETE THE FOLLOWING SECTION: ■ N/A

NUMBER OF BEDROOMS TO BE ADDED: _____ NUMBER OF ADDITIONAL OCCUPANTS IN THE RESIDENCE: _____

6. WATER SUPPLY: ☐ MUNICIPAL ☐ PUBLIC WELL ■ PRIVATE WELL ☐ SHARED WELL ☐ SPRING

7. PROPOSED USE OF WELL: ■ N/A ☐ IRRIGATION ■ POTABLE ☐ GEOTHERMAL ☐ OTHER

8. PLEASE INDICATE AND RANK DESIRED SEPTIC SYSTEM TYPE(S) IN ORDER OF PREFERENCE *(1-MOST DESIRED 5-LEAST DESIRED)*:

☐ ANY TYPE ☐ CONVENTIONAL ☐ ACCEPTED ☐ INNOVATIVE ☐ ALTERNATIVE ☐ OTHER N-A

8A. RANK: ____ ____ ____ ____ ____

9. DO ANY OF THE FOLLOWING APPLY TO THE PROPERTY IN QUESTION? IF "YES" PLEASE ATTACH SUPPORTING DOCUMENTATION.

BURIED CABLES, LANDFILLS, STUMPHOLES	☐ YES ■ NO	GRADING/SOIL REMOVAL PERFORMED	☐ YES ■ NO
EXISTING WASTEWATER (SEPTIC) SYSTEMS	☐ YES ■ NO	JURISDICTIONAL WETLANDS	☐ YES ■ NO
WELLS, SPRINGS, OR WATER LINES	■ YES ☐ NO	APPROVAL REQUIRED BY ANY OTHER PUBLIC AGENCY	☐ YES ■ NO
EASEMENTS OR RIGHT-OF-WAYS	☐ YES ■ NO	WASTEWATER OTHER THAN DOMESTIC SEWAGE	☐ YES ■ NO

10. PROPERTY OWNER:

NAME: Provident Development Group
ADDRESS: 6207 Fairview Rd
CITY: Char
STATE: NC ZIP: 28210
HOME PHONE: WORK PHONE: 367-0167
MOBILE PHONE: FAX: 367 0158

11. OWNER'S LEGAL REPRESENTATIVE, IF APPLICABLE:

NAME: Lassiter well Company
ADDRESS: 6611 Rigsbee Ave
CITY: Char
STATE: NC ZIP: 28214
HOME PHONE: WORK PHONE: 3925764
MOBILE PHONE: FAX: 399 4485

12. WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED? _____
13 WHAT IS THE ANTICIPATED CLOSING DATE FOR THIS PROPERTY? _____

14. SEPTIC SYSTEM PERMIT APPLICATION SIGNATURE SECTION:
If the information in this application is falsified, changed, or the site is altered, then the Improvement Permit and Authorization to Construct shall become invalid. I have read this application and certify that the information provided herein is true, complete and correct. Authorized county and state officials are granted right of entry to conduct necessary inspections to determine compliance with applicable laws and rules. I understand that I am solely responsible for the proper identification and labeling of all property lines and corners and making the site accessible so that a complete site evaluation can be performed. The permit is valid for either 60 months or is non-expiring depending upon the documentation submitted: complete site plan = 60 months, complete plat = non-expiring.

_____
Property Owner's or Owner's Legal Representative Signature Date

16. WELL PERMIT APPLICATION SIGNATURE SECTION:
If the information in this application is falsified, changed, or the site is altered, then the Well Permit shall become invalid. I have read this application and certify that the information provided herein is true, complete and correct. Authorized county and state officials are granted right of entry to conduct necessary inspections to determine compliance with applicable laws and rules. I understand that I am solely responsible for the proper identification and labeling of all property lines and corners and making the site accessible so that a complete site evaluation can be performed. The permit is valid for a period of 12 months from the date of issuance

Vernon Lassiter Jr 12-17-07
Property Owner's or Owner's Legal Representative Signature Date

☐ SURVEY PLAT TO SCALE SUBMITTED ☐ SCALED SITE PLAN SUBMITTED ☐ UN-SCALED SITE PLAN SUBMITTED

Mecklenburg County
Land Use & Environmental Service Agency
Groundwater & Wastewater Services
700 N. Tryon St., Suite 211
Charlotte, NC 28202
Phone: (704) 336-5103
Fax: (704) 336-6894

File #_____
Date_____

PROPOSED PLOT PLAN

A map showing existing and proposed property lines and easements with dimensions, the location of the single family residence, non-single family residence, or other facility, and appurtenances, the site for the proposed well, and the location of existing or proposed sewer lines and/or sewage disposal systems, surface water bodies, aboveground or underground storage tanks. Name all roads adjoining the property. If this a repair indicate the type of repair.

#3



Owner/Agent Signature	Vernon Lassiter Jr
Date	12-17-07

Well abandonment of
4329 Ames Smith Rd
Charlotte

LBC 12/15/04

Groundwater & Wastewater Services
700 N. Tryon St., Suite 211
Charlotte, NC 28202
704-336-5103 Phone 704-336-6894 Fax

WORK ORDER

Work Order Information

Work Order Number: **75154**
Work Order Type: **ARGU Well Review**
Submitted To: STUTTS, JACK
Date Initiated: 12/19/07 12:11:33 PM
Date Completed: 12/19/07 12:11:00 PM
Date Closed:
Unattached WO: **N**
Associated SR Number:

Priority: **3**
Status: IP

Initiated By: CALDWELL, SHAWNA
Completed By: CALDWELL, SHAWNA
Closed By:

Location

Address: **4329 AMOS SMITH ROAD**
Location:

Instructions

1. Create one work order for each ARGU review performed.
2. Geocode the location using the location address from WASPS.
3. Attach the appropriate GIS well feature(s) from the ARGU_Wells_WASPS data layer under the ENTITIES tab.
4. Select the appropriate TOWN under the DETAILS tab.
5. All documentation associated w/ the review should be included as attachments.
6. Enter time for labor required to complete all work associated w/ review.
7. Use the COMMENTS field to document work activities.

ARGU Well features are automatically created in gis when the well permit application is entered into WASPS.

Comments

Create one work order per ARGU Review
By CALDWELL, SHAWNA: 12/19/07 12:12:12 PM
Based on this review this permit application is approved requiring abandonment under the Mecklenburg Co. Groundwater Regulations dated Oct. 5, 2004 Chapter II Section VIII Abandonment of Water Supply Wells with no special conditions.

Hydrogeologist Permit Application Review

Application #: 3116
Permit File #: 10922

Permit Type: Abandonment (Residential)

ARGU Review Completed: (•) Yes ( ) No

Permit Denial?: ( ) Yes (•) No

Additional Conditions:

☐ Full Grouting ☐ Casing to Bedrock ☐ Sampling

☐ Volatile Organic Compounds (VOC's) ☐ Semi-volatile Compounds ☐ Metals (Specify in Other Conditions)

☐ Pesticides ☐ Herbicides ☐ Other

Comments/Other Sample Types:

EHS Review | Update

Time Spent (hours):
☐ Change: 1.00

The application has been forwarded to Debra Howell for review.

App. #: 3116

Septic Fee: 0.00

Date:

CRT[ ]

PERMIT APPLICATION FOR A RESIDENTIAL SITE IMPROVEMENT PERMIT FOR ONSITE WASTEWATER SYSTEM, NEW WELL INSTALLATION, OR REPAIR OF EXISTING WELL

MECKLENBURG COUNTY GROUNDWATER & WASTEWATER SERVICES

FILE # 10922

Well Fee: 0.00

Date: 12/17/2007

CRT[ ]

SEPTIC / TYPE APPLICATION: (•) NONE ( ) NEW SYSTEM ( ) ALTERATION ( ) REPAIR ( ) MODIFIED PLOT PLAN

WELL / TYPE APPLICATION: ( ) NONE ( ) NEW WELL ( ) MAJOR REPAIR (•) ABANDONMENT

JOB LOCATION INFORMATION:

TAX / PARCEL #: 113-061-18 [ ] PO

STREET ADDRESS: 4329 AMOS SMITH RD

CITY: Charlotte

STATE: NC ZIP: 28214

SUBDIVISION OR MOBILE HOME PARK NAME:

LOT #: 0

TOWNSHIP: 00

General Comments:

BUILDING INFORMATION:

TYPE OF BUILDING:

(•) SINGLE MOBILE HOME (S) ( ) MODULAR HOME (M)

( ) DOUBLE WIDE (D) ( ) MULTIPLE FAMILY (U)

( ) HOUSE (H) ( ) OTHER

HEATED SQUARE FOOTAGE: 600

NUMBER OF BEDROOMS: 2

NUMBER OF OCCUPANTS: 2

FOUNDATION FOR RESIDENCE:

[x] CONCRETE SLAB [ ] BASEMENT WITH PLUMBING

[ ] CRAWL SPACE [ ] BASEMENT WITH NO PLUMBING

IF PLANNING TO EXPAND / ALTER THE EXISTING SYSTEM INDICATE THE FOLLOWING CHANGES:

NUMBER OF BEDROOMS TO BE ADDED: 0

NUMBER OF ADDITIONAL OCCUPANTS IN THE RESIDENCE: 0

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE?: ( ) Yes (•) No

TYPE:

WATER SUPPLY:

[ ] MUNICIPAL (M) [ ] PUBLIC (C) [x] PRIVATE WELL (P) [ ] SHARED WELL (S) [ ] OTHER 'SPRINGS' (O)

PROPOSED USE OF WELL: ( ) N/A ( ) IRRIGATION (•) POTABLE ( ) GEOTHERMAL ( ) OTHER

PLEASE INDICATE AND RANK DESIRED SEPTIC SYSTEM TYPE(S) IN ORDER OF PREFERENCE *(1-MOST 5-LEAST DESIRED)*:

[ ] ANY TYPE [ ] CONVENTIONAL [ ] ACCEPTED [ ] INNOVATIVE [ ] ALTERNATIVE [ ] OTHER

RANK: 0 0 0 0 0

ARE ANY OF THE FOLLOWING LOCATED ON THE PROPERTY? IF SO, PLEASE SHOW LOCATION ON SITE PLAN/PLAT.

BURIED CABLES, LANDFILLS, STUMPHOLES	( ) Yes (•) No	GRADING/SOIL REMOVAL PERFORMED	( ) Yes (•) No
EXISTING WASTEWATER SYSTEMS	( ) Yes (•) No	JURISDICTIONAL WETLANDS	( ) Yes (•) No
WELLS, SPRINGS, OR WATER LINES	(•) Yes ( ) No	APPROVAL REQ'RD BY OTHER AGENCY	( ) Yes (•) No
EASEMENTS OR RIGHT-OF-WAYS	( ) Yes (•) No	WASTEWATER OTHER THAN DOM. SEWAGE	( ) Yes (•) No

PROPERTY OWNER:

NAME: PROVIDENT DEVELOPMENT GROUP

ADDRESS: 6707 FAIRVIEW RD

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: LASSITER WELL COMPANY

ADDRESS: 600 RHYNE RD

CITY:	CHARLOTTE		CITY:	CHARLOTTE	
STATE:	NORTH CAROLINA	ZIP: 28210	STATE:	NORTH CAROLINA	ZIP: 28214
HOME PHONE:		WORK: 704-367-0167	HOME PHONE:		WORK: 704-392-5764
MOBILE:		FAX: 704-367-0198	MOBILE:		FAX: 704-399-4485

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED?

WHAT IS THE ANTICIPATED CLOSING DATE FOR THIS PROPERTY?

PRINT | Update | Go to Front Counter | Duplicate

Parcels - Well View


- Both Site and Well
- Landfill
- Public Well
- Contamination Site
- Private Well

Jurisdictions

- Charlotte
- Cornelius
- Davidson
- Huntersville
- Matthews
- Mecklenburg
- Mint Hill
- Pineville
- Stallings

Page Comments? (include email for reply)

Send to Author



Clear Buffer

Sele

View_Cor
Found_v
Se

1

Environmen

1

Environmen

1

Environmer
GWS_Registe

1

GWS_Registe

1

La

1

Environmen

1

Mecklenburg County, NC Groundwater & Wasterwater Services
Landfill Information

For questions or comments concerning the information on this page call 704-336-5500.

***Parcel ID:** 11322117
Name: Y
Street No.: DUKE POWER COMPANY
Street Direction: 5101
Street Name:
Street Type: AMOS SMITH
City: RD
Zip: CHARLOTTE
Code: 28214
Status: LCIDP
Permit Number: Closed
Date Issued: 60-AH

* Link to GIS Real Estate System

EDMS Report for ARGU Review
4329 Amos Smith Rd., Charlotte
Tax Parcel ID # 113-061-18
File # 10922
App. #3116

Public water supplied by CMU is available at this site.

12/17/07 (Mon.) – Received request for ARGU review for water supply well abandonment located at 4329 Amos Smith Rd., Charlotte. WIS indicates no WSWs registered at this site.

12/19/07 (Wed.) – Identified one landfill site within 1,500 feet of the subject parcel:

MPL# 890 Duke Power Company Landfill
5101 Amos Smith Rd.
PID#113-221-17
Land Clearing and Inert Debris LF

File review of Duke Power Company LF file indicates:
No GW incident associated with site. Well is more than the required 100 ft. setback from the waste disposal boundary for a LCID LF and no samples are recorded for the subject well.

The referenced WSW location is within 1,500' of the property boundary for the Foxhole LF.

Based on this review this permit application is approved requiring abandonment under the Mecklenburg Co. Groundwater Regulations dated Oct. 5, 2004 Chapter II Section VIII Abandonment of Water Supply Wells with no special conditions.