Date Received 6 May 72

ICAR-SI Application No 7578

T C No 029-072-08

Map Date 31 May 72

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1 Install or Construct 2 ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge

Repair

3) PLOT PLAN ACCURATELY DIMENSIONED

13) NAME OF OWNER E. P. Mabe
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 518 Water St

15) PHONE NO Home 332 7701 Office 332 7755

16) LOCATION OF SYSTEM Lot Park
STREET OR CO RTE R AD

17) SUBDIVISION Park 52 Lot No 52 Block No

Map Book No Page No 294

18) DEED REFERENCE — DEED BOOK 2772 AT PAGE 294

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES NO DATE RUN 1971

20) PTR NUMBER See Instructions

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true

DATE OF APPLICATION

OWNER W. P. Mabe

Form No E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued 6 Mar 74 Serial No. ICAR(S) Permit No 7578

T C No 027-072-08

Map Date 31 May 72

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption Effluent Discharge)

Permission [illegible] to Construct / Alter / Repair [illegible] individual septic tank waste water treatment [illegible] described herein at the following location

Date: 6 Mar 74 [illegible] Approved 6 April 74 [illegible]

Repair



200'

3(7½x33x36 new)

10"

10"

Commercial

NAME OF OWNER E. P Mealer

ADDRESS OF PROPERTY Forestpark Trailer Park

[illegible] requirements as set forth in the [illegible] of the Mecklenburg [illegible] date of the application [illegible] A certificate of Occupancy [illegible] Director of Health for any system [illegible] to be constructed [illegible] of 30 days of completion.

Comments #52 Trailer

Richard Huntsman

Environmentalist

[illegible] signed by the division [illegible] Health Director [illegible] the signature of the Environmentalist [illegible] existing systems being altered or repaired

E-5-B-1-72

Date Issued 19 Mar 74 Serial 4425

C of A (s) No. 7578

P.O.T.C. No 027-0726

Map Date 31 May 72

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner NESBET (LAST) E.P. (FIRST) (MIDDLE)

Location of Property Forest Park Mobile Home Park

Application Number 7578 Permit Number 7578

Inspection Data:

Liquid Capacity of Tank Repair Tank Material

Total Length of Drain Tile 200' Number of Lines 3(7½x33'x36")

Depth of Filter Material 36" Cover Depth 15"

Water Supply Source Comm Distance from Water Source 100'+

Excavation Inspected 19 Mar 74 (DATE) Tank Inspected (DATE)

Nitrification Field Inspected 19 Mar 74 (DATE)

Washing Machine Line Inspected, If Applicable (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption effluent discharge as described above and it has been installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Trailer # 52

Richard Hartman
Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 6 MAR 74

ICAR(S) Application No [illegible]

T C No 800227272

Map Date 31 May 72

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1. Install or Construct 2. ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge

Repair

3. PLOT PLAN (ACCURATELY DIMENSIONED)

13. NAME OF OWNER [illegible] Hunter Co
LAST FIRST MI

14. ADDRESS OF OWNER [illegible] 1515 Kenilworth St

15. PHONE NO Home 332 7725 Office 332 7725

16. LOCATION OF SYSTEM Forest Park
STREET OR ROAD

17. SUBDIVISION [illegible] 26 - 74 - 69 Lot No 26-74-69 Block No

Map Book No. [illegible] 3 Page No 294

18. DEED REFERENCE -- DEED BOOK 2722 AT PAGE 294

19. HAS A PERCOLATION TEST BEEN RUN? ✓ YES NO DATE RUN [illegible]

20. PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the statements of same are true. It is understood that any permit applied for hereon may be revoked in effect if any of the above facts are not true.

6 MAR 74
DATE OF APPLICATION

H F Hunter
OWNER

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY