Date Received 8/4/78

MECK COUNTY DEPARTMENT OF

APT No. 1440

T. C. No. 023-085-21

Map Date 3-22-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Lindemann Harold
LAST FIRST MIDDLE

2) ADDRESS OF OWNER 527 Nottingham Dr. ZIP 28211

3) PHONE NO. Home 366-8853 Office


4) LOCATION OF PROPERTY RIVER CIR.
STREET OR COUNTY ROAD

5) SUBDIVISION LOT NO 21 BLOCK NO. 85

MAP BOOK NO 23 PAGE NO 08

6) DEED REFERENCE DEED BOOK 2355 PAGE NO 448

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Harold Lindemann
OWNER

EHD-5 7a

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

APT 14407
TC 023-085-21
Lot 21

OWNER: Harold Tinglemanis
ADDRESS: 527 Nottingham Dr.
COUNTY: Charlotte, N.C.
LOCATION OF SITE: River Circle

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 10,500 sq. ft

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 20-30% / PS / U	(S) 2-6% / PS / U	S / PS / U	S / PS / U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2-1 / PS clay / (U)	S 2-1 / PS clay / (U)	S / PS / U	S / PS / U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S Massive / PS / (U)	S Massive / PS / (U)	S / PS / U	S / PS / U
4. SOIL DEPTH (In.)	S / PS / U	S Depth / PS Variable / (U)	S / PS / U	S / PS / U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S 40" / PS / (U)	(S) None / PS / U	S / PS / U	S / PS / U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) 36" to ground water / PS / U	S Poorly Drained / PS / (U)	S / PS / U	S / PS / U
7. SOIL PERMEABILITY (Percolation Rate)	S slow / PS V slow / (U)	S V. slow / PS / (U)	S / PS / U	S / PS / U
8. OTHER (Specify)	S Inadequate / PS Area / (U)	S / PS / U	S / PS / U	S / PS / U
9. SITE CLASSIFICATION	unsuitable	unsuitable		
SOIL SERIES	W. Hos	Chewacla		

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: William A. Marlin

Title: Soil Scientist Date: 8-3-78

DHS Form 260: (2/77)
Sanitation

#2-

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 14407
T.C. NO. 023-085-12
MAP DATE 3-22-78
DATE 9-5-78

NAME OF OWNER Lindemonis, Haralds

ADDRESS OF OWNER 527 Nottingham Drive, Charlotte, NC 28211

LOCATION OF LOT River Circle, Lot 21, Block 85

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive.
Soil Permeability Unsuitable.
Inadequate area available for installation of ground absorption sewage disposal system inaccordance with North Carolina Department of Human Resources specifications.

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section

JRA:glr

EHD 398
7/77

R