13046
#10939

6 JAN '20 AM 9:04

MECKLENBURG COUNTY
HEALTH DEPARTMENT

APPLICATION FOR APPROVAL TO USE AN EXISTING ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM / WATER SUPPLY WELL

APPLICATION TYPE: (●) SEPTIC ONLY ( ) WELL ONLY ( ) SEPTIC & WELL
( ) ADDITION OR RENOVATION WITH OCCUPANCY INCREASE
(●) ADDITION OR RENOVATION WITH NO OCCUPANCY INCREASE
( ) EXCHANGE MOBILE HOME (SAME # BEDROOMS)
( ) COMMERCIAL OR INDUSTRIAL

PERSON FILING APPLICATION:
NAME: Stuart Hogge
ADDRESS: 4800 Rounding Run
CITY: Charlotte
STATE: NC ZIP: 28277
PHONE: 704 617-2044
ALTERNATE PHONE:
E-MAIL: stuarthogge@yahoo.com

PROPERTY OWNER: [☑] SAME AS PERSON FILING APPLICATION
NAME:
ADDRESS:
CITY:
STATE: ZIP:
PHONE:
ALTERNATE PHONE:
E-MAIL:

JOB LOCATION INFORMATION
TAX PARCEL #: 13901136
STREET ADDRESS: 8636 Blair Rd
CITY: Mint Hill
STATE: NC ZIP: 28227

SUBDIVISION OR MOBILE HOME PARK NAME:
LOT #:

WATER SUPPLY:
( ) MUNICIPAL (●) PRIVATE WELL ( ) PUBLIC WELL ( ) SHARED WELL ( ) OTHER

RESIDENTIAL PROPERTY TYPE: ( ) N/A
(●) HOUSE ( ) MODULAR HOME ( ) MULTIPLE FAMILY
( ) SINGLE MOBILE HOME ( ) DOUBLE WIDE
( ) OTHER

OCCUPANCY (both fields are required):
NUMBER OF BEDROOMS: 3
NUMBER OF OCCUPANTS: 6

COMMERCIAL / INDUSTRIAL PROPERTY TYPE: [ ] N/A
TYPE OF BUSINESS:
EMPLOYEES PER SHIFT:
OF SHIFTS:
INDUSTRIAL WASTES? ( ) YES ( ) NO
UNDERGROUND STORAGE TANKS? ( ) YES ( ) NO

ADDITION/RENOVATION TYPE ATTACHED TO EXISTING STRUCTURE:
[ ] BEDROOM [■] BATHROOM [ ] KITCHEN [ ] DINING ROOM [ ] LIVING ROOM [ ] DEN
[■] GARAGE [ ] SUNROOM [ ] PORCH [ ] DECK [■] OTHER office

ADDITION/RENOVATION TYPE DETACHED FROM EXISTING STRUCTURE:
[ ] DETACHED GARAGE [ ] DETACHED GARAGE WITH PLUMBING [ ] POOL HOUSE [ ] SHOP [ ] BARN
[ ] STORAGE SHED [ ] DETACHED PORCH / DECK [ ] OTHER

*The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

Owner's/Agent's Signature

1/3/20
Date

A PROPOSED PLOT PLAN (see page 2) is required to be submitted with each application.

MECKLENBURG COUNTY – GROUNDWATER & WASTEWATER SERVICES
3205 Freedom Dr. Suite 8000, Charlotte, NC 28208 OFFICE: (980) 314-1680, FAX: 704-336-6894


Revised on: 03/27/19

File #: _____

PROPOSED PLOT PLAN

A drawing showing the locations of the following items is required: existing and proposed property lines with dimensions, easements or right-of-ways, proposed building pad(s) or existing building footprint(s), all appurtenances (garage, driveway, deck, pool, etc.), location of existing or proposed well(s), location of existing or proposed sewer lines and sewage disposal systems, surface water bodies, and any aboveground or underground storage tanks. Provide names for all roads that adjoin the property.

Street Address: 8636 BLAIR RD Tax Parcel #: 13901136



*The undersigned, an authorized agent of the Mecklenburg County Health Department, certifies that the Department has approved the Request for the "Job Location" contained in this document. This approval is granted in accordance with the provisions of Laws and Rules for Sanitary Sewage Collection, Treatment, and Disposal and Water Supply Wells in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an installation, construction, alteration and/or repair approval is granted by this Department.
- Addition/Renovation approval valid 1 year from issuance date
- Mobile home exchange approval valid 6 months from issuance date

Garage addition approved
No addition bedroom

REHS Signature 1-14-2020 Date

MECKLENBURG COUNTY – GROUNDWATER & WASTEWATER SERVICES
3205 Freedom Dr. Suite 8000, Charlotte, NC 28208 OFFICE: (980) 314-1680, FAX: 704-336-6894

Revised on: 03/27/19

Google Maps 8636 Blair Rd, Tax Parcel#13901136


PROPERTY LINE 8.5 ACRES



Imagery ©2020 Google, Imagery ©2020 Maxar Technologies, U.S. Geological Survey, USDA Farm Service Agency, Map data ©2020 100 ft

8636 EXISING HOUSE
3 BED ROOM
2 ½ BATH

Google Maps 8636 BLAIR RD TAX PARCEL # 13901136



PROPOSED NEW ATTACHED ADDITION

-PAD 32' X 28'

- ONE CAR GARAGE
- OFFICE
- FULL BATH

EXISTING SEPTIC TANK LOCATION

MECKLENBURG COUNTY
LAND USE AND ENVIRONMENTAL SERVICES
Payment Receipt

Receipt Information

Date: 01/06/20
Receipt #: 119957
Check / Auth #: MC 08081Z
Received By: ELLISLW

Amount: 100.00
Tendered: 100.00
Returned: 0.00

Account Information

Account #: 200000
Contractor: HOGGE, STUART
Attn:
Address: 4800 ROUNDING RUN
Address:
City/State/Zip: CHARLOTTE, NC 28277

Item	Description	Permit#	Quantity	Unit Price	Total Price
0705	Use Existing System 8636 BLAIR RD		1	100.00	100.00

Mecklenburg
Environmental Health
3205 Freedom Drive
Charlotte, NC, 28208
Phone: (980) 314-1651
01/06/20 10:06

Sale

Merchant ID: 153629
Sequence #: 001
Card Type : MASTERCARD
Auth. Code: 08081Z
Acct. No: **********5738

Amount : 100.00

APPROVED

OP

Signature

I agree to pay the above total amount according to the card issuer agreement (Merchant agreement if credit voucher)

We appreciate your payment!
Thank You Very Much!

Merchant Copy

----------Outstanding Balances----------

Month-To-Date	Prior Month	30 Days	60 Days	90 Days	Balance

Exceed - no answer

Date Received MECKLENBURG COUNTY DEPARTMENT OF RECEIVED AUG 9 1977 ENVIRONMENTAL HEALTH

APT No. 13046

T. & P. No. 139-011-03

Map Date 4-19-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Hartley (LAST) Jessup (FIRST) S (MIDDLE)

2) ADDRESS OF OWNER Rt 1 Box 86-12 ZIP 28212

3) PHONE NO Home 545-9469 Office


4) LOCATION OF PROPERTY Hwy 51 (STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinafter described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



* ACCURATELY DIAGRAM & DIMENSION LOT

Jessup Hartley
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

APT 13046
PO 137-011-03

OWNER: Jessie L. Whitley
ADDRESS: Rt. 1, Box 8612
COUNTY: Charlotte
LOCATION OF SITE: off Highway 51

DATE REQUESTED: 9-14-77
PLAT NO.:
LOT SIZE: 120,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U — 2 to %	(S) PS U — 2-6%	(S) PS U — 2-6	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2:1 PS Expand. U (U) clay	S some PS (PS) 2-1 U clay	S Mixed PS U (U)	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S Blocky PS U (U)	S PS (PS) Blocky U	S Massive PS U (U)	S PS U
4. SOIL DEPTH (In.)	S < 40" PS U (U)	(S) 48" PS U	S Depth PS Varies U (U)	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S Saprolite PS @ 36-40" U (U)	(S) Bedrock PS 70' U	(S) None PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Seasonal PS Perched high water U (U) Table	(S) water PS Table U 70'	S Perched PS high U (U) water Table	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS V Slow U (U)	S PS (PS) mod-slow U	S Subject PS To Flooding U (U)	S PS U
8. OTHER (Specify)	S PS U	(S) Adequate PS Area U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	Provisionally Suitable	unsuitable	
SOIL SERIES	Helena	Cecil Mecklenburg	Chewacla	

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: Based on this investigation, an adequate area of provisionally suitable soil for the installation of a septic tank system. System should be located in area of provisionally suitable soil

Described By: William A Marlin

Title: Soil Scientist Date: 8-23-77

DHS Form 2601 (2/77)
Sanitation

Serial No. 1247

PTR No. 13046

Date Issued August 29, 1977

T C No. P.0.139-011-03

Map Date 4-19-77


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Whitley (LAST) Jessup (FIRST) S. (MIDDLE)

ADDRESS OF OWNER Route 1, Box 8612, Charlotte, NC ZIP 28212

LOCATION OF PROPERTY Highway 51 (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The soil investigation was conducted on that portion of the lot as indicated on the above plot. **Provisionally**

The permeability rate determined by the investigation was **Suitable** The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to construct and operate a system must be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of construction of the wastewater treatment system on the said lot.
2. The size of the septic tank and the absorption area which must be installed will be determined by the Mecklenburg County Department of Environmental Health in accordance with the permit obtained above, and on the size of the building to be constructed there.
3. The approval of said lot for the system mentioned herein does not guarantee acceptable system installation in every detail.
4. The soil investigation and the percolation tests which were performed on the lot which is the subject of this report are valid for a period of five years. Lots indicated as acceptable for system installation in which the system is not installed within the five year period must be retested.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

William B. Marion
Soil Scientist

John R. Atkinson
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 8/10/77

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH RECEIVED AUG 9 1977

SEE INSTRUCTIONS ON BACK

ICAR(S) Application No. 13046

T.C. No. 139-011-03


Map Date 4-19-77

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption effluent discharge



31) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home Yes ✓ No

Residence ✓ Yes No

4 No. of Bedrooms 3

5 Business Use Max No Employees

6 Washing Machine ✓ Yes No

7 Garbage Disposal Yes ✓ No

8 Dishwasher ✓ Yes No

9 Water Supply

A) Individual Well ✓

B Governmental System

C Community System

1 Well source

2 Governmental source

Sewage System

House located within 200 feet of public sewer Yes ✓ No

House located within 200 feet of community sewer Yes ✓ No

11 FHA Case No —

12 VA Case No —

13) NAME OF OWNER WHITLEY (LAST) JESSUP (FIRST) S (MIDDLE)

14) ADDRESS OF OWNER R-1 Box [redacted]8612 28212

15) PHONE NO Home 545-7469 Office

16) LOCATION OF SYSTEM Hwy 51 (STREET OR COUNTY ROAD)

17) SUBDIVISION — Lot No — Block No —

Map Book No Page No

18) DEED REFERENCE — DEED BOOK AT PAGE

19) HAS A SOIL INVESTIGATION BEEN RUN? YES ✓ NO DATE RUN

20) PTR NUMBER See Instructions

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

8-1-77
DATE OF APPLICATION

Jessup Whitley
OWNER

EHD-5-76

Environmental Health Department's Copy

Date Issued August 29, 1977

Serial No. 1132

LA No. 13046

T. C. No. P.0.139-011-03

Map Date 4-19-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Whitley (LAST) Jessup (FIRST) S, (MIDDLE)

ADDRESS OF OWNER Route 1, Box 8612, Charlotte, NC ZIP 28212

LOCATION OF LOT Highway 51 (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 13046. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permits which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Environmentalist

Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy


Date Issued 9-22-77 Serial No. 1107 ICAR(S) Permit No. 13046

T C No RO 139-011-03

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 13046, dated 8-19-77 and this permit shall be void and of no effect if the information provided in the application is in any way false or erroneous. All work shall be completed on or before 10-22-77, after which date this permit shall be null and void.



PLOT OF SYSTEM

Pumping Capacity PS

Septic Tank Size 1500

Tank Construction PS

Absorption Area Information Lines

Total Line Length 495 - 125

Number of Lines 5 3

Distance from House 10

Distance from Property Line 10

Distance from Well 100'

NAME OF OWNER Jessup S. White

LOCATION OF PROPERTY Hwy # 51

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Ordinance which are in effect on the date of the granting of this permit. A certificate of approval shall be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.** 15 X 99 X 17'

9 X 42 X 17'

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

Date Issued 9-28-77 Serial No. 1081 C of A (s) No. 13046 T C No 139-011-03

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Whitley (LAST) Jessup (FIRST) S. (MIDDLE)

Location of Property Hwy #51

Application Number 13046 Permit Number

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 495' 125' Number of Lines 5 3

Depth of Filter Material 12" Cover Depth 20"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected — (DATE) Tank Inspected 9-28-77 (DATE)

Nitrification Field Inspected 9-28-77 (DATE)

Washing Machine Line Inspected, If Applicable 9-28-77 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been X installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Installed as permitted

Environmentalist

EHD-S-76

Environmental Health Department's Copy

2/100 EH

C..TIFIC TE OF COMPLETION/O. E.. TION P RMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 13046 DATE: 3-11-93

TC: 139-011-03 CO ☐ L ☒ CRT

SERIAL Nº 15145

Name of Owner Jessup Whitley Juris.:

Address of Property 8604 Blair Rd

Inspection Data:

Tank Material PCC

Total Length of Drainfield 535'

Number of Lines 6 @ 90'

Cover Depth 12"-16"

Water Supply Source well

Distance to Water Source 50'+

Excavation Inspected 3-11-93

Tank(s) Inspected 3-11-93

Wash Line Inspected ———

High Water Alarm Inspected ———

PLOT

Design: 1993, cond, 1600 sq ft at 6-3'x90' lines, 1500 gal, 12"s, ~~division~~ water CTR# 174
EH
digital checked 3-22-93

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 4 Bedroom house, repair area for block panel system.
Do not pave over septic tank system!
Tank is 6'8" from neighbor's well.
Typed

Susan Coleman
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

400 gal

INSTALLATION, CONSTRUCTION, LETTER NO. 1, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 13C/16 DATE: 2-17-13

TC: 13-01-03 PC ☐ L

SERIAL Nº 15128

Permission is hereby given to X Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 2-12-13. All work shall be completed on or before 2-17-13, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.


House
Driveway
well
Property Line
Property Line
Property Line

Wit # 13046

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

Pd 45 CK # 2321 9-31-92

[] CAT

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5182

Date: 8/27/92

PERSON FILING APPLICATION:
NAME: LEE (last) WILLIAM (first) D (mi)
ADDRESS: 5 SILL BEAR RD. PHONE: 704 545-4006 945 4913
CITY: CHARLOTTE STATE: NC. ZIPCODE: 28227

PROPERTY INFORMATION (FROM ENGINEERING PERMIT):
TAX/PARCEL NUMBER: BK 139 PG 111 # 3 TSI-21-C-3AC
STREET ADDRESS: 8604 BEAR RD
ZONING: CHARLOTTE, NC R-40

PROPERTY OWNER:
NAME: WHITLEY (last) JESSUP (first) S. (mi)
ADDRESS: 8600 BEAR RD PHONE: 704 545 4913
CITY: CHARLOTTE STATE: NC ZIPCODE: 28227

SUBDIVISION OR MOBILE HOME PARK NAME: N/A

Township (check one):
[] 0 Mecklenburg County [] 2 Davidson [] 4 Pineville [] 6 Huntersville
[] 1 Charlotte [] 3 Cornelius [] 5 Matthews [X] Mint Hill

TYPE APPLICATION (check one):

LOT NUMBER: LOT SIZE (in acres): .91

[X] SOIL TEST - INDIVIDUAL LOT (B)
[] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[] EXCHANGE MOBILE HOME - SAME # BEDROOMS (T)
[] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[] COMMERCIAL OR INDUSTRIAL (N)
[] SOIL TEST DEVELOPMENT (P)
[] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
[] SINGLE MOBILE HOME (S) [] HOUSE (H) [] MULTIPLE FAMILY (U)
[] DOUBLE WIDE (D) [X] MODULAR HOME (M) [] OTHER ____ (O)

NUMBER BEDROOMS: 4 NUMBER OCCUPANTS: 5

SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
[] Community (C) [] Shared Well (S)
[] Municipal (M) [] Other 'spring' (O)
[X] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):
[] Swimming Pool [] Jacuzzi [] Stable/Barn [] Workshop [] None
[] Garage [] Storage Building [] Deck/Patio [] Bedrooms [] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: [signature] Date: 8-31-92

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules for Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair approval is granted by this Department.

...This permit is not transferable.

...

[] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

D. K. Fleshman 9-30-92
Environmentalist Date

Director or Authorized Section Head Date

WATER : 122791


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 13C46

TC: 139-011-03PO

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 12-26

TC: 31-C11-C3 pd.

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy

Mecklenburg County
Health Department

Betty S. Snow, R.N., M.A.
Health Director

September 24, 1992

Mr. Jessup S. Whitley
8600 Blair Road
Charlotte, NC 28227

RE: Propert, located at 8609 Blair Road
FILE: 13046
PARCEL: 139-011-03

Dear Mr. Whitley:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as PROVISIONALLY SUITABLE for such an installation. A copy of the Site Evaluation Report (Serial Number 12829) is enclosed for your information.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Our review process begins upon receipt of an Application for an Improvement Permit accompanied by a plot plan drawn to scale with accurate dimensions indicated detailing the location of existing well or type sewage disposal systems (if applicable), setbacks, and utility easements. Proposed buildings, etc. must be drawn on the plot plan to allow sufficient remaining space for the sewage disposal system and well. The well should be located 100 feet from any part of any sewage disposal system (including those located on adjacent properties).

Please note that this classification may be changed if any filling, grading or construction (including the drilling of a well) is performed on the lot which without prior approval from this Department. Current regulations in effect are "Laws and Rules for Sanitary Sewage Collection, Treatment, and Disposal: 15A NCAC 18A .1900, August, 1991". Changes in regulations may impact future approvals on this lot.

If there are any questions concerning this matter, please contact Bill Marlin at 336-5574.

Sincerely,

Kelly Randall, R.S., Soil Scientist
Individual Water and Wastewater Systems

9400

Ck # 2348 9-25-92

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

Lot # 246

W CRT

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

Date:

PERSON FILING APPLICATION:
NAME: LEE (last) WILLIAM (first) D (mi)
ADDRESS: 8600 BLAIR RD. PHONE: 704 545 4046
CITY: CHARLOTTE STATE: NC ZIPCODE: 28227

PROPERTY INFORMATION (FROM ENGINEERING FORM):
TAX/PARCEL NUMBER: [illegible]
STREET ADDRESS: 8600 Blair Rd
ZONING:

PROPERTY OWNER:
NAME: WHITLEY (last) JESSE (first) S. (mi)
ADDRESS: 8600 BLAIR RD PHONE: 704 545 4046
CITY: CHARLOTTE STATE: NC ZIPCODE: 28227

SUBDIVISION OR MOBILE HOME PARK NAME:

Township (check one):
[ ] 0 Mecklenburg County [ ] 2 Davidson [ ] 4 Pineville [ ] 6 Huntersville
[ ] 1 Charlotte [ ] 3 Cornelius [ ] 5 Matthews [X] Mint Hill

TYPE APPLICATION (check one):

LOT NUMBER: LOT SIZE (in acres):

[ ] SOIL TEST - INDIVIDUAL LOT (B)
[X] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[ ] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
[ ] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[ ] COMMERCIAL OR INDUSTRIAL (N)
[ ] SOIL TEST DEVELOPMENT (P)
[ ] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[ ] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[ ] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
[ ] SINGLE MOBILE HOME (S) [ ] HOUSE (H) [ ] MULTIPLE FAMILY (U)
[ ] DOUBLE WIDE (D) [X] MODULAR HOME (M) [ ] OTHER _____ (O)

NUMBER BEDROOMS: 4 NUMBER OCCUPANTS: 5

SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
[ ] Community (C) [ ] Shared Well (S)
[ ] Municipal (M) [ ] Other 'spring' (O)
[X] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):
[ ] Swimming Pool [ ] Jacuzzi [ ] Stable/Barn [ ] Workshop [ ] None
[ ] Garage [ ] Storage Building [ ] Deck/Patio [ ] Bedrooms [ ] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: William D Lee Date: 9/28/92

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules for Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair approval is granted by this Department.

...This permit is not transferable.

...

[ ] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[ ] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[ ] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

B R Ferguson 10-1-92
Environmentalist Date

[illegible] 10-2-92
Director or Authorized Section Head Date

WATER : 122791

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12829

File: 13046 Action 1

Parcel: PC 134-011-03 PC

Location: 8600 Blair Road

Subdivision:


Lot: Block: Acres: .78

Owner: Jessup S. Whitley
Address: 8600 Blair Road
Charlotte, N.C. 28227

Comments: 100% Repair - additional area may be available

Described by: William R. Martin

Date: 2-23-92



*** EVALUATION KEY ***

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 10-15%	S PS (U) 72" cut	(S) PS U 10%	S PS (U) Depression	S PS U	S PS U
Texture	S (PS) U slightly Expansive clay	S PS U —	S (PS) U slightly clay Expansive	S PS U —	S PS U	S PS U
Structure	S (PS) U sub & Blocky	S PS U —	S (PS) U sub & Blocky	S PS U —	S PS U	S PS U
Drainage	S (PS) U 72" wet	S PS U	S (PS) U 72" wet	S PS U —	S PS U	S PS U
Depth	S (PS) U 36"+	S PS U —	S PS (U) 27-32"	S PS U —	S PS U	S PS U
Restrictive Horizons	S (PS) U 72"	S PS U	S (PS) U >36"	S PS U —	S PS U	S PS U
Available Space	S (PS) U Limited	S PS U	S PS (U) Restricted	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IIE Cecil 1.4%	>2 cut	IIE Pacolet 2.4%	Depression		
Area Classification	S (PS) U	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U