

15901 N C 73 HY

00182123

12/17/07

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12459

File: 7936-A / 47B Action 3

Parcel: 001-451-02 ☑PC

Location: 15901 NC HWY 73

~~Subdivision:~~ BROWN COVE PARK


Lot: A Block: Acres: ∠ 1.0

Owner: MECKLENBURG COUNTY
Address: 700 N. TRYON ST
CHARLOTTE NC 28202

Comments: 100% REPAIR

Described by: Wells Randall

Date: 1-10-92



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S PS (U) EXPANSIVE CLAY	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U ∠ BLOCKY	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S PS (U) DRAINAGE MOTTLES 14"	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36" +	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S PS U NONE	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	(S) PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	ENON LIKE					
Area Classification	S PS (U)	S PS U	S PS U	S PS U	S PS U	S PS U

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER № 12459

File: 213-A/473 Action 3

Parcel: 141-451-02 ☑ PC

Location:

Subdivision:

Lot: A Block: Acres:

Owner:
Address:


Comments:

Described by:

Date:

***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.



FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series						
Area Classification	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U

400 ☑ SITE A Pd. 50.00 ck # 1931 11/13 12-6-92

RESTROOM
750 GPD
#7936A/478

Pc ☑

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

[] CRT

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

PERSON FILING APPLICATION:

NAME: MECKLENBURG COUNTY ENGINEERING (last) (first) (mi)

ADDRESS: 700 N. TRYON ST. PHONE: 704 336-4530

CITY: CHARLOTTE STATE: NC ZIPCODE: 28202

Date: JANUARY 6, 1992

PROPERTY OWNER:

NAME: MECKLENBURG COUNTY (last) (first) (mi)

ADDRESS: 700 N. TRYON ST. PHONE: 704 336-4530

CITY: CHARLOTTE STATE: NC ZIPCODE: 28202

PROPERTY INFORMATION
(FROM ENGINEERING FORM):

TAX/PARCEL NUMBER: 001-451-02/03

STREET ADDRESS: 15901 N.C. HWY. 73 HUNTERSVILLE, NC 28078

ZONING: R-R

Township (check one):
[] 0 Mecklenburg County [] 2 Davidson [] 4 Pineville [✓] 6 Huntersville
[] 1 Charlotte [] 3 Cornelius [] 5 Matthews [] 7 Mint Hill

SUBDIVISION OR MOBILE HOME PARK NAME: BROWN'S COVE PARK

LOT NUMBER: A LOT SIZE (in acres): SEE PLAN

TYPE APPLICATION (check one):

[✓] SOIL TEST - INDIVIDUAL LOT (D)
[] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
[] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[] COMMERCIAL OR INDUSTRIAL (N)
[] SOIL TEST DEVELOPMENT (P)
[] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
[] SINGLE MOBILE HOME (S) [] HOUSE (H) [✓] MULTIPLE FAMILY (U)
[] DOUBLE WIDE (D) [] MODULAR HOME (M) [] OTHER RESTROOM (O)

NUMBER BEDROOMS: NUMBER OCCUPANTS:

SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
[] Community (C) [✓] Shared Well (S)
[] Municipal (M) [] Other 'spring' (O)
[] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):
[] Swimming Pool [] Jacuzzi [] Stable/Barn [] Workshop [✓] None
[] Garage [] Storage Building [] Deck/Patio [] Bedrooms [] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Robert L. Davis Date: 1/6/92 (PROJECT ENGINEER)

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair permit is issued by this Department.

...This permit is not transferable.

...

[] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

_____ Environmentalist Date

_____ Director or Authorized Section Head Date

WWATER : 112991

Mecklenburg County
Health Department

January 14, 1992

Mecklenburg County
700 N. Tryon Street
Charlotte, NC 28202

RE: Property located at 15901 N. C. Hwy 73
FILE: 7936A/47B
PARCEL: 001-451-02/A

Dear Sir:

At your request a soils investigation was conducted on the property designated above. Results of this investigation showed the site to be classified as **UNSUITABLE** under criteria as set forth in Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Division of Health Services; Sanitary Engineering Section, Subchapter 10A, Sanitation. A copy of the Site Evaluation Report (Serial Number) is enclosed.

The soil on this property is not suitable for use with any conventional, modified or alternative system of which I am aware. If you wish to exercise your right of appeal concerning the interpretation and enforcement of these rules you may do so in accordance with G.S. 150B and 10 NCAC 1B.

If I can be of assistance, please do not hesitate to call.

Sincerely,

Kelly Randall

Kelly Randall, R.S.
Individual Water and Wastewater Systems

Enclosure

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603