Date Received 6 July 1979

15891

APT No. [redacted]

T. C. No. 211-223-9A

Map Date 9-9-38

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Doyle, James Austin & wife Sharon A.
(LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 10209 Weatherwood - Pineville NC ZIP 28106

3) PHONE NO Home 704-847-9571 Office 704-372-4800


4) LOCATION OF PROPERTY Fairview Drive
(STREET OR COUNTY ROAD)

5) SUBDIVISION Carmel Club Estates LOT NO 13 Section BLOCK NO C

MAP BOOK NO 211 PAGE NO 22

6) DEED REFERENCE DEED BOOK 3058 PAGE NO 556

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation or an on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

APT 15891

(Ground Absorption Sewage Disposal)

OWNER: John & Sharon Doyle
ADDRESS: 10201 Matthews Pineville
COUNTY: Mecklenburg 28105
LOCATION OF SITE: Fairview Lane

DATE REQUESTED:
PLAT NO.: 211-223-20, Lot 13-E
LOT SIZE: 62,360

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 2-10% PS U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2-1 PS Clay (U)	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S Massive PS (U)	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S 20" PS (U)	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	(S) None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Potential PS Lateral water movement (U)	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S V. slow PS (U)	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable			
SOIL SERIES	Wilkes			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)


Recommendations/Comments:

Described By: William R. Marlin

Title: Soil Scientist Date: 7-10-79

DHS Form 2604 (2/77)
Sanitation

2


91'
391'
Pa. Ave

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
[illegible] BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR. NO. 15891
T.C. NO. 211-223-28
MAP DATE 9/9/78
DATE 7/19/79

NAME OF OWNER Mr. and Mrs. John J. Doyle, Jr.

ADDRESS OF OWNER 10209 Matthews-Pineville Road Matthews, NC 28105

LOCATION OF LOT Parview Drive Carmel Club Estates subdivision Lot 13, Section C

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Depth Unsuitable
Soil Permeability Unsuitable

John R. Adkisson

John R. Adkisson, Environmentalist

R