Date Received 6-11-84

MECK COUNTY DEPARTMENT OF RECEIVED JUN 1 ENVIRONMENTAL HEALTH

SIR No. 21071

T. C. No. 108-112-01 PD

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER DEClaffence Clarence D (LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 2538 Dilton Road ZIP 28213

3) PHONE NO Home ____ Office ____


4) LOCATION OF PROPERTY Pineville-Matthews (STREET OR COUNTY ROAD)

5) SUBDIVISION ____ LOT NO ____ BLOCK NO. ____

MAP BOOK NO ____ PAGE NO ____

6) DEED REFERENCE DEED BOOK ____ PAGE NO ____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Clarence DeClaffence
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21071

T.C. NO. P0107-112-09

(Ground Absorption Sewage Disposal)

OWNER: Reid DeGRAFFE
ADDRESS: 2538 Milton Rd 28313

PLAT NO:
LOT SIZE: 2 A

LOCATION OF SITE: ON A Dirt Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S / PS Complex Slopes / U	S / (PS) 2-8 / U	S / PS / U	S / PS / U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S / PS / U	S Mixed / PS Clay / (U)	S / PS / U	S / PS / U
3. SOIL STRUCTURE (12-36 inches)	S / PS / U	S / PS weak Plasty / (U)	S / PS / U	S / PS / U
4. SOIL DEPTH (inches)	S / PS / U	S / PS 12 - 25 / (U)	S / PS / U	S / PS / U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S / PS / U	S / (PS) None / U	S / PS / U	S / PS / U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S / PS / U	S / (PS) slow / U	S / PS / U	S / PS / U
7. OTHER (Specify)	S / PS / U	S / PS / U	S / PS / U	S / PS / U
8. SOIL GROUP		IV B		
9. SITE CLASSIFICATION		Unsuitable Unsuitable		
10. SOIL SERIES		Wilkes		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Ramsey
Title: Soil Scientist

Date: 6-21-81

2H


231
Wilkes
Home site
Complex Slopes
Complex Slopes
577
Wilkes 2-
Flood Plain

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 21071
T.C. NO. PO 108-112-09
DATE: 6-25-84

Reid C. DeGraffen, Jr.
2538 Milton Road
Charlotte, NC 28213

RE: Property located at Plaza Road Ext.

Dear Mr. DeGraffen:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister Jr. by W. B. K.
Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure