Date Received 1/2/20

MECK. COUNTY DEPARTMENT OF
RECEIVED
JAN 1 0 1990
ENVIRONMENTAL HEALTH

APT No. 16426
T. C. No. [illegible]
Map Date 3/31/[illegible]

08

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Stitt (LAST) Richard (FIRST) Donald (MIDDLE)

2) ADDRESS OF OWNER 173 Box 80 Huntersville NC ZIP 28078

3) PHONE NO Home 875-3975 Office


4) LOCATION OF PROPERTY Blue Moon Court (STREET OR COUNTY ROAD)

5) SUBDIVISION Wildwood Green LOT NO 18 BLOCK NO

MAP BOOK NO 14 PAGE NO 473 & 475

6) DEED REFERENCE DEED BOOK 4118 PAGE NO 0045

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and on-site inspection of the lot hereinabove described for the purpose of determining the feasibility for the installation of an individual septic tank wastewater treatment system with subsurface absorption or effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Richard D Stitt
OWNER

EHD 5-74

Access to lot 18 through fence on lot 19. I own both.

Environmental Health Department's Copy

S. I. R. NO. 16426

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX II
SITE EVALUATION

T. C. # 017-286-08

(Ground Absorption Sewage Disposal)

OWNER: RICHARD D. SHAW
ADDRESS: R-3 Box 9
COUNTY: HUNTERSVILLE, N.C.
LOCATION OF SITE: BLUE Moon CUBJ

DATE REQUESTED: 1-10-80
PLAT NO.:
LOT SIZE: 90 x 2

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS (U) 0-2	S PS U 2-5	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey. Note 2:1 Clay)	S (PS) U clayey	S (PS) U Clayey	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) U 48	S PS U 48	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata Rock)	S (PS) U NONE	S (PS) U None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & internal)	S surface PS (U)	S PS Adequate U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U Moderate	S (PS) U Moderate	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable	Provisionally Suitable ✓		
SOIL SERIES	Cecil- WATER Stands on Surface	Cecil		

S - Suitable PS - Provisionally Suitable U Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies wet areas, fill areas, wells, water bodies, slope patterns, etc

Recommendations/Comments: USEABLE SPACE IS VERY LIMITED

Described By: W. B. RAMSEY

Title: Soil scientist Date: 1-15-80

2

NHS Form 2601
Sanitation
EHD 539 (3/79)

COULD BE A WELL IN THIS AREA
112
81
I
Cecil
2-5
Penny Drained Area
II
III
Cecil
2-5
This is a Dog House
NOT A well.
BLUE MOON COURT.
HAMBRIGHT ROAD

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 16426

T.C. # 017-286-08

DATE January 16, 1980

NAME OF OWNER Shaw, Richard D.

ADDRESS OF OWNER Route 3, Box 9, Huntersville, NC

LOCATION OF LOT Blue Moon Court, Wildwood Green, Lot 18

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

Limited Area

Please submit plans of proposed system

John R. Adkisson, Environmentalist