K

Date Received 10-16-73

MECK. COUNTY HEALTH DEPT. RECEIVED OCT 16 1973 ENVIRONMENTAL HEALTH DIVISION

CAR(S) Application No 7120

T C No


Map Date 1-11-71

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1) X Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms None

5) Business Use X Max No Employees 2 - 5

6) Washing Machine ___ Yes X No

7) Garbage Disposal ___ Yes X No

8) Dishwasher ___ Yes X No

9) Water Supply
- A) Individual Well ___
- B) Governmental System X
- C) Community System ___
  - 1 Well source ___
  - 2 Governmental source ___

10) Sewage System
- House located within 200 feet of public sewer ___ Yes X No
- House located within 200 feet of community sewer ___ Yes X No

11) FHA Case No ___

12) VA Case No ___

13) NAME OF OWNER Auten Motor Co. G. W. Auten Jr.
(LAST FIRST MIDDLE)

14) ADDRESS OF OWNER P.O. Box 436 Huntersville N.C.

15) PHONE NO. Home 525-1183 Office 875-2356

16) LOCATION OF SYSTEM old Statesville Rd North Hwy 115 N.C.
(STREET OR COUNTY ROAD)

17) SUBDIVISION McRavin Lot No. 123 to 141 Block No. MAP Book # 5 Page 54

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 2020 AT PAGE 115

19) HAS A PERCOLATION TEST BEEN RUN? ___ YES X NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

10-15-73
DATE OF APPLICATION

G. W. Auten Jr.
OWNER

FORM NO E-4-8-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 4517

ICAR(S) Permit No. 7120

Date Issued 12 Oct 77

T. C. No. 019-013-02

Map Date 11 Jan 71


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7120 dated 16 Oct 77 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 17 Dec 77 after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate _____

Liquid Capacity of Tank 1500

Tank Construction SC

Absorption and/or Nitrification Lines:

Total Line Lenght 300'

Number of Lines 6(6'x5C'x12")

Distance from House 20'

Distance from Property Line 10'

Distance from Well 50'+

NAME OF OWNER Duke Water Company

LOCATION OF PROPERTY Huntersville (Hwy 115)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: Claudius Thomas (Cont)

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO. E-5-4-1-71

HEALTH DEPARTMENT'S COPY

Serial 4094

C of A (s) No. 7120

Date Issued 22 Oct 73

T. C. No 019-013-02

Map Date 11 June 71

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Autec Motor Company (LAST, FIRST, MIDDLE)

Location of Property Huntersville, N.C (Highway 115-N)

Application Number 7120 Permit Number 7120

Inspection Date:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 300' Number of Lines 2 (15 X 50' X 17")

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source City Well Distance from Water Source 50'+

Excavation Inspected 22 Oct 73 (DATE) Tank Inspected 22 Oct 73 (DATE)

Nitrification Field Inspected 22 Oct 73 (DATE)

Washing Machine Line Inspected, If Applicable N/A (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: Claudius Moore (Contr.)

M. H. Kirby
Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY