Date Received 5-18-83

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 18 1983
ENVIRONMENTAL HEALTH

SIR No. 19688

T. C. No. 101-115-11

Map Date _____

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

## APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER HOLLAR (LAST) TROY (FIRST) _____ (MIDDLE)

2) ADDRESS OF OWNER RT 7 BOX 330 MOORESVILLE NC (ZIP) 28115

3) PHONE NO. Home 663-2926 Office NONE


4) LOCATION OF PROPERTY RIVER RD. (BETHEL CHURCH RD) (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO. 5 BLOCK NO. _____

MAP BOOK NO _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK 10 PAGE NO. 185

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.




7) ACCURATELY DIAGRAM & DIMENSION LOT

Troy Hollar
OWNER

EHD-5-74

Environmental Health Department's Copy

Serial No. 5037

SIR No. 19688

T. C. No. 001-115-11

Date Issued 5-27-83

Map Date


# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## SOIL INVESTIGATION REPORT

NAME OF OWNER Hollar, (LAST) Troy (FIRST) (MIDDLE)

ADDRESS OF OWNER Rt. 7, Box 330, Mooresville, NC ZIP 28115

LOCATION OF PROPERTY Bethel Church Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 5 BLOCK NO.




PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable** The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot
4. This approval is void if any grading, filling or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration and or repair of such a system

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

William R. Mullin
Soil Scientist

John P. Johnson
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19680

T.C. NO. 101-115-11

(Ground Absorption Sewage Disposal)

OWNER: Troy Fuller
ADDRESS: Rt. 7 Box 330 Mooresville, NC. 28115

PLAT NO: Lot 5
LOT SIZE: 21,780

LOCATION OF SITE: Rocket Church Rd

| FACTORS | AREA 1 | AREA 2 | AREA 3 | AREA 4 |
|---|---|---|---|---|
| 1. SLOPE (%) | S (PS) 2-9% U | S PS U | S PS U | S PS U |
| 2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay) | S (PS) Clay U | S PS U | S PS U | S PS U |
| 3. SOIL STRUCTURE (12-36 inches) | S (PS) Blocky U | S PS U | S PS U | S PS U |
| 4. SOIL DEPTH (inches) | S (PS) 36-40" U | S PS U | S PS U | S PS U |
| 5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock) | S (PS) Saprolite >36" U | S PS U | S PS U | S PS U |
| 6. SOIL DRAINAGE/GROUNDWATER (external and internal) | (S) 7+9" To ground water PS U | S PS U | S PS U | S PS U |
| 7. OTHER (Specify) | S PS U | S PS U | S PS U | S PS U |
| 8. SOIL GROUP | IVA | | | |
| 9. SITE CLASSIFICATION | Provisionally Suitable | | | |
| 10. SOIL SERIES | Cecil-Like | | | |

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William B. Martin
Title: Soil Scientist

Date: 5-25-83

EHD 539 (Revised: 6/82)

DEPARTMENT OF
ENVIRONMENTAL HEALTH
BUNCOMBE COUNTY
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO.

T.C. NO.

(Found Description Sequence Proposed)

OWNER:

ADDRESS:

LOCATION OF SITE:

SEE INSTRUCTIONS ON BACK

19685

ICAR(S) Application No. [illegible]

T. C. No. 023.151.01

Map Date 2


RECEIVED
FEB 19 1996
ENVIRONMENTAL HEALTH

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**Application for an**
**Installation, Construction, Alteration, and/or Repair Permit**
**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to: Increase existing system

1) _____ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ✓ Yes ____ No
Residence ✓ Yes ____ No

4) No. of Bedrooms 2
5) Business Use — Max No Employees ____
6) Washing Machine ____ Yes ✓ No
7) Garbage Disposal ____ Yes ✓ No
8) Dishwasher ____ Yes ✓ No
9) Water Supply:
A) Individual Well ____
B) Governmental System ____
C) Community System:
1. Well source Yes
2. Governmental source ____
10) Sewage System:
House located within 200 feet of public sewer ____ Yes ✓ No
House located within 200 feet of community sewer ____ Yes ✓ No
11) FHA Case No. ____
12) VA Case No. ____

13) NAME OF OWNER Elbert Realty Co
LAST FIRST MIDDLE

14) ADDRESS OF OWNER P.O. Box 221516 Charlotte NC 28222

15) PHONE NO. Home _____ Office 537-0700

16) LOCATION OF SYSTEM 13510 Poplar Ferry Road
STREET OR COUNTY ROAD

17) SUBDIVISION Riverside Meadows Lot No. 3 Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

Elbert Realty Co
OWNER

DATE OF APPLICATION

EHB-5-76

Environmental Health Department's Copy

Jane Helms

Date Issued 2/21/86

Serial No. 9371

SIR No. 19688

T. C. No. 023-151-01

Map Date L CRT

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**TO THE BUILDING INSPECTION DEPARTMENT**

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Elbert Realty Co.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER P. O. Box 221516 ZIP 28222

LOCATION OF LOT 12510 Rozzelle Ferry Road
(STREET OR COUNTY ROAD)

SUBDIVISION Riverside M.H.P. LOT NO. 3 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number _____. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

* * * USE EXISTING SYSTEM * * *

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy