BI-12-11-1

C of A (s) No. 17690

Date Issued 12-10-81 **Serial** 4911 T C No 199-011-21-2

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Gastonia United Oil Company, Inc.
(LAST FIRST MIDDLE)

Location of Property 13920 York Road

Application Number 17690 Permit Number 17690

Inspection Date:

Liquid Capacity of Tank 1500 gallons Tank Material precast concrete

Total Length of Drain Tile 600' Number of Lines 5

Depth of Filter Material 17" Cover Depth 7' to 2'

Water Supply Source well (not in yet) Distance from Water Source >58' from well

Excavation Inspected ____ (DATE) Tank Inspected 12-10-81 (DATE)

Nitrification Field Inspected 12-10-81 (DATE)

Car wash ~~Washing Machine~~ Inspected If Applicable 12-10-81 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption effluent discharge as described above and it has been ✓ installed or constructed ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit as in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Joel Greene (contractor)
B+F Quick Stop
Hit old drainfield crossing the new installation — it was dug out and packed back.

Mike Sutton
Environmentalist

EHD-5-76

Environmental Health Department's Copy

Date Issued 12-2-81

Serial No. 5138


ICAR(S) Permit No. 17690

T C No 199-0[illegible]-2[illegible]

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 17690 dated 12-2-81 and the permit is to be void and of no effect if the information provided in the application is in any way false. All work shall be completed on or before 1-2-81, after which date this permit shall be null and void.



Permit is for: S.F.

Tank Capacity: 1000 gallons

Tank Construction: precast concrete

[illegible]: 500'

[illegible]: E

[illegible] use: >10'

Property line: >10'

[illegible] well: >50'

PLAN OF SYSTEM

NAME OF OWNER: Sinclair United Oil Company, Inc.

LOCATION OF PROPERTY: 12200 York Road

The system shall be built in strict accordance with this approved permit and the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered inoperative or placed in use. The issuance of this permit does not in any way guarantee that the system installed will be free from failure or that the owner now or hereafter owning the dwelling using such system will not, as a result of the failure of the system to operate properly, be required to make additional installations.

H20 - 6' wide x 10' long x 7" deep

Comments

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 9-22-81

Serial No. 5273

LA No 17690

T C. No 111-011-21,22

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Gastonia United Oil Company
LAST FIRST MIDDLE

ADDRESS OF OWNER Drawer, 68, Gastonia, NC ZIP 28052

LOCATION OF LOT 13920 York Road (N.C. Hwy. #49)
STREET OR COUNTY ROAD

SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption effluent discharge based on the soil investigation on an on-site inspection of the said lot and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 17690. This approval is subject to the following terms and conditions

1. That the absorption field be installed constructed altered and/or repaired in the same area where the soil investigation was run
2. That an Installation Construction Alteration and or Repair Permit be issued and in full force and effect when the system is installed constructed, altred and or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permits which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

John R Atkinson

Environmentalist

Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 1-28-81

RECEIVED
FEB 19 1981

ICAR (S) Application No 17690

T C No 201-231-


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
"Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge"

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1 Install 2 Construct 2 Alter 2 Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3 PLOT PLAN ACCURATELY DIMENSIONED

Mobile Home ..Yes ..No
Residence ..Yes ..No
4 Number of Bedrooms
5 Water Use — Max No
Employees 2
6 Washing Machine Yes No
7 Garbage Disposal Yes No
8 Dishwasher Yes No
9 Water Supply
A Public Supply .05
B Individual System
Well
C Alternate Source
10 Distance from
Nearest Public Sewer 210 feet
Is Public Sewer Yes No
Nearest Public Sewer 210 feet at
Elevation Lower Yes No
11 EHA Case No None
12 LA Case No None

13 NAME OF OWNER Gastonia (LAST) United (FIRST) Oil Co Inc (MIDDLE)

14 ADDRESS OF OWNER P. O. Box Eastgate Shp Ctr Gastonia N C

15 PHONE NO Home Office 834 3561

16 LOCATION OF SYSTEM Lot 1 Eastgate Shp Ctr, 24 (STREET OR COUNTY ROAD) Gastonia N C 28134

17 SUBDIVISION Hwy 49 - 2 miles East of Dustin Boyce Bridge Lot No Block No

Map Book No Page No

18 DEED REFERENCE — DEED BOOK 2516 AT PAGE 49
(REGISTER OF DEEDS OFFICE)

19 HAS A SOIL INVESTIGATION BEEN RUN? YES NO DATE RUN

20 PTR NUMBER See instructions

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true

Gastonia United Oil Co Inc

DATE OF APPLICATION 1-28-81

OWNER By Tom E Gibson

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 3991

PTR No. 17690

Date Issued March 3, 1981

T C No. 199-011-21,22

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER (LAST) Gastonia United Oil Company, INc. (FIRST) (MIDDLE)

ADDRESS OF OWNER 2766 East Ozark Avenue, Gastonia, NC (ZIP)

LOCATION OF PROPERTY Highway 49 (NUMBER OF NEW ROAD)

SUBDIVISION Rt. 1, Box 134, Pineville, NC (LOT NO) (BLOCK NO)



PLOT PLAN (SCALE 1" =)

Provisionally Suitable

Soil Scientist

Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 17690
T.C. No. 199-011-21,22

(Ground Absorption Sewage Disposal)

OWNER: GASTONIA United Oil Co.
ADDRESS: 2766 EAST OZARK AVE
COUNTY: GASTONIA
LOCATION OF SITE: Hwy 49 At 1st Store N of Old County Store

DATE REQUESTED: 1-28-81
PLAT NO:
LOT SIZE: 2A

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-10 U 2-20	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S (PS) Clayey U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 48> U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (inches) (Impervious strata, Rock)	S (PS) NONE U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) Adequate U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (percolation rate)	S (PS) Moderate U	S PS U	S PS U	S PS U
8. OTHER (specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	✓ Suitable			
10. SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable


** See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments:

Described By: W. B. Tamsey
Title: Sanitarian
Date: 3-2-81

DHS Form 2601
Sanitation
EHD 539 (2/80)

✓


Strip Leased Area
Cecil
2-20
Proposed Cecil
Sign 2-10
200
Proposed Gas
Pump Area
200
Highway 49

Date Received_____

APT No 17690

T. C. No. 199-011-21, 22

Map Date_____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER (LAST, FIRST, MIDDLE) GASTONIA UNITED OIL Co.

2) ADDRESS OF OWNER DRAWER 68, GASTONIA, N.C. ZIP 28052

3) PHONE NO Home _____ Office 824-3561


4) LOCATION OF PROPERTY York Rd - N.C. #49 (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the purpose of having an investigation and inspection of the property hereinafter described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent disposal.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Tom Gefvert by [illegible]
OWNER

EHD 5-74

Environmental Health Department's Copy