Date Received 5-22-73

APT No 6334

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER FLYNNCO, INC (WARREN E. FLYNN)
(LAST) (FIRST) (MIDDLE)

2) ADDRESS OF OWNER P.O. B. 725, Mathews, N.C. ZIP

3) PHONE NO Home 364-7431 Office 847 4731


4) LOCATION OF PROPERTY 1101 REVERDY LANE
(STREET OR COUNTY ROAD)

5) SUBDIVISION REVERDY WOODS LOT NO 15 BLOCK NO. NONE

MAP BOOK NO 15 PAGE NO 565 + 567

6) DEED REFERENCE. DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT 247.31'

OWNER Warren Flynn

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 3185

PTR No. 6334

T C No. 227-043-05

Date Issued June 7, 1973

Map Date 12-15-72

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Flynnco, Inc. (Warren E. Flynn)
LAST FIRST MIDDLE

ADDRESS OF OWNER Post Office Box 725, Matthews, N.C. ZIP 28105

LOCATION OF PROPERTY 1101 Reverdy Lane
STREET OR COUNTY ROAD

SUBDIVISION Reverdy Woods LOT NO. 15 BLOCK NO.



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater teratment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John K Adkisson

Director, Environmental Health Division or
Authorized Section Head

FORM NO. E-2-4-1-71

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 5-22-73

ICAR(S) Application No 6334

T C No


Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ✓ Install or Construct 2 ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



4 No of bedrooms 4

5 Business Use Max No Employees

6 Washing Machine ✓ Yes No

7 Garbage Disposal Yes ✓ No

8 Dishwasher ✓ Yes No

9 Water Supply
A Individual Supply ✓
B Government System
C Community System
1 Well source
2 Government source

10 Sewage System
House located within 200 feet of public sewer Yes ✓ No
House located within 200 feet of community sewer Yes ✓ No

11 FHA Case No NONE

12 VA Case No NONE

31) PLOT PLAN (ACCURATELY DIMENSIONED) 247.31'

13) NAME OF OWNER FLYNNCO, INC. (WARREN E. FLYNN) (LAST, FIRST, MIDDLE)

14) ADDRESS OF OWNER P.O. BOX 725, MATHEWS, N.C.

15) PHONE NO Home 364-7431 Office 847-4731

16) LOCATION OF SYSTEM 1101 REVERDY LANE (STREET OR COUNTY ROAD)

17) SUBDIVISION REVERDY LANE Lot No. 15 Block No NONE

Map Book No 15 Page No. 565 + 567

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION ___

OWNER Warren Flynn

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 3021

LA No. 6334

Date Issued June 7, 1973

T C. No 227-043-08

Map Date 12-15-72

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Flynnco, Inc. (Warren E. Flynn)
LAST FIRST MIDDLE

ADDRESS OF OWNER Post Office Box 725, Matthews, N.C. ZIP 28105

LOCATION OF LOT 1101 Reverdy Lane
STREET OR COUNTY ROAD

SUBDIVISION Reverdy Woods LOT NO 15 BLOCK NO.

MAP BOOK NO. PAGE NO.

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/in on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 6334. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Thomas R. Ward
Environmentalist

John R Atkisson
Director, Environmental Health Division or Authorized Section Head

FORM NO. E-3-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 11-13-73

Serial No. 4626

ICAR(S) Permit No. 6334

T. C. No. _____

Map Date _____


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 6334, dated 5-22-73, and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 12-13-73, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500 gal.

Tank Construction Concrete

Absorption and/or Nutrification Lines.

Total Line Lenght 795'

Number of Lines 6

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Lynwood Inc.

LOCATION OF PROPERTY 1101 Remedy Lane

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: 15 X 133' another pit and
with 7½ X 50'
County Septic Tank 6

Division or Section Head

Thomas R. Ward
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO. E-5-4-1-71

HEALTH DEPARTMENT'S COPY

Serial 4199

C of A (s) No. 6334

Date Issued 11-20-73

T C No. 227-043-05

Map Date 12-15-72

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Flynn, Inc. (LAST, FIRST, MIDDLE)

Location of Property 1101 Ronald Lane

Application Number 6334 Permit Number 6334

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material Concrete

Total Length of Drain Tile 795' Number of Lines 6

Depth of Filter Material 17" Cover Depth 20"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 11-20-73 (DATE) Tank Inspected 11-20-73 (DATE)

Nitrification Field Inspected 11-20-73 (DATE)

Washing Machine Line Inspected, If Applicable 11-20-73 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ~~installed~~ or constructed, ~~altered~~ or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: Installed by County Septic Tank Co.

Thomas R. Ward
Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY