Date Received 6/22/79

MECK COUNTY DEPARTMENT OF
RECEIVED
JUN
ENVIRONMENTAL HEALTH

APT No 15871
T. C No. 193-068-03
Map Date 1/14/77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER J. W. Huntley Const Co Inc
LAST FIRST MIDDLE

2) ADDRESS OF OWNER P.O. Box 25242 Charlotte N.C. ZIP 28212

3) PHONE NO Home 7866446 Office same


4) LOCATION OF PROPERTY Ole Creek Trail off Margaret Wallace Rd
STREET OR COUNTY ROAD

5) SUBDIVISION Ole Creek LOT NO 3 BLOCK NO F

MAP BOOK NO 14 PAGE NO 181

6) DEED REFERENCE DEED BOOK 3806 PAGE NO 126

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of an investigation of the property hereinafter described for the purpose of determining the feasibility of the installation of an individual sewage disposal system with a subsurface soil absorption effluent disposal



There is a small creek at the back of the lot where the proposed drain field will be. Creek is approximately 50' from the back of the lot.

7) ACCURATELY DIAGRAM & DIMENSION LOT

Wayne Huntley
OWNER

EHD 5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 15871
193-060-03

(Ground Absorption Sewage Disposal)

OWNER: F.W. HUNTLEY Const. Co DATE REQUESTED: 7-2-79
ADDRESS: PO Box 25242 PLAT NO.:
COUNTY: Meck. 28212 LOT SIZE: 34/112
LOCATION OF SITE: Olde Creek Trail lot 3 Block F

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-30 U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS (U) mostly Saprolite	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S PS (U) massive	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) >48 U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS (U) Saprolite	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS (U) slow	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS (U) slow	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable			
SOIL SERIES	Wilkes			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)


Recommendations/Comments:

Described By: Willard B Ramsey

Title: Soil Scientist Date: 2-12-79

dhs form 2601 (1/79)
Sanitation

2


OLD CREEK TRAIL
2-30
WILKES
FAILURE
2-30
WILKES
2-10
WILKES

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR. NO. 15871
T.C. NO. 193-068-03
MAP DATE 1/14/77
DATE 7/13/79

NAME OF OWNER F. W. Huntley Construction Company, Inc.

ADDRESS OF OWNER PO Box 25242 Charlotte, NC 28212

LOCATION OF LOT Old Creek Trail Lot 3 Block F

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive
Soil Permeability Unsuitable

John R. Adkisson

John R. Adkisson, Environmentalist

R