

2015 BURGANDY DR

04702508

7/2/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7466-A DATE: 3/10-92

TC: 047-025-08 ☐ L ☑ CRT

SERIAL № 13926

Name of Owner Ray Foster Juris.:

Address of Property 2015 Burgandy Dr.

Inspection Data:

Tank Material PVC

Total Length of Drainfield 400

Number of Lines 4 @ 100'

Cover Depth 18"-32"

Water Supply Source well

Distance to Water Source > 50'

Excavation Inspected 3-10-92

Tank(s) Inspected 3-10-92

Wash Line Inspected

High Water Alarm Inspected

PLOT

Design: 1992, 1500ST, CON, 1200SFT, 12", cecil CTR# 206

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☑ installed or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☑ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Installed for 3 bedrooms

B. R. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

D400

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 7466-A DATE: 3-6-92

TC: 047-025-08 ☑ L

SERIAL Nº 14063

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 10-3-91. All work shall be completed on or before 4-6-92, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank _____ gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400 feet

Number of Lines 4

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well >50 feet

NAME OF OWNER Ray Foster

LOCATION OF PROPERTY 2015 Burgandy Dr.

Comments: 4 lines 3'X100'X12" stone

Division or Section Head

B. R. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

10/03/91

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr 2nd Floor
700 N. Tryon Street
Charlotte, NC 28202

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 1466A
TC: 047-025-08
SERIAL: № 0019922

CK#2688
$200.00
☑ L ☑ CRT

JOB LOCATION

① ADDRESS: 2015 Burgandy Drive Char.NC 28262 (STREET NO. / STREET) ② FILE:
③ JURISDICTION: Mecklenburg County ④ TAX PARCEL NO.:
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: RAY (FIRST) W (MIDDLE) Foster (Ruth A) (LAST)
⑨ MAILING ADDRESS: 2008 Burgandy Drive
⑩ CITY: Charlotte ⑪ STATE: NC ⑫ ZIP: 28262
⑬ PHONE: (WORK) ⑭ (HOME) (704) 596-4848

REQUEST

This request is for a(n):

⑮ ☒ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3 ㉕ Type?
㉓ Maximum occupancy? 2 ㉖ Maximum number of employees?
㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Ruth A Foster
Date: Oct 3, 1991

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:


... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 60 months from the date of issuance.

B. R. Ferguson — Environmentalist — 10-11-91 — Date

Director or Authorized Section Head — 10-15-91 — Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.


IDEAL MOBILE HOME PARKS, INC.
DEED 5674 P. 858
10' PUBLIC DRAINAGE R/W
N 73°49'00" E
81.88'
149.68'
LOT 13
N 19°28'30" E
124.05'
repair area
5 lines 3'x80'
53,077 sq. ft.
1.218 Acres
LOT 10
LOT 11
BLOCK 2
LOT 9
S 89°56'53" W
201.31'
S 65°47'50" E
209.42'
well
25' SETBACK LINE
L=19.93'
L=29.27'
R=480.71'
R=480.71'
L=135.73'
CHORD= S 14°51'26" W 135.28'
60.00'
BURGANDY DRIVE
60' PUBLIC R/W

BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

FROM: COUNTY ENGINEERING DEPARTMENT

EHD FILE _____ JURISDICTION CODE Cher

PARCEL NUMBER 047-025-08

ASSIGNED ADDRESS 2015 Burgandy Dr

EXISTING ADDRESS 2009 Burgandy Dr

PROJECT NAME NA

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	DISAPPROVED
1. SUBDIVISION REGULATIONS	/ /	/ /*
2. FLOODWAY REGULATIONS	/ /	/ /*
3. EROSION CONTROL REGULATIONS	/ /	/ /*
4. PUBLIC UTILITY EASEMENT	/ /	/ /*

	PRESENT	NOT PRESENT
5. PUBLIC UTILITY EASEMENT	/ /*	/ /
6. PROPERTY FRONTS ON THOROUGHFARE	/ /*	/ /
7. DRIVEWAY PERMIT REQUIRED	/ /*	/ /

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: Is county correct address

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: Gigi

OPWEAR 06-88

NEW ADDRESS / /*

FORM 100

Mecklenburg County
Health Department

June 5th, 1991

George L. Bicket, Jr.
2001 Burgandy Drive
Charlotte, NC 28202

RE: Property located at 2001 Burgandy Drive Lot 10
FILE: 7466A
PARCEL: 047-025-08

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as PROVISIONALLY SUITABLE for such an installation. A copy of the Site Evaluation Report (Serial Number 17254) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Gene Saughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 17254

File:

Action 1

Parcel: 7466A
047-025-08

☐ PC

Location:

Subdivision: Burgandy Drive

Lot: 10 Block: 2 Acres: 1.0


Lot 10

Owner:
Address:
George L. Bicket, Jr.
2001 Burgandy Drive
Charlotte, NC 28202

Comments: Will need surface water diversion at least - would recommend subsurface interceptor drain above downfall

Described by: William R. Marlin

Date: 6-4-91



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-6%	S PS (U) old Terraces	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U clay	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	(S) PS U 7½" to 7½" water	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	(S) PS U 7½"	S PS U —	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	(S) PS U 7½"	S PS U —	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U —	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil-Lilly	old Terraces				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

Paid
05/23/91
CK# 5463
$50.00
Rec

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 74666A

TC: 047-025-08

☒ PC ☐ REPT

JOB LOCATION

① ADDRESS: BURGANDY DRIVE

② SUBDIVISION: RANDOMWOOD ③ LOT: 10 ④ BLOCK: 2

⑤ PARCEL REFERENCE: BOOK NO.: _____ PAGE NO.: _____ PARCEL NO.: 047-025-08

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: GEORGE (FIRST) L. (MIDDLE) BICKETT JR (LAST)

⑧ MAILING ADDRESS: 2001 BURGANDY DRIVE

⑨ CITY: CHARLOTTE ⑩ STATE: N.C. ⑪ ZIP: 28207

⑫ PHONE: (WORK) — (HOME) 588-0740 - 536-1945

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: George L. Bickett Jr.

Date: May 23 '91

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY