6-3-83

RECEIVED
JUN 3 1983
ENVIRONMENTAL HEALTH

JUN 1 1983
ENVIRONMENTAL HEALTH

SIR No. 19737
T. & R. No. 111-041-08
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH


APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Brawley (LAST) Columbus (FIRST)
2) ADDRESS OF OWNER 9600 Brawley Lane ZIP 28215 (MIDDLE)
3) PHONE NO. Home _____ Office _____
4) LOCATION OF PROPERTY Teeter Drive (STREET OR COUNTY ROAD)
5) SUBDIVISION _____ LOT NO _____ BLOCK NO. _____
MAP BOOK NO _____ PAGE NO. _____
6) DEED REFERENCE DEED BOOK _____ PAGE NO. _____

111 041 08

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.

FIND SIGN AND FOLLOW ROPE TO ROPED OFF House AREA



7) ACCURATELY DIAGRAM & DIMENSION LOT

Columbus Brawley
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 5071

SIR No. 19737

T. C. No. PO 111-041-08

Date Issued 6-17-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Brawley (LAST) Columbus (FIRST) (MIDDLE)

ADDRESS OF OWNER 9600 Brawley Lane Charlotte, NC ZIP 28215

LOCATION OF PROPERTY Teeter Drive (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the sptic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling or construction, including the drilling of a well, is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, repair and or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

ENDS: William R. Rankin
Soil Scientist

Bill D. Hardister Jr.
Environmental Health Director or
Authorized Section Head

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 17937

T.C. NO. PO 111-04108

(Ground Absorption Sewage Disposal)

OWNER: Columbus Brumley
ADDRESS: 9800 Brumley Lane Charlotte, N.C. 28215

PLAT NO:
LOT SIZE: Approx 3 Acres

LOCATION OF SITE: East of Toeter Dr.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-10%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 36-40" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) >36" U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) >36" To ground water U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IV A			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cecil Like			

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William B. Martin
Title: Soil Scientist

Date: 6-16-83

EHD 539 (Revised: 6/82)



Tester Pit & Dirt Profile