Date Received 6-18-82

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
JUN 18 1982

SIR No. 18797

T. P. No. 137-229-17

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Little (LAST) Pauline (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 4901 Victoria Ave. Charlotte, N. C. ZIP 28213

3) PHONE NO Home 596-1929 Office Brenda Kiser 365-2222

4) LOCATION OF PROPERTY Victoria Ave. Road #2631 (STREET OR COUNTY ROAD)


5) SUBDIVISION LOT NO 47 BLOCK NO 229

MAP BOOK NO 37 PAGE NO 22

6) DEED REFERENCE DEED BOOK #6 PAGE NO 839

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge

Part #49, 50, 51, part 52



7) ACCURATELY DIAGRAM & DIMENSION LOT

Pauline B. Little
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. NO. 18797
T.C. NO. PO 037-229-47

(Ground Absorption Sewage Disposal)

OWNER: Pauline Little
ADDRESS: 4901 Victoria Ave
COUNTY: 28213
LOCATION OF SITE: Victoria Ave

DATE REQUESTED: 6-18-82
PLAT NO:
LOT SIZE: .44A

Lot 46, 47 + PO. 45 & 48

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-10	S (PS) U 2-10	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S PS (C) Massive	S PS (C) Massive	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS (C) Blocky	S PS (C) Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (D) 48	S PS (D) 48	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS Clay (B)	S PS Slow (B)	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS Slow (C)	S PS Slow (C)	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation rate)	S PS Slow (C)	S PS Slow (C)	S PS U	S PS U
8. OTHER (Specify) Small Size	S PS (E)	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable	Unsuitable		
10. SOIL SERIES	Vance	Helena		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)


Recommendations/Comments:

Described By: W. B. Ramsey
Title: Soil Scientist
Date: 6-29-82

DHS Form 2601
Sanitation
EHD 539 (3/82)

2

Part of Tract 47



MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R.# 18797

P.O.# PO 037-229-47

DATE: 7-1-82

NAME OF OWNER: Little, Pauline

ADDRESS OF OWNER: 4801 Victoria Ave., Charlotte, NC 28213

LOCATION OF LOT: Victoria Avenue, Lots 46,47 & PO 45 & PO 48

It determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

SOIL TEXTURE (massive)	UNSUITABLE
SOIL STRUCTURE (blocky)	UNSUITABLE
SOIL DEPTH (less than 48 inches)	UNSUITABLE
SOIL DRAINAGE/GROUNDWATER (slow)	UNSUITABLE
SOIL PERMEABILITY (slow)	UNSUITABLE

Mike Sekton

Michael E. Sekton
Environmentalist
On Premise Waste Disposal Section