Date Received 9/6/77

APT No. 14523

T. C. & O. No. 105-222-09

Map Date 3-1-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Keen (LAST) Jr. (FIRST) Donald (MIDDLE)

2) ADDRESS OF OWNER 221 Hillside Ave ZIP 28209

3) PHONE NO Home 372-9292 Office 558-2287


4) LOCATION OF PROPERTY 9001 Fairies Rd. 34 Plaza Rd Extn. (STREET OR COUNTY ROAD)

5) SUBDIVISION Northeast Mobile Home City (see attached) LOT NO 29 BLOCK NO

MAP BOOK NO Print PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is made to Mecklenburg County Department of Environmental Health for the conduct of soil tests on the property described above for the purpose of determining the adaptability of said property for a septic tank sewage treatment system in accordance with the specifications on page 2.



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER E Keen

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

APT 14523
PO 105-222-04
LOT #29

OWNER: Donald J. Klein
ADDRESS: 231 Hillcrest Ave
COUNTY: Charlotte N.C.
LOCATION OF SITE: Northeast Mobile Home Park - Farina Rd

DATE REQUESTED:
PLAT NO.:
LOT SIZE: 5,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-10% U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2-1 (U) Clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS massive (U)	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) 40" PS U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) 7+' to PS ground U water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S Slow PS U (U) Slow	S PS U	S PS U	S PS U
8. OTHER (Specify)	S See PS Note (U)	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable			
SOIL SERIES	Enon			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: * Drainfield from existing trailer on adjacent lot runs across lot.

Described By: William A. Martin

Title: Soil Scientist Date: 9-29-78

DHS Form 2604 (2/77)
Sanitation

#2

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SIR.NO. 14523
T.C. NO. P.0.105-222-09
MAP DATE 3-1-77
DATE 10-2-78

NAME OF OWNER Keen, J. Donald

ADDRESS OF OWNER 221 Hillside Avenue, Charlotte, NC 28209

LOCATION OF LOT 9001 Faires Road, Lot 29, Northeast Mobile Home Park

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive.
Soil Permeability Unsuitable.
Site Classification Unsuitable - Drainfield from existing system crosses lot.

John R. Adkisson

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section

IHD 308
77.7

R