W

Date Received 4-5-73 (180)

APT No. 5929

T. C No [redacted] 213413-11

Map Date 2-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Mail to Richard Turner Rt 6 or C Monroe Rd 28112

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Finger (LAST) Jon (FIRST) Robert (MIDDLE)

2) ADDRESS OF OWNER 114 Springway Drive, Concord, N.C. ZIP 28025

3) PHONE NO Home 786-1763 Office SAME


4) LOCATION OF PROPERTY Beverly Circle (STREET OR COUNTY ROAD)

5) SUBDIVISION Sandis Beverly Park LOT NO 11 BLOCK NO. B

MAP BOOK NO 8 PAGE NO. 161

6) DEED REFERENCE DEED BOOK [redacted] PAGE NO [redacted]

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER Jon R. Finger

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY

Department of Public Health

1200 Blythe Boulevard

Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. April 25, 1973
2. _____
3. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. 5929
T.C. No. 213-113-11
4-14-73

NAME OF OWNER Finger, Jon Robert

ADDRESS OF OWNER 114 Springway Drive, Concord, N.C. ZIP 28025

LOCATION OF LOT Beverly Circle, Lot 11-B

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	4-24-73	180 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Thomas R. Ward
Environmentalist

(Stencil No.)
MED 398

FORM NO.
E-19-8-14-70