Date Received 10-3-78

MECK COUNTY DEPARTMENT OF
RECEIVED
OCT 5 1978
ENVIRONMENTAL HEALTH

14612 1

APT No. ~~8543~~ P.O.

T. C. No. 137-032-19

Map Date 4-19-74

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Nord (LAST) Nettie (FIRST) Stevens (MIDDLE)

2) ADDRESS OF OWNER 7475 Trueright ch. Rd Charlotte, NC ZIP 28212

3) PHONE NO. Home 545-4411 Office


4) LOCATION OF PROPERTY Trueright ch RD Charlotte, NC (STREET OR COUNTY ROAD)

5) SUBDIVISION Mint Acres LOT NO 34 back portion BLOCK NO

MAP BOOK NO 7 PAGE NO 243 & 34

6) DEED REFERENCE DEED BOOK 1848 PAGE NO 441

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on-site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mrs Nettie Stevens Nord
OWNER

EHD 5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY HEALTH DEPARTMENT

INTER-OFFICE COMMUNICATION

DATE: October 3, 1974

TO: John R. Adkisson

FROM: W. Everette Lynn, Jr. WEL
Soil Scientist

SUBJECT: Apt. #513 (N. S. Hord)
Lot No. 34, Truelight Church Road
10-2-74

The lot consists of soils of the Cecil series. These soils have good drainage, good aeration and moderate permeability.

Based on this investigation, the lot is recommended for approval for installation of a septic tank system. System design should be based on a 60 min./in. perc. rate.

WEL:dsb