Date Received 9-1-82

MECK COUNTY DEPARTMENT OF
RECEIVED
SEP 1 1982
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 18973

T. C. No. 085-054-32


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ Install or Construct 2) * Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



* → SEE ATTACHMENT

3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes * No
Residence * Yes ___ No

4) No of Bedrooms 3

5) Business Use — Max No Employees NA

6) Washing Machine * Yes ___ No

7) Garbage Disposal ___ Yes * No

8) Dishwasher ___ Yes * No

9) Water Supply:
A) Individual Well ___
B) Governmental System *
C) Community System:
1. Well source ___
2 Governmental source ___

10) Sewage System.
House located within 200 feet of public sewer * Yes ___ No
House located within 200 feet of community sewer ___ Yes * No

11) FHA Case No NA ?

12) VA Case No. NA ?

13) NAME OF OWNER Moore (LAST) Floyd (FIRST) (MIDDLE)

14) ADDRESS OF OWNER 3003 Dogwood Ave

15) PHONE NO. Home 334-6103 Office NA

16) LOCATION OF SYSTEM 3001 Dogwood Ave (STREET OR COUNTY ROAD)

17) SUBDIVISION Graham Heights Lot No. 6 Block No. 17

Map Book No. 4 Page No. 370-371

18) DEED REFERENCE — DEED BOOK 2354 AT PAGE 423

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES * ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) NA

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

8-17-82
DATE OF APPLICATION

OWNER

EHD-5-76

Date Issued 9-2-82

Serial No. 5712


ICAR(S) Permit No. 18973

T. C. No. 085-054-32

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18973, dated 8-17-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 9-16-82, after which date this permit shall be null and void.



PLOT OF SYSTEM

REPAIR

Permeability Rate _____

Liquid Capacity of Tank _____

Tank Construction _____

Absorption and/or Nitrification Lines:

Total Line Length 300'

Number of Lines 3

Distance from House > 5'

Distance from Property Line > 5'

Distance from Well _____

NAME OF OWNER Moore, Floyd

LOCATION OF PROPERTY 3000 Dogwood Avenue

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Repair broken pipe under house. Rebuild septic tank where broken. Run schedule 40 pipe past the area where the drainfield was dug up and install a drainfield 9' wide x 50' long x 6" of sand + 34" of stone.

Division or Section Head

Mike Sexton
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76 Grade to drain all surface water.

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY