Date Received

MECK COUNTY DEPARTMENT OF
RECEIVED
JUN 3 6 19[illegible]
ENVIRONMENTAL HEALTH

APT No. 15870
T. C. No 93-068-02
Map Date 4/14/77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER J. W. Huntley Const Co Inc
LAST FIRST MIDDLE

2) ADDRESS OF OWNER P.O. Box 25242 Charlotte N.C. ZIP 28212

3) PHONE NO Home 536-6446 Office same


4) LOCATION OF PROPERTY Olde Creek Trail off Margaret Wallace Rd
STREET OR COUNTY ROAD

5) SUBDIVISION Olde Creek LOT NO 2 BLOCK NO. F

MAP BOOK NO 14 PAGE NO 181

6) DEED REFERENCE DEED BOOK 2506 PAGE NO 126

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on-site inspection of the lot described below for the purpose of determining the site's suitability for installation of an individual subsurface sewage disposal system with subsurface soil absorption effluent discharge.



There is a brick at the halfway mark on the lot line we would prefer to build but we can locate somewhere else.

7) ACCURATELY DIAGRAM & DIMENSION LOT

Wayne Huntley
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

15870
193-068-02

(Ground Absorption Sewage Disposal)

OWNER: F.N. HUNTLEY const. CO DATE REQUESTED: 6-7-79
ADDRESS: PO Box 25241 PLAT NO.:
COUNTY: Meck. 28212 LOT SIZE: 32,400
LOCATION OF SITE: Olde Creek Trail Lot 2 - Block F

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-30 U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS Saprolite U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS Massive U	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS >48 U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S PS Rock U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S PS slow U	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS slow U	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable			
SOIL SERIES	Wilkes			

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: W.B. Ramsey
Title: Soil Scientist Date: 7-12-79

DHS Form 2601 (2/77)
Sanitation

3


150
Wilkes
2-30
2-10
Wilkes
2-30
Wilkes
249
Wilkes
2-20
133
Old Creek Trail

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR. NO. 15870
T.C. NO. 193-068-02
MAP DATE 1/14/77
DATE 7/13/79

NAME OF OWNER F. W. Huntley Construction Company, Inc.

ADDRESS OF OWNER PO Box 25242 Charlotte, NC 28212

LOCATION OF LOT Olde Creek Trail off Margaret Wallace Road Lot 2 Block F

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Soil Structure Massive
Soil Permeability Unsuitable

John R. Adkisson, Environmentalist

R