SEE INSTRUCTIONS ON BACK

Date Received 6/7/77

ICAR(S) Application No. 1240

T C No. 141-161-05


Map Date 4-27-73

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to build new home

1) ___ Install or Construct 2) X Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home Yes ___ No

4) Proposed Bedrooms 4

5) Existing Use Vacant

Existing ___

6) Water Supply Yes ___ No

7) Public Sewer Yes ___ No

8) Connection Yes ___ No

9) Water Supply

A Individual Well ✓

B Governments System ___

C Community System

Well Source ___

2 Governments source ___

10) Sewage System

Property approximately 200 feet of public sewer Yes ___ No

House located within 200 feet of community sewer Yes ___ No

11) EHA Case No. ___

12) LA Case No. ___

13) NAME OF OWNER WOODARD (LAST) EDWARD (FIRST) H. (MIDDLE)

14) ADDRESS OF OWNER 7644 DIXIE BEACH RD.

15) PHONE NO Home NONE Office NONE

16) LOCATION OF SYSTEM 7644 DIXIE BEACH RD (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No ___ Block No ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 2190 AT PAGE 454

19) HAS A SOIL INVESTIGATION BEEN RUN? YES ✓ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

6-3-77
DATE OF APPLICATION

Edward Hazelton Woodard
OWNER

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

DATE ISSUED
1. 6/7/77
2. _____
3. _____

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR NO. 12540
T.C. NO. 141-161-05
M.P DATE 4-27-75

NAME OF OWNER: Woodard, Edward H.

ADDRESS OF OWNER: 7044 Dixie Rivef Road

LOCATION OF LOT: 7044 Dixie River Road

The lot described above is not recommended for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

Insufficient lot size

Recommend an area of at least 20,000 sqyare feet.

John R. Adkisson

John R. Adkisson, Environmentalist
Of Premises Waste Disposal Section

JRA:jjk

(Stencil No.)
BHL 389
6/7-

PSP" NO.
T-1[illegible]-8-21-7-