SEE INSTRUCTIONS ON BACK

Date Received 23 Mar 83

ICAR(S) Application No. 19481

T. C. No. 059-171-01


Map Date 15 Nov 82

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ✓ No
Residence ✓ Yes ___ No
4) No. of Bedrooms 4
5) Business Use — Max No Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System:
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No ___
12) VA Case No. ___

13) NAME OF OWNER GARDNER (LAST) Jimmy (FIRST) WAYNE (MIDDLE)

14) ADDRESS OF OWNER (Was 401) 2810 DALEVIEW DR. CHARLOTTE, N.C. 28214

15) PHONE NO. Home 392-5037 Office 1-800-822-9860

16) LOCATION OF SYSTEM Dana (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

3/23/83
DATE OF APPLICATION

Jimmy Wayne Gardner
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 3-28-83

Serial No. 6142


ICAR(S) Permit No. 19481

T. C. No. 059-171-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19481, dated 3-23-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 4-20-83, after which date this permit shall be null and void.



PLOT OF SYSTEM

REPAIR

Permeability Rate

Liquid Capacity of Tank

Tank Construction

Absorption and or Nitrification Lines

Total Line Length 100'

Number of Lines 2

Distance from House > 10'

Distance from Property Line > 10'

Distance from Well > 50'

NAME OF OWNER Gardner, Jimmy Wayne

LOCATION OF PROPERTY 2810 Dalevieu Drive

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Install two drainfield repairs - each 3'wide x 17'long x 53" of stone

Comments: keep > 6' between the drainfields

Division or Section Head

Mike Sexton
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-74 Flush 2 lbs. copper sulfate annually to deter the growth of tree roots from the gum tree.

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY