Date Rec'd 8-17-82

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 17 1982
ENVIRONMENTAL HEALTH

SIR No. 18933
T. C. No. 047-032-13
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Jordan (LAST) Clarence (FIRST) A (MIDDLE)

2) ADDRESS OF OWNER 3150 South Decatur Blvd. #146, Las Vegas, Nevada ZIP 89102

3) PHONE NO. Home 702/873-7195 Office


4) LOCATION OF PROPERTY Mineral Springs Road #2500 (STREET OR COUNTY ROAD)

5) SUBDIVISION None LOT NO. PARCEL A BLOCK NO.

MAP BOOK NO. PAGE NO.

6) DEED REFERENCE DEED BOOK 866 PAGE NO. 152

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

X M R Jordan
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 4672

PTR No. 18933

Date Issued 8-30-82

T. C. No. PO 047-032-13

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Jordan, (LAST) Clarence (FIRST) #146 A. (MIDDLE)

ADDRESS OF OWNER [redacted] 3150 S. Decatur Blvd., Las Vegas, Nevada ZIP 89102

LOCATION OF PROPERTY Mineral Springs Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO Parcel A BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate attained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling or construction, including the drilling of wells, performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William G. Mauldin
Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 11123

T.C. NO. PC 047-03273

(Ground Absorption Sewage Disposal)

OWNER: Clarence A. Jordan
ADDRESS: 3150 South Decatur Blvd #146 Las Vegas, Nev. 89102
LOCATION OF SITE: Mineral Springs Rd

PLAT NO: Lot A
LOT SIZE: Approx 59,000 sq ft

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-8%	S PS (U) Complex Slopes	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 clay)	S (PS) U clay	S (PS) U clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	(S) PS U 48"	S PS (U) Depth Variable	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	(S) PS U None	(S) PS U None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) PS U >6' To Ground Water	S PS (U) Eroded Areas Channel Water	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA	IVA		
9. SITE CLASSIFICATION	Provisionally suitable	unsuitable		
10. SOIL SERIES	Cecil	Complex Slopes		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Point between lots B & C used as a reference point - No house site Marked

Described by: William A. Martin
Title:

Date: 8-27-82

EHD 539 (Revised: 6/82)


Complex Slopes
200'
25'
25'
Creek
200'
B
C
Distances Approximate
Mineral Springs Rd