Date Received 3-1-84

SIR No. 20675

T. C. No. 231-111-04

Map Date 8/83

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Providence Woods, Inc. (LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 7140 E. Independence Blvd. Charlotte, NC 28205 (ZIP)

3) PHONE NO Home — Office 704-372-2565

4) LOCATION OF PROPERTY Amanda Dr. (STREET OR COUNTY ROAD)

5) SUBDIVISION Providence Woods LOT NO — / — BLOCK NO II

MAP BOOK NO — PAGE NO —

6) DEED REFERENCE DEED BOOK 4571 PAGE NO 693-694

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

Plan see attached map

7) ACCURATELY DIAGRAM & DIMENSION LOT

T. P. Newman
OWNER Agent

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20695

T.C. NO. PO 231-11-84

(Ground Absorption Sewage Disposal)

OWNER: [illegible]
ADDRESS: [illegible] Charlotte, N.C. 28205
PLAT NO: 11 BV
LOT SIZE: [illegible]
LOCATION OF SITE: [illegible]

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S 6-15% PS U	S 2-8% PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S Clay PS U	S Clay PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S Blocky PS U	S Blocky PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S 30-40" PS U	S 30-40" PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S >36" PS U	S >36" PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S >40" to ground water PS U	S Drainageway Depression PS U	S PS U	S PS U
7. OTHER (Specify)	S Somewhat Limited Area PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA	IVA		
9. SITE CLASSIFICATION	provisionally suitable	unsuitable		
10. SOIL SERIES	Cecil Like	Drainageway Depression		

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: System may require lift station
Recommend plans for house, well & system location be submitted

Described by: William A. Martin
Title: Soil Scientist

Date: 4-27-84

14


Approx 140'
Complex slopes
355'
Approx 120'
326'
Drainageway Depression
508
144'
Amanda

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20675
T.C. NO. PO 231-111-04
DATE: 5-1-84

Providence Woods, Inc.
1740 E. Independence Boulevard
Charlotte, NC 28205

RE: Property located at Amanda Drive, Lot 1, Blk. 5

Dear Sirs:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure