

10419 WILDLIFE RD

19960117

1/8/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

c APP 623300

FEE: 100
DATE: 8/2/07
CRT [ ]

APPLICATION FOR APPROVAL TO USE AN EXISTING ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM
MECKLENBURG COUNTY - GROUNDWATER & WASTEWATER SERVICES
700 N. Tryon St., Suite 211 Charlotte, NC 28202
Phone: (704) 336-5103 Fax: (704) 336-6894

GWS – UES.APP 06/07

FILE #: 5690B

TYPE APPLCATION: ID# 2569

- ☐ ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A / M)
- ☑ ADDITION - RENOVATION OR GARAGE WITH NO MAJOR CHANGES (X)
- ☐ EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
- ☐ COMMERCIAL OR INDUSTRIAL (N)

PERSON FILING APPLICATION: PH# 24576

NAME: EARL COULSTON
ADDRESS: 10419 WILDLIFE R
CITY: CHARLOTTE
STATE: ZIP:
PHONE: 704-507-2175 CONTACT PERSON 704-201-4803
ALTERNATE PHONE:

PROPERTY OWNER: CS VO

NAME:
ADDRESS:
CITY:
STATE: ZIP:
PHONE:
ALTERNATE PHONE:

JOB LOCATION INFORMATION

TAX/PARCEL #: 199-601-17
STREET ADDRESS: ~~10419~~ 10419
CITY: CHARLOTTE WILDLIFE
STATE: NC ZIP: 28270
SUBDIVISION OR MOBILE HOME PARK NAME:
LOT #: 34

TOWNSHIP:

- ☑ 0-MECKLENBURG
- ☐ 1-CHARLOTTE
- ☐ 2-DAVIDSON
- ☐ 3-CORNELIUS
- ☐ 4-PINEVILLE
- ☐ 5-MATTHEWS
- ☐ 6-HUNTERSVILLE
- ☐ 7-MINT HILL

WATER SUPPLY:

- ☑ MUNICIPAL (M)
- ☐ COMMUNITY (C)
- ☐ PRIVATE WELL (P)
- ☐ SHARED WELL (S)
- ☐ OTHER 'SPRINGS' (O)

RESIDENTIAL PROPERTY TYPE:

- ☑ HOUSE (H)
- ☐ MODULAR HOME (M)
- ☐ MULTIPLE FAMILY (U)
- ☐ SINGLE MOBILE HOME (S)
- ☐ DOUBLE WIDE (D)
- ☐ OTHER (O)

Addition

OCCUPANCY (both fields are required):

NUMBER OF BEDROOMS: 5
NUMBER OF OCCUPANTS: 7

COMMERCIAL / INDUSTRIAL PROPERTY TYPE:

TYPE OF BUSINESS:
EMPLOYEES PER SHIFT:
OF SHIFTS:

INDUSTRIAL WASTES? ☐ YES ☐ NO
UNDERGROUND STORAGE TANKS? ☐ YES ☐ NO

ADDITION TYPE ATTACHED TO EXISTING STRUCTURE:

- ☐ BEDROOM
- ☐ BATHROOM
- ☐ KITCHEN
- ☐ DINING ROOM
- ☐ LIVING ROOM
- ☐ DEN
- ☐ GARAGE
- ☐ SUNROOM
- ☑ PORCH
- ☐ DECK
- ☑ OTHER EXCERISE ROOM

ADDITION TYPE DETACHED FROM EXISTING STRUCTURE:

- ☐ DETACHED GARAGE
- ☐ DETACHED GARAGE WITH PLUMBING
- ☐ POOL HOUSE
- ☐ SHOP
- ☐ BARN
- ☐ STORAGE SHED
- ☐ DETACHED PORCH / DECK
- ☐ OTHER

ATTACHED

*The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

Owner's/Agent's Signature — Date: 8/2 07

*The undersigned, an authorized agent of the Mecklenburg County Health Department, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules for Sanitary Sewage Collection, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an installation, construction, alteration and/or repair approval is granted y this Department.
- This permit is not transferable.

☐ ADDITION / RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE
☐ MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE

OK TO USE EXISTING SYSTEM.


EHS Signature — Date: 8/8/07

Mecklenburg County
Land Use & Environmental Service Agency
Groundwater & Wastewater Services
700 N. Tryon St., Suite 211
Charlotte, NC 28202
Phone: (704) 336-5103
Fax: (704) 336-6894

File #_____
Date_____

PROPOSED PLOT PLAN

A map showing existing and proposed property lines and easements with dimensions, the location of the single family residence, non-single family residence, or other facility, and appurtenances, the site for the proposed well, and the location of existing or proposed sewer lines and/or sewage disposal systems, surface water bodies, aboveground or underground storage tanks. Name all roads adjoining the property. If this a repair indicate the type of repair.



← DRAINFIELD AT OPPOSITE SIDE OF HOUSE

Owner/Agent Signature

Date 08/21/07

LBC 12/15/04

FEE
DATE
CRT [illegible] X010230 V.W.

APPLICATION FOR APPROVAL TO USE AN EXISTING ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM
MECKLENBURG COUNTY - GROUNDWATER & WASTEWATER SERVICES
700 N. Tryon St., Suite 211 Charlotte, NC 28202
Phone: (704) 336-5103 Fax: (704) 336-6894

GWS – UES.APP 01/05

FILE # 5690B

#604 Project 172997

TYPE APPLCATION:

- [X] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A / M)
- [ ] ADDITION - RENOVATION OR GARAGE WITH NO MAJOR CHANGES (X)
- [ ] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
- [ ] COMMERCIAL OR INDUSTRIAL (N)

PERSON FILING APPLICATION:
NAME: Harold Weatherman CFRAS/First Group #255
ADDRESS: 1727 - 8A Sardis Rd North
CITY: Charlotte, NC
STATE: NC ZIP: 28270
PHONE:
ALTERNATE PHONE:

PROPERTY OWNER:
NAME:
ADDRESS:
CITY:
STATE: ZIP:
PHONE:
ALTERNATE PHONE:

JOB LOCATION INFORMATION
TAX/PARCEL #: 199-601-17
STREET ADDRESS: 10419 Wildlife Rd
CITY: Charlotte, NC
STATE: ZIP:
SUBDIVISION OR MOBILE HOME PARK NAME: Sanctuary!
LOT #: #34

TOWNSHIP:

- [ ] 0-MECKLENBURG
- [ ] 1-CHARLOTTE
- [ ] 2-DAVIDSON
- [ ] 3-CORNELIUS
- [ ] 4-PINEVILLE
- [ ] 5-MATTHEWS
- [ ] 6-HUNTERSVILLE
- [ ] 7-MINT HILL

WATER SUPPLY:

- [X] MUNICIPAL (M)
- [ ] COMMUNITY (C)
- [ ] PRIVATE WELL (P)
- [ ] SHARED WELL (S)
- [ ] OTHER 'SPRINGS' (O)

RESIDENTIAL PROPERTY TYPE:

- [X] HOUSE (H)
- [ ] MODULAR HOME (M)
- [ ] MULTIPLE FAMILY (U)
- [ ] SINGLE MOBILE HOME (S)
- [ ] DOUBLE WIDE (D)
- [ ] OTHER (O)

NUMBER OF BEDROOMS: 5 UNKNOWN
NUMBER OF OCCUPANTS:

COMMERCIAL / INDUSTRIAL PROPERTY TYPE:
TYPE OF BUSINESS:
EMPLOYEES PER SHIFT:
OF SHIFTS:
INDUSTRIAL WASTES? [ ] YES [ ] NO
UNDERGROUND STORAGE TANKS? [ ] YES [ ] NO

ADDITION TYPE ATTACHED TO EXISTING STRUCTURE:

- [ ] BEDROOM
- [ ] BATHROOM
- [ ] KITCHEN
- [ ] DINING ROOM
- [ ] LIVING ROOM
- [ ] DEN
- [ ] GARAGE
- [ ] SUNROOM
- [ ] PORCH
- [ ] DECK
- [ ] OTHER

ADDITION TYPE DETACHED FROM EXISTING STRUCTURE:

- [ ] DETACHED GARAGE
- [ ] DETACHED GARAGE WITH PLUMBING
- [X] POOL HOUSE
- [ ] SHOP
- [ ] BARN
- [ ] STORAGE SHED
- [ ] DETACHED PORCH / DECK
- [ ] OTHER

*The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

Owner's/Agent's Signature — Date: 3-28-06

*The undersigned, an authorized agent of the Mecklenburg County Health Department, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules for Sanitary Sewage Collection, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an installation, construction, alteration and/or repair approval is granted y this Department.
- This permit is not transferable.

- [ ] ADDITION / RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE
- [ ] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE

Pool house OK. Not over top Septic System

EHS Signature — Date: 3/30/06


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5103

FILE: 56908

TC: 199-601-17

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

OWNER/AGENT SIGNATURE

DATE

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

Change in Plot Plan

GWS – RES. APP 07/05

SEPTIC FEE: 100.00
DATE:
CRT #:

PERMIT APPLICATION FOR A RESIDENTIAL SITE IMPROVEMENT PERMIT / CONSTRUCTION AUTHORIZATION FOR ON-SITE WASTEWATER SYSTEM NEW WELL INSTALLATION OR REPAIR OF EXISTING WELL MECKLENBURG COUNTY GROUNDWATER & WASTEWATER SERVICES

WELL FEE:
DATE:
CRT #:

FILE # MCHD File #5690B

SEPTIC / TYPE APPLICATION: ☐ NONE ☒ NEW SYSTEM ☐ ALTERATION ☐ REPAIR ☐ MODIFY PLOT PLAN

WELL / TYPE APPLICATION: ☒ NONE ☐ NEW WELL ☐ MAJOR REPAIR ☐ ABANDONMENT

JOB LOCATION INFORMATION:

TAX/PARCEL #: 199-371-03
STREET ADDRESS: Lot #34 Wildlife Rd.
CITY: 10419 Wildlife Rd
STATE: NC ZIP:
SUBDIVISION OR MOBILE HOME PARK NAME: Sanctuary
LOT #: 34 Phase 2 map 2 Steele Creek
TOWNSHIP: Steele Creek TWSP

☒ 0-MECKLENBURG ☐ 4-PINEVILLE
☐ 1-CHARLOTTE ☐ 5-MATTHEWS
☐ 2-DAVIDSON ☐ 6-HUNTERSVILLE
☐ 3-CORNELIUS ☐ 7-MINT HILL

BUILDING INFORMATION:

TYPE OF BUILDING:
☐ SINGLE MOBILE HOME (S) ☐ MODULAR HOME (M)
☐ DOUBLE WIDE (D) ☐ MULTIPLE FAMILY (U)
☒ HOUSE (H) ☐ OTHER
HEATED SQUARE FOOTAGE: 8900 SF
NUMBER OF BEDROOMS: 5
NUMBER OF OCCUPANTS:

FOUNDATION FOR RESIDENCE:
☐ CONCRETE SLAB ☐ BASEMENT WITH PLUMBING
☒ CRAWLSPACE ☐ BASEMENT WITH NO PLUMBING

IF PLANNING TO EXPAND/ALTER THE EXISTING SYSTEM INDICATE THE FOLLOWING CHANGES:
NUMBER OF BEDROOMS TO BE ADDED: NUMBER OF ADDITIONAL OCCUPANTS IN THE RESIDENCE:
WILL THERE BE A HOME BUSINESS IN THE RESIDENCE? ☐ YES ☐ NO TYPE:

WATER SUPPLY:

☐ MUNICIPAL (M) ☒ PUBLIC (C) ☐ PRIVATE WELL (P) ☐ SHARED WELL (S) ☐ OTHER 'SPRINGS' (O)

PROPOSED USE OF WELL: ☐ N/A ☐ IRRIGATION ☐ POTABLE ☐ GEOTHERMAL ☐ OTHER

ARE ANY OF THE FOLLOWING LOCATED ON THE PROPERTY? IF SO, PLEASE SHOW LOCATION ON SITE PLAN/PLAT.

BURIED CABLES, LANDFILLS, STUMPHOLES ☐ YES ☒ NO
EXISTING WASTEWATER SYSTEMS ☐ YES ☒ NO
EASEMENTS OR RIGHT-OF-WAYS ☐ YES ☒ NO
WELLS, SPRINGS, OR WATER LINES ☐ YES ☒ NO
DESIGNATED WETLANDS ☐ YES ☒ NO
GRADING/SOIL REMOVAL PERFORMED ☐ YES ☒ NO

PROPERTY OWNER:

NAME: Cyrus Homes, Inc
ADDRESS: 1727-8A, Sandi Rd N. #255
CITY: Charlotte NC 28270
STATE: ZIP:
HOME PHONE: WORK PHONE: 704-295-1200
MOBILE PHONE: 704-634-1263 FAX: 704-295-1201

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: Pavan Kumar
ADDRESS:
CITY: Same as Lit. S.
STATE: ZIP:
HOME PHONE: WORK PHONE:
MOBILE PHONE: FAX:

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED?

WHAT IS THE ANTICIPATED CLOSING DATE FOR THIS PROPERTY?

"An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

P. Kumar 8-16-05
Owner's/Agent's Signature Date

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENT & NATURAL RESOURCES DIVISION
OF ENVIRONMENTAL HEALTH ON-SITE
WASTEWATER SECTION

"A Well Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

P. Kumar 8-16-05
Owner's/Agent's Signature Date

MECKLENBURG COUNTY HEALTH DEPARTMENT
GROUNDWATER & WASTEWATER SERVICES
700 N. TRYON ST., SUITE 211
CHARLOTTE, NC 28202 704-336-5103 / FAX: 704-336-5894

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5103

FILE: 5690B DATE: 1/23/06

TC: 199-371-03 ☐ L

SERIAL Nº 20487

Permission is hereby given to _____ (Install) or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 1/23/06. All work shall be completed on or before 1/23/06, after which date this permit shall be null and void. The system shall meet all of the construction requirements of I5A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

See Operation Permit
(2)

PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank N/A gallons

Tank Construction PCC

Trench Depth 24-30"

Absorption and/or Nitrification Lines:

Trench Width 3' feet

Trench Walls Scored and Porous yes

Total Line Length 500 feet

Number of Lines 4

Depth of Stone N/A inches

Distance from House 75 feet

Distance from Property Line 710' feet

Distance from Well N/A feet

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER Cyrus Homes

LOCATION OF PROPERTY Old Camp Trail Lot 34 Sanctuary

Comments: Installation of 25% Reduction System w/ Gravity feed.
Installation of French Drain Around Septic system

Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 56908 DATE: 1/23/06

TC: 199-~~37-03~~ 601-17 ☐ L ☐ CRT

SERIAL 19929

Name of Owner Cyras Homes Juris.: Lake Wylie

Address of Property Wildlife Rd Sanctuary Lot 34

Inspection Data:

Tank Material PCC

Total Length of Drainfield 500'

Number of Lines 5 @ 100'

Cover Depth 12"

Water Supply Source Municiple


Distance to Water Source >50'

Excavation Inspected (Ed) 1/23/06

Tank(s) Inspected 1/23/06

Wash Line Inspected N/A

High Water Alarm Inspected N/A



PLOT

Design Gravity fed 25% Reduction System #2 Flow w 150 gal PCC Tanks Dosing Tank ETR# Stanley

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 15A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Also needed is French Drain around septic system for surface water collection to not be allowed over system.

Jack J. Potter EHS/RS

Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

EE: Credit for 3/24 overpmt

ATE: 8/13/04

APPLICATION FOR IMPROVEMENT PERMIT
FOR RESIDENTIAL SITE
INDIVIDUAL WATER AND WASTEWATER
SYSTEMS PROGRAM

[ ] CRT

YPE APPLICATION: [X] NEW SYSTEM [ ] EXPANSION/ ALTERATION OF EXISTING SYSTEM [ ] REPAIR OF EXISTING SYSTEM

NORTH CAROLINA
DEPARTMENT OF ENVIRONMENT,
HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

FILE #: 5690B

PROPERTY INFORMATION (FROM ENGINEERING FORM) FOR JOB LOCATION:

TAX/PARCEL NUMBER: 199-371-03 PO

STREET ADDRESS:

SUBDIVISION OR MOBILE HOME PARK NAME: The Sanctuary At Lake Wylie, LLC

LOT NUMBER: ~~32~~ 34

TYPE OF BUILDING (CHECK ONE):

- [ ] SINGLE MOBILE HOME(S)
- [ ] DOUBLE WIDE (D)
- [X] HOUSE (H)
- [ ] MODULAR HOME (M)
- [ ] MULTIPLE FAMILY (U)
- [ ] OTHER (O)

TOWNSHIP (CHECK ONE):

- [✓] 0 MECKLENBURG
- [ ] 1 CHARLOTTE
- [ ] 2 DAVIDSON
- [ ] 3 CORNELIUS
- [ ] 4 PINEVILLE
- [ ] 5 MATTHEWS
- [ ] 6 HUNTERSVILLE
- [ ] 7 MINT HILL

HEATED SQUARE FOOTAGE:

NUMBER OF BEDROOMS:

NUMBER OF OCCUPANTS:

CLOSING DATE

FOUNDATION FOR RESIDENCE:

- [ ] WITHOUT BASEMENT
- [ ] ON SLAB
- [ ] CRAWL SPACE
- [X] WITH BASEMENT /PLUMBING
- [ ] WITH BASEMENT /NO PLUMBING

IF EXPANSION/ALTERATION OF EXISTING SYSTEM, DESCRIBE THE PROPOSED BUILDING ADDITION:

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE: [ ] YES [✓] NO TYPE:

WATER SUPPLY (CHECK ONE):

- [ ] COMMUNITY (C)
- [ ] SHARED WELL (S)
- [✓] MUNICIPAL (M)
- [ ] OTHER 'SPRINGS' (O)
- [ ] PRIVATE WELL (P)

IF ANY OF THE FOLLOWING ARE LOCATED ON THE PROPERTY, PLEASE SHOW LOCATION ON PLAT:

BURIED CABLES, LANDFILLS, STUMPHOLES	[ ] YES [✓] NO	WELL, SPRINGS OR WATERLINES	[ ] YES [✓] NO
EXISTING WASTEWATER SYSTEMS	[ ] YES [✓] NO	DESIGNATED WETLANDS	[ ] YES [✓] NO
EASTMENTS OR RIGHT-OF-WAYS	[✓] YES [ ] NO		

PROPERTY OWNER:

NAME: (LAST) The Sanctuary At Lake Wylie, LLC (FIRST) (MI)

ADDRESS: 10933 Ballantyne Crossing Ave

CITY: Charlotte STATE: NC ZIP: 28277

DAYTIME PHONE: (704) 544-0201 ext 226

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: (LAST) Jacobs (FIRST) Tony (MI) C

DAYTIME PHONE: 704 563-6905

m 704 582 9219

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED?

An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

SIGNED: Tony C Jacobs, CPSS (Agent) DATE: 8-13-04

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR., SUITE 211, 700 N. TRYON ST., CHARLOTTE, N.C. 28202., (704) 336-5102

TONEY C. JACOBS & ASSOCIATES, INC.

Consulting Soil Scientists

Licensed by the North Carolina Board for Licensing of Soil Scientists

Certified by the American Registry of Certified Professionals in Agronomy, Crops and Soils

168 Broadbill Drive
Mooresville, NC 28117
Phone (704) 663-6905
Fax (704) 662-9845 E-mail jacobs@i-america.net

January 24, 2005

To: Mr. David Cornelius, R.S.
Mecklenburg County Env. Health Dept.

From : Toney C. Jacobs
Paul G. Penninger

RE: Request for an Improvement Permit for lot 34 at The Sanctuary:
MCHD file # 5690B

Crescent Resources is requesting an Improvement Permit for lot **34** at The Sanctuary Subdivision for a **5** bedroom, basement home. Mr. Bill Marlin of the MCHD evaluated the soils on 10-04-04 and determined the septic area is PS at an 0.3 gpd/ft^2 LTAR. Toney C. Jacobs and Associates, Inc. has flagged a 25% reduction septic system and PPBPS repair on the lot, as shown on the attached sketch.

We understand a building permit cannot be issued until your office issues an Authorization to Construct (ATC). The buyer of the lot will apply for the ATC. If the buyer's house pad does not fit in the "building envelope" shown on the Improvement Permit, we understand the proposed system may have to be modified prior to your office issuing the ATC. **No grading shall take place on lot prior to obtaining the ATC from the MCHD.**

Tri-County Wastewater (TCWW) is under contract to supply maintenance services for each septic system installed at The Sanctuary. TCWW will have a list of preferred septic contractors for the subdivision and will also have requirements for the installation of the septic systems that are greater that the state requirements. It will be the responsibility of TCWW to enforce any requirements above state requirements or the conditions on the Improvement Permit or ATC.

Please review the attached system sketch and design specifications for the Improvement Permit. Please call if you have and questions, comments, or corrections.

Design Specifications for Lot 34 at

The Sanctuary, MCHD File # 5690B

System Type:	primary: repair:	pressure manifold , 25% reduction LP PPBPS
Daily design flow:		600 gpd
Septic tank size:		1500 gal. (2 compartments)
Pumping tank size:		1500 gal.
Effluent loading rate:		0.3 gpd/ft^2 for primary and repair
Number and length of laterals:		4@ 90 ft. and 2 @ 70 ft. for a total of 500 ft. of 25% reduction trench
Flow rate through the system:		27.5 gpm –use five, ½ in. SCH 80 taps with 2 ft. head pressure on pressure manifold (5.5 gpm per tap)
Pump requirements:		to be calculated by installer or owners agent when specific house and pump tank location are available
Dosing volume:		approx. 270 gal. – 2.2 doses/day at design flow
Depth of water pumped per dose:		calculated to specific tank by measure or dealer engineering specifications (1 cubic ft. of water equals 7.48 gal.)
Check valve:		YES
Siphon break hole:		No

Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 of 3
Property ID: PO 199-371-03
Lot #: 34
File #: 5690B ACS
Code: 1

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: The Sanctuary at Lake Wylie
Applicant: Toney Jacobs
Address: 10933 Ballantyne Crossing Ave., Charlotte, N. C. 28277
Date Evaluated: 10/4/2004
Proposed Facility: Residence
Design Flow (.1949): 600gpd
Property Size: Approx 1.0a inv.
Location of Site: Old Camp Trail
Property Recorded:
Water Supply: [x] Public [ ] Individual [ ] Well [ ] Spring [ ] Other
Evaluation Method: [x] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [x] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941 1941 Structure/ Texture	1941 Consistence Mineralogy	OTHER PROFILE FACTORS 1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	Profile Class & LTAR
1	R, 6	0-6	DISTURBED		>48" TO SOIL WETNESS	48+	N/A	NONE	PS, IV
		6-48	SBK/ABK/C	FI/SEXP/S/P					.25GPD/FT^2
2	"	0-6	GR/CL	FR/SEXP/SS/SP	>49" TO SOIL WETNESS	49+	"	"	PS, IV
		6-49	SBK/C	FI/SEXP/S/P					.275GPD/FT^2
3	"	0-5	GR/CL	FR/SEXP/SS/SP	>48" TO SOIL WETNESS	48+	"	"	"
		5-48	SBK/C	FI/SEXP/S/P					
4	LS, 10	0-4	GR/CL	FR/SEXP/SS/SP	"	"	"	"	"
		4-48	SBK/C	FI/SEXP/S/P					
5	"	0-5	GR/CL	FR/SEXP/SS/SP	>51" TO SOIL WETNESS	51+	"	"	PS, IV
		5-37	SBK/C	FI/SEXP/S/P					.3GPD/FT^2
		37-51	SBK/CL	FR/SEXP/SS/SP					
A	"	0-3	GR/CL	"	>50" TO SOIL WETNESS	50+	"	"	"
		3-50	SBK/C	FI/SEXP/S/P					
B	"	0-3	GR/CL	FR/SEXP/SS/SP	>46" TO SOIL WETNESS	46+	"	"	"
		3-46	SBK/C	FI/SEXP/S/P					
		BORING TERMINATED@		46"FLOATER ROCK					
C	"	0-4	GR/CL	FR/SEXP/SS/SP	>36" TO SOIL WETNESS	36+	"	"	"
		4-36	SBK/C	FI/SEXP/S/P					
		BORING TERMINATED@		36" FLOATER ROCK					

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)		
Site LTAR	.3GPD/FT^2	.275GPD/FT^2

Other Factors (.1946):
Site Classification (.1948): PROVISIONALLY SUITABLE
Evaluated By: W. R. Marlin, LSS, 10/6/2004, W R Marlin
Others Present:

Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 2 of 3
File #: 5690B

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
CONTINUED


PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr. Horiz.	
D	LS, 8	0-4	GR/CL	FR/SEXP/SS/SP	>50" TO SOIL WETNESS	50+	N/A	NONE	PS, IV .3GPD/FT^2
		4-50	SBK/C	FI/SEXP/S/P					
E	"	0-3	GR/CL	FR/SEXP/SS/SP	>48" TO SOIL WETNESS	48+	"	"	"
		3-48	SBK/C	FI/SEXP/S/P					

COMMENTS:
100% repair

Landscape Position	Group	Texture	.1955 LTAR	Structure
R-Ridge	I	S-Sand	1.2 - 0.8	SG-Single Grain
SS-Shoulder Slope		LS-Loamy Sand		M-Massive
LS-Linear Slope				CR-Crumb
FS-Food Slope	II	SL-Sandy Loam	0.8 - 0.6	GR-Granular
NS-Nose Slope		L-Loam		SBK-Subangular Blocky
HS-Head Slope				ABK-Angular Blocky
CC-Concave Slope	III	SI-Silt	0.6 - 0.3	PL-Platy
CV-Convex Slope		SICL-Silty Clay Loam		PR-Prismatic
T-Terrace		CL-Clay Loam		
FP-Flood Plain		SCL-Sandy Clay Loam		
	IV	SC-Sandy Clay	0.4 - 0.1	
		SIC-Silty Clay		
		C-Clay		

Consistence Moist	Consistence Wet	Mineralogy
VFR-Very Friable	NS-Non-Sticky	SEXP-Slightly Expansive
FR-Friable	SS-Slightly Sticky	EXP-Expansive
FI-Firm	S-Sticky	
VFI-Very Firm	VS-Very Sticky	
EFI-Extremely Firm	NP-Non-Plastic	
	SP-Slightly Plastic	
	P-Plastic	
	VP-Very Plastic	

Sketch of Soil Evaluation Locations



Permit Number: ~~3692B~~ 5690B

CONDITIONS OF IMPROVEMENT PERMIT

Tax Number: 199-371-03

- The IMPROVEMNET PERMIT is subject to revocation if site plans or the intended use change. There is to be **NO** grading, filling, or disturbance of the soil in the area of the septic tank system or repair area.
- CONSTRUCTION AUTHORIZATION must be obtained prior to receiving a Building Permit. The Construction Authorization is **NOT** transferable. Do not clear, grade, fill or disturb soil prior to obtaining a Construction Authorization.
- Domestic-type wastewater only. No industrial process wastewater may be discharged into the system.

Basement: ☒ Yes ☐ No ☐ Partial Basement

Primary Wastewater System

Type: ☐ I ☐ II ☒ III ☐ IV ☐ V ☐ VI

☐ Conventional
☐ Prefabricated, permeable block panel system
☐ Shallow Placed Conventional
☐ Low Pressure Pipe
☐ Large Diameter Pipe
☐ Fill
☐ Other
☒ Innovative or Experimental:

0.3 Long-term acceptance rate (GPD/ft^2)	600 Max gallons/day wastewater flow	1500 Absorption Area (ft^2)	9 Trench spacing (min. on centers) (ft)
Serviced by private well: ☐ Yes ☒ No	1500 Gallon septic tank	500 Total trench length (ft)	24 Maximum trench depth (in) (At least 12" of provisionally suitable soil must remain between trench bottom and unsuitable soil conditions.)
5 Bedrooms in residence	1500 Gallon pump tank	na Depth of stone (in)	

Any surface water present: **No** Type: Minimum separation distance (ft):

Additional conditions: **Install according to plans on file submitted by Toney Jacobs and Associates. Lot #34**

Repair Area System

Type: ☐ I ☐ II ☒ III ☐ IV ☐ V ☐ VI

☐ Conventional
☒ Prefabricated, permeable block panel system
☐ Shallow Placed Conventional
☒ Low Pressure Pipe
☐ Large Diameter Pipe
☐ Fill
☐ Other
☐ Innovative or Experimental:

1000 Absorption Area (ft^2) 342 Total trench length (ft)	na Depth of stone (in)	8 Trench spacing (min. on centers) (ft)	24 Maximum trench depth (in)

The undersigned, an authorized agent of the MECKLENBURG COUNTY HELTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. The approval is granted in accordance with the provisions of Laws and Rules For Sewage, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

*** No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair Approval is granted by this Department.

*** This Improvement permit is transferable.

3/15/05
DENR Authorized Agent Date

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR.
SUITE 211
700 N. TRYON ST.
CHARLOTTE, NC 28202
(704) 336-5103

3/15/05
Owner/Agent Signature Date

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENTAL, HEALTH, AND
NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

634-1263

FEE: _____
DATE: _____

AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION
VOID SIXTY (60) MONTHS FROM DATE OF ISSUANCE

ACS

PERMIT NUMBER: 5690B
PARCEL NUMBER: 199-371-03

JOB LOCATION ADDRESS: Old Camp Trail Lot #34
PROPERTY OWNER: Cyras Homes
BUILDING CONTRACTOR: Cyras Homes
SUBDIVISION NAME: The Sanctuary @ Lake Wylie
AUTHORIZATION ISSUED BY: David Cornelius, RS DATE: 08/16/05

David Cornelius, RS
DENR AUTHORIZED AGENT

AUTHORIZATION CONDITIONS

1. WASTEWATER SYSTEM CONSTRUCTION AND INSTALLATION MUST MEET ALL CONDITIONS AND SPECIFICATIONS AS SET FORTH IN IMPROVEMENT PERMIT NUMBER 5690B, AND THE ATTACHED SITE PLAN WITH SYSTEM DETAILS. CONSTRUCTION AND INSTALLATION MUST ALSO MEET ALL REQUIREMENTS SET FORTH IN THE RULES GOVERNING SANITARY SEWAGE COLLECTION, TREATMENT, AND DISPOSAL AND ANY OTHER APPLICABLE RULES AND LAWS.

2. AN INSTALLATION, CONSTRUCTION, ALTERATION AND/OR REPAIR APPROVAL MUST BE SECURED PRIOR TO INSTALLATION OF THE SEPTIC TANK SYSTEM. THE INSTALLER OF THE SYSTEM SHALL BE A REGISTERED SEPTIC TANK CONTRACTOR WITH THE MECKLENBURG COUNTY HEALTH DEPARTMENT.

3. ANY ALTERATION IN SITE OR SOIL CONDITIONS (INCLUDING LOCATION OF STRUCTURES AND APPURTENANCES) OR MODIFICATION IN USE, DESIGN WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS AS SPECIFIED IN THE ASSOCIATED IMPROVEMENT PERMIT AND APPLICATION, MAY SUBJECT THIS AUTHORIZATION AND ASSOCIATED PERMIT(S) TO REVOCATION.

4. OTHER CONDITIONS: Install according to plans on file submitted by Toney Jacobs and Associates
Change in plot plan approved and on file.

OWNER CERTIFICATION

I CERTIFY THAT THERE HAVE BEEN NO ALTERATIONS IN SITE OR SOIL CONDITIONS OR MODIFICATIONS TO FACILITY, WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS FROM THOSE SPECIFIED IN THE ORIGINAL APPLICATION OR ASSOCIATED IMPROVEMENT PERMIT UNLESS AUTHORIZED IN WRITING BY THE MECKLENBURG COUNTY HEALTH DEPARTMENT. I ALSO UNDERSTAND THAT ANY SUCH ALTERATIONS, MODIFICATIONS, OR FALSE INFORMATION ARE GROUNDS FOR REVOCATION OF PERMITSAND AUTHORIZATION TO CONSTRUCT.

_____ _____
SIGNATURE OF OWNER/OWNER'S REPRESENTATIVE DATE

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 56908 DATE: 1/23/06

TC: 199 ~~-391-03~~ 601-17 ☐ L ☐ CRT

SERIAL 19929

Name of Owner Cyres Homes Juris.: Lake Wylie

Address of Property Wildlife Rd Sanctnary Lot 34

Inspection Data:

Tank Material PCC

Total Length of Drainfield 500'

Number of Lines 5 @ 100'

Cover Depth 12"

Water Supply Source Municipl


Distance to Water Source >50'

Excavation Inspected (28) 1/23/06

Tank(s) Inspected 1/23/06

Wash Line Inspected N/A

High Water Alarm Inspected N/A



PLOT

Design Gravity fed 25% Reduction System #2 Flow w 150 Sol PCC Tank Datager Tank ETR# Stanley

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of I5A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of I5A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Also needed is French Drain around septic system for surface water collection to not be allowed over system.

Jack J. Potts E/H/S

Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Mecklenburg County Groundwater & Wastewater Services
700 N. Tryon St., Suite 211 Charlotte, NC 28202
Phone: (704) 336-5103 Fax: (704) 336-6894

NC DENR
Division of Environmental Health
On-Site Wastewater Section

OPERATION PERMIT for an ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM

File #: 5691B Permit #: 30013182 4051 Tax Parcel #: 19960118

Property Owner: Arcadia Homes Diamond Construction

Job Location Address: 13306 Withers Cove Rd lot 35

City: Charlotte State: NC Zip Code: 28278

Operation Permit Issuance Date: 6/16/09 Contractor Name: Larry Tucker

Permitted Design Flow: 600 GPD

Liquid Capacity of Septic Tank: 1500 gallons
Shaft Inst 1500 BTF353

Liquid Capacity of Dosing Tank: 1500 gallons

Effluent Pump Model: Myers MWH50-MW200
Shaft 1500 PT 353

Drainfield Installation ☐ N/A

Trench Depth: 36 inches

Trench Width: 3' feet

Line Spacing: 9' feet (O.C.)

Total line length: 600 feet

# of Lines: 6 @ 101' feet

Depth of Media: 12" inches (Type) Infiltrator -

Depth of Cover: 16" inches

Distribution Device: pressure manifold

Bed Installation *(For Repair Installations ONLY.)* ☒ N/A

Bed Depth: _____ inches

Bed Width: _____ feet

Total line length: _____ feet

# of Lines: _____ @ _____ feet

Depth of Media: _____ inches (Type) _____

Depth of Cover: _____ inches

Distribution Device: _____

Water Supply Source

☒ Municipal ☐ Private Well ☐ Community Well

☐ Other _____

System Installation Setbacks

Distance from Building Foundation: 25' feet

Distance from Property Line: 10' feet

Distance from Water Supply Source: 10' feet


Inspection Dates

Tank(s) Inspected: 6/10/09

Excavation Inspected: 6/10/09

Pump & Controls Inspected: 6/16/09

SKETCH OF SYSTEM INSTALLATION
(As-Built Drawing)



The undersigned has inspected the Septic Tank System described above, and certifies it has been ☒ installed ☐ altered ☐ repaired ☐ as detailed in the plot above ☐ in accordance with the permit issued and meets the provisions of 15A NCAC 18A. 1900, "Laws and Rules for Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. The issuance of this Operation Permit does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1900 in addition to those listed below under "Comments." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the Suspension or Revocation of this permit.

Comments: System Classification & Type: Type IIIb approved innovative System
Pump to pressure manifold to 6 laterals @ 100' length Changed → 304

DENR Authorized Agent: Jason Jackson Signature: Jason Jackson

Mecklenburg County Groundwater & Wastewater Services
700 N. Tryon St., Suite 211 Charlotte, NC 28202
Phone: (704) 336-5103 Fax: (704) 336-6894

NC DENR
Division of Environmental Health
On-Site Wastewater Section

INSTALLATION APPROVAL for an ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM

File #: 5691B Permit #: 2009 3152 4051 Tax Parcel #: 199-601-14

Property Owner: McCrackin Hayes Diamond Construction Sanctuary

Job Location Address: 13306 Withers Cove Rd lot 35

City: Charlotte State: NC Zip Code: 28278

Installation Approval Issuance Date: 6/8/09

Permission is hereby given to ☒ install ☐ alter ☐ repair an on-site wastewater treatment & and disposal system, with subsurface soil absorption and effluent discharge, as specified herein at the described location. This approval is granted based upon the application information submitted to our office. All work shall be completed on or before 6/8/09, after which date this approval shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of granting this approval. An **Operation Permit** must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now of hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

***NOTICE: This system shall not be installed while soils are in a wet condition.**

Permitted Design Flow: 600 GPD

Site LTAR: .25 GPD/ft² (For new installations only.)

Liquid Capacity of Septic Tank: 1500 gallons

Liquid Capacity of Dosing Tank: 1500 gallons

Drainfield Design ☐ N/A

Trench Depth: 36 inches

Trench Width: 3' feet

Line Spacing: 9 feet (O.C.)

Total line length: 600 feet

# of Lines: 6 @ 100 feet

Depth of Media: 12" inches (Type) Approved infiltrative

Distribution Device: Pressure Manifold

Bed Design *(For Repair Installations ONLY.)* ☒ N/A

Bed Depth: _____ inches

Bed Width: _____ feet

Total line length: _____ feet

# of Lines: _____ @ _____ feet

Depth of Media: _____ inches (Type) _____

Distribution Device: _____

Water Supply Source

☒ Municipal ☐ Private Well ☐ Community Well

☐ Other _____


Minimum System Setbacks

Distance from Building Foundation: 25' feet

Distance from Property Line: >10' feet

Distance from Water Supply Source: 10' feet

SKETCH OF SYSTEM LAYOUT
(Proposed Layout)




Comments: System Classification & Type: Install type 1116 pump to approved system. pump to 6 lines @ 100' each from pressure manifold

DENR Authorized Agent: Jason Jackson Signature: Jason Jackson

File #
5691B

App #
4051




Diamond Homes
Development
Dassen Rader
704-791-4692

O.K. to use existing system for a retaining wall.


Jimmy Nunn, R.S.
1/23/09

Proposed Retaining Wall
1/15/09


Re-locate if possible
763
NL763
5' SIDEYARD
40' MBS
762
729
Look
66.00'
57
778-834
66.00'
758
NL758
100' MBS*
761
NL761
726 drain
725 drain
724 repair
727 drain
760 drain
765 drain
766 drain
768 repair
769 repair
770 repair
771 repair
773 repair
774 repair
752
NL752
5' SIDEYARD
40' MBS
REPAIR AREA
51.06'
DRAIN FIELD
Driveway
Driveway
REPAIR AREA
80.05'
20' SETBACK
741
NL741
759
SIP
Map
WITHERS COVE ROAD
Map

File #
56918

App #
4051



Diamond Homes
Development
Dassen Rader
704-791-4692

O.K. to use existing system for a retaining wall.

Jerry Rhyne R.S.
1/28/09

Proposed
Retaining
Wall
1/15/09

Groundwater & Wastewater Services
Septic Project File & Data Review Worksheet

2007
U+S OK

GWS File #: 5690B WASPS App #: 2569

Primary ES assigned to project: CS

Secondary ES assigned to project:

Project Type: New System ☐ Alteration ☐ Repair ☐ Modified Plot Plan ☐ U+S ☑

I. File Review:

Rule or Law				
	Permit Application			
1937(d)	Is the Application complete	Yes ☐	No ☐	N/A ☐
1937(d)	Is there a Site plan/Plat with application	Yes ☐	No ☐	N/A ☐
1937(d)	Is the Facility shown?	Yes ☐	No ☐	N/A ☐
1937(d)	Are appurtenances shown	Yes ☐	No ☐	N/A ☐
	Site Evaluation Information			
1939 (a)(1)	Topography and Landscape Position Recorded?	Yes ☐	No ☐	N/A ☐
1940 (a-g)	Slope % Recorded?	Yes ☐	No ☐	N/A ☐
1939 (a)(2)	Texture Class Recorded?	Yes ☐	No ☐	N/A ☐
1939 (a)(2)	Structure type Recorded?	Yes ☐	No ☐	N/A ☐
1939 (a)(2)	Consistence Recorded?	Yes ☐	No ☐	N/A ☐
1939 (a)(2)	Mineralogy Recorded?	Yes ☐	No ☐	N/A ☐
1939 (a)(3)	Soil Wetness Condition Recorded?	Yes ☐	No ☐	N/A ☐
1939 (a)(4)	Soil Depth to Rock or Parent Material Recorded When Encountered	Yes ☐	No ☐	N/A ☐
1939 (a)(5)	Depth to Restrictive Horizons Recorded When Encountered?	Yes ☐	No ☐	N/A ☐
1939 (a)(6)	Sufficient Available Space Recorded?	Yes ☐	No ☐	N/A ☐
1937(m)	Are the Profile Locations Shown?			
1939(a)	Are the S/PS Profiles in system & in repair area?	Yes ☐	No ☐	N/A ☐
& 1945(b)	Number of auger borings made: _____ Were sufficient auger borings made?	Yes ☐	No ☐	N/A ☐
1939(d), 1955, 1956, 1957	LTAR	Yes ☐	No ☐	N/A ☐
	Improvement Permit/Construction Authorization			
1937(g) 130A-336(a)	Proposed System Type stated-Initial	Yes ☐	No ☐	N/A ☐
1945(b)	Proposed System Type stated-Repair	Yes ☐	No ☐	N/A ☐
130A-336 (a)(3)	System location identifiable by setbacks - Initial	Yes ☐	No ☐	N/A ☐
1937(g) 1945(b)	System components shown – Initial	Yes ☐	No ☐	N/A ☐
1945(b)	Repair area shown	Yes ☐	No ☐	N/A ☐
1937 (f)(g)	Does System design match facility, flow & WWcharacteristics?	Yes ☐	No ☐	N/A ☐
1937 (f)(g)	Is System design consistent with soil/site conditions?	Yes ☐	No ☐	N/A ☐
1937 (f)(g)	Is the System located in the approved area?	Yes ☐	No ☐	N/A ☐
130A-336(a)	Is the Design flow (gpd) indicated?	Yes ☐	No ☐	N/A ☐

130A-336(a)	Number of Bedrooms, employees, seats, etc. indicated?			
1937(g)	Trench depth indicated?	Yes ☐	No ☐	N/A ☐
1937(g)	Trench width indicated?	Yes ☐	No ☐	N/A ☐
1937(g)	Trench length indicated?	Yes ☐	No ☐	N/A ☐
130A-336(a)(1)	Proposed/existing well shown?	Yes ☐	No ☐	N/A ☐
130A-336(a)(1)	Property line lengths shown?	Yes ☐	No ☐	N/A ☐
130A-336(a)	Facility/appurtenance setbacks shown from fixed points?	Yes ☐	No ☐	N/A ☐
1937(i)	Operation Permit	Yes ☐	No ☐	N/A ☐
1937(i)	System type as described in table V(a) of rule .1961	Yes ☐	No ☐	N/A ☐
1937(i)	Conditions for system performance, operation, maintenance, monitoring and reporting.	Yes ☐	No ☐	N/A ☐

H. WASPS Review:

Construction authorization issued	Yes ☐	No ☐	N/A ☐
Installation approval issued	Yes ☐	No ☐	N/A ☐
Operation permit issued	Yes ☐	No ☐	N/A ☐
Other related documentation	Yes ☐	No ☐	N/A ☐


Comments: # Items requiring correction/modification: _____

CA issued date: _____

OP issued date: _____

Review performed by: _____ Date performed: 8-9-07

N86°41'41"E
316.72'
PROP. PAVEMENT
EXIST. PAVEMENT
60' PUBLIC R/W
DRIVE
PT = 2+79.09
N35°33'55"E
79.01'
R=720.00'
L=20.58'
N07°09'20"W
51.43'
N35°33'55"E
35.54'
R=680.00'
L=63.00'
162,822 sq.ft.
3.74 ac.
34
N16°49"E
51.43'
PROPOSED TRANSFORMER
F.O. w/ Splice Vault
Divider
N72°05'05"W
85.32'
R=642.91'
L=92.91'
N72°05'05"W
85.32'
R=642.91'
L=92.91'
147,126 sq.ft.
3.38 ac.
33
N06°58'25"W
49.60'
N51°51'22"W
57.17'
R=375.00'
L=127.57'
SETBACK
FROM
PROP.
PAVEMENT
AR=245.00'
N10°35'47"E
R=175.00'
L=109.16'
56.55'
N10°35'47"E
R=125.00'
L=78.81'
56.55'
R=95.00'
L=88.14'
37.28'
46.39'
64+00
65+00
66+00
11+00
12+00
13+00
14+00
3+00
4+00
53+00
54+00
620
618
616
614
612
610
622
624
626
628



SITE PLAN SURVEY
OF
LOT 34, THE SANCTUARY PHASE 2 MAP 2
STEELE CREEK TWSP., MECKLENBURG CO. NORTH CAROLINA
SURVEYED FOR PAUL KUMAR
DH LDO 2004.SANC PH2

Michelone, Jeremy

From: lee@tcwwastewater.com
Sent: Wednesday, January 21, 2009 3:17 PM
To: Michelone, Jeremy
Subject: RE: Sanctuary lot 34 phase2
Attachments: water record for- Coulston.xls

Jeremy,

The home belongs to Earl Coulston. The address is 10419 Wildlife Rd. Tim says this system has been giving us issues for a while and we have been gathering data to help diagnose the problem. Please see the attached spread sheet from Tim re: the customers water usage. Brandon Long from our company will contact you and the home owner to set up at meeting. Just incase you need it, Brandon's number is 704-202-4613.Thanks so much for your help.

Lee Boyd
TCW Wastewater Mgnt.
704-283-2740
Fax 704-283-2733

- Level D-Box
- Fill in low spots
- French Drain
- Try to use less water

Walker, Philo

From: vicki@tcwwastewater.com
Sent: Friday, May 14, 2010 10:25 AM
To: Walker, Philo
Cc: Tim Bannister
Subject: 10419 Wildlife - Coulston
Attachments: 10419 Wildlife Coulston.pdf

Philo,

Please find attached two spreadsheets evaluating water usage at the Coulston home at 10419 Wildlife Rd, The Sanctuary. Also attached are the last 4 inspection reports done by TCW. Any questions, call me on my mobile phone.

Tim Bannister
TCW Wastewater Management
P. O. Box 1830
Indian Trail, NC 28079
email: vicki@tcwwastewater.com
704-283-2740 phone
704-283-2733 fax
704-201-7514 mobile

5690B