Date Received 5-9-94

SIR No. 20994

T. C. No. 001-201-05

Map Date 1978

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER (LAST) MARTIN (FIRST) DEVELOPMENT (MIDDLE) GROUP

2) ADDRESS OF OWNER 1800 ONE TRYON CENTER CHARLOTTE NC ZIP 28284

3) PHONE NO Home _____ Office 332-1242

4) LOCATION OF PROPERTY NORTH POINT RD (STREET OR COUNTY ROAD)

5) SUBDIVISION LOOKOUT POINT LOT NO 14 BLOCK NO _____

MAP BOOK NO [redacted]1 PAGE NO [redacted]20

6) DEED REFERENCE DEED BOOK N/A PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Owner

EHD-5-75

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. _____

T.C. NO. _____

(Ground Absorption Sewage Disposal)

OWNER: _____ PLAT NO: _____
ADDRESS: _____ LOT SIZE: _____
LOCATION OF SITE: _____

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP				
9. SITE CLASSIFICATION				
10. SOIL SERIES				

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: _____
Title: _____ Date: _____


471'
445'
North Point
Rd.

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. _____

T.C. NO. _____

(Ground Absorption Sewage Disposal)

OWNER: _____ PLAT NO: _____
ADDRESS: _____ LOT SIZE: _____

LOCATION OF SITE: _____

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP				
9. SITE CLASSIFICATION				
10. SOIL SERIES				

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: _____
Title: _____

Date: _____


471'
445'
North Point
Rd.

Serial No. 6220

SIR No. 20994

T C No. P0 001-201-05

Date Issued May 30, 1985

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Martin Development Group
LAST FIRST MIDDLE

ADDRESS OF OWNER 1800 One Tryon Center Charlotte, NC ZIP 28284

LOCATION OF PROPERTY North Point Rd.
STREET OR COUNTY ROAD

SUBDIVISION Lookout Point LOT NO 30 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and [illegible] by the Mecklenburg County Department of Environmental Health on the lot described above. [illegible] conducted on that portion of the lot as indicated on the above plot.

The permeability rate determined by the investigation was Provisionally Suitable. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. A permit [illegible] Mecklenburg County Department of Environmental Health [illegible] the wastewater treatment system on the said lot.
2. The [illegible] by the Mecklenburg County Department of Environmental Health [illegible] and on the size and type [illegible] there.
3. This approval [illegible] the above plot.
4. The [illegible] the [illegible] in the [illegible] Department of Environmental Health [illegible] acceptable for system installation [illegible]

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

EHD-5-76 Soil Scientist

Environmental Health Director or Authorized Section Head

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 20994 DATE: 6-23-86

TC: PO 001-201-05/L

SERIAL № 10117

Permission is hereby given to ____ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated _____. All work shall be completed on or before _____, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction PCC

Absorption and or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400' feet

Number of Lines 4

Depth of Stone 12" inches

Distance from House 5'± feet

Distance from Property Line 10'± feet

Distance from Well 50'± feet

NAME OF OWNER WIGHTMAN + CO.

LOCATION OF PROPERTY 16109 NORTH POINT RD

Comments: 4 lines x 100' long x 3' wide x 12" stone

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

PROPOSED PLOT PLAN

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 20994

TC: 60·001-201·05

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: Walt Thomas

Date: 6-11-96

APPLICATION FOR AN IMPROVEMENT PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

OFFICE USE ONLY

FILE: 20994

TC: PD CC1-201-05

JOB LOCATION

① ADDRESS: 16109 (STREET NO) North Point (STREET) Road ② FILE:

③ CITY: ④ TAX PARCEL NO.

⑤ SUBDIVISION: Lucent Point ⑥ LOT: 30 ⑦ BLOCK:

OWNER

⑧ NAME: Whitman + Co. (FIRST) (MIDDLE) (LAST)

⑨ MAILING ADDRESS: 234 Randolph Road

⑩ CITY: Charlotte ⑪ STATE: NC ⑫ ZIP: 28207

⑬ PHONE: (WORK) 704 334-0635 ⑭ (HOME)

REQUEST

This request is for a(n):

⑮ ☑ New installation permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type?

㉓ Maximum occupancy? ㉖ Maximum number of employees?

㉔ Basement? ☐ yes ☐ no ㉗ Maximum number of seats?



㉘ Accurately dimensioned plot

WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☐ Individual well

B ☐ Municipal system

C ☐ Community well

D ☑ Community system

㉜ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: William A. Long

Date: 9/27/05

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Serial No. 9547

SIR No. 20994

Date Issued 6/12/1986

T. C. No. 001-201-05 PO

Map Date V CKT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Wightman & Co.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 2034 Randolph Road ZIP 28207

LOCATION OF LOT 16109 North Point Road
(STREET OR COUNTY ROAD)

SUBDIVISION Lookout Point LOT NO 30 BLOCK NO.

MAP BOOK NO. PAGE NO.

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number_____. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Kelly Crandall
Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

For Applicant's Copy

C of A (s) No. 20994

Date Issued 7-9-86 **Serial** 8724 T C PO No. 001-201-05

✓ CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Wightman Co. (LAST) (FIRST) (MIDDLE)

Location of Property 16109 North Point Rd.

Application Number — Permit Number —

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PCC

Total Length of Drain Tile 400' Number of Lines 4

Depth of Filter Material 12" Cover Depth 12"-18"

Water Supply Source Comm. Distance from Water Source —

Excavation Inspected 7-9-86 (DATE) Tank Inspected 7-9-86 (DATE)

Nitrification Field Inspected 7-9-86 (DATE)

Washing Machine Line Inspected If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 1986, 500ST, CON, 1200 SFT, 12G, cecil

B. R. Ferguson
Environmentalist

EHD-5-76