Date Received June 17, 82

SIR No. 18794

T. C. No. 133-251-18

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER SULLIVAN (LAST) EARL (FIRST) J. (MIDDLE)

2) ADDRESS OF OWNER 5232 ALBEMARLE RD. ZIP _____

3) PHONE NO Home 536-7095 Office 568-8010


4) LOCATION OF PROPERTY 7128 LAWYERS RD. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 18 BLOCK NO _____

MAP BOOK NO 133 PAGE NO 251

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and inspection of the premises above described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Dan K. Honeycutt
OWNER AGENT 372-4500

EHD-5-76

Environmental Health Department's Copy

Serial No. 4590

PTR No. 18794

Date Issued 6-21-82

T C. No. 133-251-18

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Sullivan, (LAST) Earl. (FIRST) J. (MIDDLE)

ADDRESS OF OWNER 5232 Albemarle Rd., Charlotte, NC ZIP 28212

LOCATION OF PROPERTY 7128 Lawyers Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 18 BLOCK NO



PLOT PLAN

This is to certify that [illegible] Mecklenburg County Department of Environmental Health [illegible] was conducted on [illegible]

The permeability rate [illegible] Provisionally Suitable [illegible] is approved for the [illegible] subsurface soil absorption [illegible]

[illegible]

This approval is granted [illegible] Commission of the North Carolina Department of Human Resources and the Mecklenburg County Health Director [illegible] in the future [illegible] this approval will not have been granted and the new [illegible] on the issuance [illegible]

William H. Wilson
Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

FHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. NO. W 284
T.C. NO. 133-251-18

(Ground Absorption Sewage Disposal)

OWNER: Earl J. Sullivan
ADDRESS: 5232 Albemarle Rd.
COUNTY: Charlotte, N.C.
LOCATION OF SITE: 7128 Fawver Rd

DATE REQUESTED:
PLAT NO:
LOT SIZE: 25,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-6%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S (PS) U clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS U 48"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS U None	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) PS U 70-76 ground water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation rate)	S (PS) U moderate	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U See Note	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cec. l			


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments: Lot has limited area of provisionally suitable soils- City of Charlotte Building Permit 23086 issued 6-8-82 Sewer line approximately 125 feet from right rear corner of lot.

Described By: William A. Mackin
Title: Soil Scientist
Date: 6-16-82

DHS Form 2601
Sanitation
EHD 539 (3/82)


125'
Building + Parking
200'
200'
Lowyers Rd
125'