

8005 PLEASANT GROVE RD

03517447

1/3/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3969B DATE: 6-4-99

TC: 035-174-97 ☒ L ☐ CRT

SERIAL Nº 17710

Name of Owner Kenneth R. Rodgers Juris.: _____

Address of Property 8005 Pleasant Grove Road

Inspection Data:

Tank Material Existing

Total Length of Drainfield 120'

Number of Lines 2 @ 60'

Cover Depth 18"

Water Supply Source Municipal

Distance to Water Source _____

Excavation Inspected 6-4-99

Tank(s) Inspected existing

Wash Line Inspected 6-4-99

High Water Alarm Inspected N/A

PLOT

Design 1999 Repair, CON, 360 SFB, 18"stone, 6"sand CTR# Big M Construction

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☒ altered or ~~repaired~~

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of I5A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of I5A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Repair to the existing washer line

Phillip S. Walker R.S.
Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3969B DATE: 6-1-99

TC: 035-174-47 ☒ L

SERIAL Nº 17841

Permission is hereby given to _____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5-18-99. All work shall be completed on or before 7-1-99, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation ~~Permit must be obtained~~ from the Mecklenburg County Health Department before any system can be covered up or placed into service. ~~The issuance~~ of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. pond



PLOT OF SYSTEM

Liquid Capacity of Septic Tank Existing gallons

Liquid Capacity of Dosing Tank NA gallons

Tank Construction Existing

Trench Depth 36"

Absorption and/or Nitrification Lines:

~~Trench~~ Bed Width 6' feet

Trench Walls Scored and Porous yes

Total Line Length 120' feet

Number of Lines 2(60')

Depth of Stone 18" stone, 6" sand inches

Distance from House >5' feet

Distance from Property Line >10' feet

Distance from Well >50' feet

property on municipal water now

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER Kenneth R. Rodgers

LOCATION OF PROPERTY 2005 Pleasant Grove Road

Comments: Check existing old well to see if properly abandoned | Install Washer bed 6'wd x 60'long x 18"stone x 6"sand | Keep the septic system >50' from the pond

Phil S. Walker RS.

Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

3969B

Name: Rodgers (Last) Kenneth (First) R (MI)

Address: 8005 Pleasant Grove Rd Phone: 704

City: Charlotte State: NC

Date: 5/18/99

Name: Rodgers (Last) Kenneth (First) R (MI)

Address: 8005 Pleasant Grove Rd Phone: 704


City: Charlotte State: NC

Township (check one):
☒ Charlotte

1956

5

5/18/99



plumb Kitchen sink into the septic tank

6" wd x 60' long x 18" stone x 6" sand

900 632 4994 ULOCO

Fax copy of well abandonment form