INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3270-A DATE: 5-18-87

TC: 001-052-24 ☐ L

SERIAL № 10924

Permission is hereby given to ____ Install or Construct, ✓ After or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 4-20-87. All work shall be completed on or before 6-18-87, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank repair/septic 1 gallons

Liquid Capacity of Dosing Tank ____ gallons

Tank Construction ____

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 75 feet

Number of Lines 1

Depth of Stone 17 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well) 50 feet

NAME OF OWNER Dennis McManus

LOCATION OF PROPERTY 18105 Arbor Pl.

Comments: 1 line 3'X75'X17" stone

Division or Section Head

P.R. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

APPLICATION FOR AN IMPROVEMENT PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 374-[illegible]

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

RECEIVED APR 24 1987 ENVIRONMENTAL HEALTH

RECEIVED APR 21 1987 MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

OFFICE USE ONLY
FILE: 3270A
TC:
SERIAL: Nº . 13220
☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 18105 ARBOR PLACE (STREET NO. / STREET) ② FILE:
③ JURISDICTION: [redacted] 001 052 24
④ SUBDIVISION: POINT LARGO ⑥ LOT: 24 ⑦ BLOCK:

OWNER

⑧ NAME: DENNIS (FIRST) JOSEPH (MIDDLE) McMANUS (LAST)
⑨ MAILING ADDRESS: 18105 ARBOR PLACE
⑩ CITY: HUNTERSVILLE ⑪ STATE: N.C. ⑫ ZIP: 28078
⑬ PHONE: (WORK) ⑭ (HOME)

REQUEST

This request is for a(n):

⑮ ☐ New permit
⑯ ☑ Repair or alteration permit
⑰ ☐ Autherization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? ㉓ Type?
㉔ Maximum occupancy? ㉕ Maximum number of employees?
㉖ Basement? ☐ yes ☑ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☑ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Dennis J. McMa
Date: 4-20-87

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

Environmentalist / Date

Director or Authorized Section Head / Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.