ward

Date Received 6-14-23

APT No 6487

T. C. No.

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Ciucevich (LAST) Francis (FIRST) Paul (MIDDLE)

2) ADDRESS OF OWNER Providence Lane West P.O. Box 834 Matthews NC (ZIP) 28105

3) PHONE NO Home [redacted] 366-3128 Office [redacted] 366-3124


4) LOCATION OF PROPERTY Matthews - Mint Hill Road (STREET OR COUNTY ROAD)

5) SUBDIVISION N/A LOT NO Unrecorded See attached BLOCK NO Unrecorded - See attached

MAP BOOK NO Unrecorded PAGE NO

6) DEED REFERENCE DEED BOOK 3136 PAGE NO 451

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Francis P. Ciucevich

OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
INTER-OFFICE COMMUNICATION

DATE: July 19, 1973

TO: Thomas R. Ward
Environmentalist

FROM: W. Everette Lynn, Jr.,
Soil Scientist
W.E.L.

SUBJECT: Soils investigation on Matthews - Mint Hill Road
APT #6487

Dear Mr. Ward:

On July 17, 1973 a soils investigation was made on the lot in question on the Matthews-Mint Hill Road (N.C. 51) to determine site suitability for a septic tank system. The soils were found to be intergradient between the Cecil and Mecklenburg series. These soils have good aeration and drainage. They also have moderate permeability. Slow percolation rates probably result from a trace of swelling clay minerals. Although these minerals impose some limitation, it is not believed to be serious enough to warrant disapproval of the site.

As a result of these investigations, it is recommended that the site be given conditional approval with design based on a 60 min./in. perc. rate. The conditions affecting approval are that the system be located on the front of the lot (adjacent to N.C.-51) and that adequate room for repair be provided.

WEL/jdg

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203
Telephone 374-2113

Date Issued
1. 7-6-73
2. _____
3. _____

SDR No. 6487
T.C. No. P.O.215-081-12

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Francis Paul Giucevich

ADDRESS OF OWNER Providence Lane West ZIP 28211

LOCATION OF LOT Mathews-Mint Hill Road

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
x	1.	7-5-73	250 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Thomas R. Ward
Environmentalist

(Stencil No.)
HHD 398
8/70

FORM NO.
H-19-8-14-70

ware

SEE INSTRUCTIONS ON BACK

Date Received 6-14-73

ICARIS Application No 6487

T C No


Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) X Install or Construct 2) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms none

5) Business Use Max No Employees 12

6) Washing Machine Yes X No

7) Garbage Disposal Yes X No

8) Dishwasher Yes X No

9) Water Supply
A) Individual Well X
B) Government System
C) Community System
1 Well Source
2 Government System

10) Sewage System
House located within 200 feet of public sewer Yes X No
House located within 200 feet of community sewer Yes X No

11) FHA Case No

12) VA Case No

13) NAME OF OWNER Ciucevich (LAST) Francis (FIRST) Paul (MIDDLE)

14) ADDRESS OF OWNER Providence Lane West P.O. Box 804 Matthews, N.C.

15) PHONE NO Home 366-3128 Office 366-2124

16) LOCATION OF SYSTEM Matthews - Mint Hill Road (STREET OR COUNTY ROAD)

17) SUBDIVISION ~~N/A~~ N/A Lot No Unrecorded Block No Unrecorded

Map Book No Un recorded Page No.

18) DEED REFERENCE — DEED BOOK 3436 AT PAGE 451

19) HAS A PERCOLATION TEST BEEN RUN? X YES NO DATE RUN

20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

6-14-73
DATE OF APPLICATION

P. P. Ciucevich
OWNER

REVISED 8-1-72

HEALTH DEPARTMENT'S COPY